

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9105070178 DOC. DATE: 91/05/02 NOTARIZED: NO DOCKET #
FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362

AUTH. NAME AUTHOR AFFILIATION
RAY, H.B. Southern California Edison Co.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Forwards application for amends to Licenses NPF-10 & NPF-15.
Amend revises Tech Spec 3/4.7.6, "Snubbers," per Generic Ltr
90-09, "Alternative Requirements for Snubber Visual Insp
Intervals & Corrective Actions."

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 6 + 27
TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	1 1	PD5 PD	1 1
	KOKAJKO, L.	2 2		
INTERNAL:	ACRS	6 6	NRR/DET/ECMB 9H	1 1
	NRR/DET/ESGB	1 1	NRR/DOEA/OTSB11	1 1
	NRR/DST 8E2	1 1	NRR/DST/SELB 8D	1 1
	NRR/DST/SICB 7E	1 1	NRR/DST/SRXB 8E	1 1
	NUDOCS-ABSTRACT	1 1	OC/LEMB	1 0
	OGC/HDS3	1 0	<u>REG FILE</u> 01	1 1
	RES/DSIR/EIB	1 1		
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 22

A/A-21
Leip



Southern California Edison Company

23 PARKER STREET

IRVINE, CALIFORNIA 92718

HAROLD B. RAY
SENIOR VICE PRESIDENT

May 2, 1991

TELEPHONE
714-458-4400

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
Amendment Application Nos. 105 and 90
Change to Technical Specification 3/4.7.6, "Snubbers"
San Onofre Nuclear Generating Station
Units 2 and 3

Reference: Generic Letter 90-09, "Alternative Requirements For
Snubber Visual Inspection Intervals and Corrective
Actions"

Enclosed are Amendment Application Nos. 105 and 90 to Facility Operating Licenses NPF-10 and NPF-15, respectively, for the San Onofre Nuclear Generating Station, Units 2 and 3. These Amendment Applications consist of Proposed Change Number (PCN) 352. PCN-352 is a request to revise Technical Specification (TS) 3/4.7.6, "Snubbers." Southern California Edison proposes to replace the existing snubber visual inspection schedule in Surveillance Requirement (SR) 4.7.6.b with the refueling outage based visual inspection schedule, from Generic Letter 90-09, referenced above. Changes to the visual inspection acceptance criteria in SR 4.7.6.c as recommended in Generic Letter 90-09 are also requested. Changes to the Bases for TS 3/4.7.6 are made for consistency.

The proposed changes to TS 3/4.7.6 incorporate the changes recommended in Generic Letter 90-09 with minor editorial clarifications as discussed in a telephone conversation with the NRC staff on March 28, 1991.

NRC approval of this change to TS 3/4.7.6, "Snubbers" is requested by August 3, 1991 which is the currently scheduled start date for the upcoming San Onofre Unit 2, Cycle 6 refueling outage. NRC approval by August 3, 1991 will allow accessible and inaccessible snubbers to be categorized separately or grouped together prior to performing snubber visual inspections during

9105070178 910502
PDR ADOCK 05000341
P PDR


Adol
111

May2, 1991

the Unit 2 Cycle 6 refueling outage so the Cycle 6 outage inspection results may be used for establishing the next snubber inspection interval.

If you would like additional information on this Technical Specification change request, please let me know.

Very truly yours,



Enclosure

cc: J. B. Martin, Regional Administrator, NRC Region V
C. Caldwell, NRC Senior Resident Inspector, San Onofre Units
1, 2 and 3

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

Application of SOUTHERN CALIFORNIA)	Docket No. 50-361
EDISON COMPANY, <u>ET AL.</u> for a Class 103)	
License to Acquire, Possess, and Use)	
a Utilization Facility as Part of)	Amendment Application
Unit No. 2 of the San Onofre Nuclear)	No. 105
Generating Station)	

SOUTHERN CALIFORNIA EDISON COMPANY, ET AL. pursuant to 10 CFR 50.90, hereby submit Amendment Application No. 105.

This amendment application consists of Proposed Technical Specification Change No. NPF-10-352 to Facility Operating License No. NPF-10. Proposed Technical Specification Change No. NPF-10-352 is a request to revise Technical Specification 3/4.7.6, "Snubbers." The proposed Technical Specification change will replace the existing visual inspection schedule in Surveillance Requirement 4.7.6.b (Visual Inspection) with the snubber visual inspection schedule recommended in NRC Generic Letter 90-09 and will revise Surveillance Requirement 4.7.6.c (Visual Inspection Acceptance Criteria) essentially as recommended in NRC Generic Letter 90-09.

Subscribed on this 1ST day of MAY, 1991.

Respectfully submitted,

SOUTHERN CALIFORNIA EDISON COMPANY

By:

Harold B. Ray
Harold B. Ray
Senior Vice President

State of California


County of Orange

On 5/1/91 before me, BARBARA A. MCCARTHY,
personally appeared HAROLD B. RAY, personally known
to me (~~or proved to me on the basis of satisfactory evidence~~) to be the
person whose name is subscribed to the within instrument and
acknowledged to me that he executed the same in his authorized capacity,
and that by his signature on the instrument the person, or the entity
upon behalf of which the person acted, executed the instrument.

WITNESS my hand and official seal.

Signature

Barbara A. McCarthy



James A. Beoletto
Attorney for Southern
California Edison Company

By:

James A. Beoletto
James A. Beoletto

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

Application of SOUTHERN CALIFORNIA)	Docket No. 50-362
EDISON COMPANY, <u>ET AL.</u> for a Class 103)	
License to Acquire, Possess, and Use)	
a Utilization Facility as Part of)	Amendment Application
Unit No. 3 of the San Onofre Nuclear)	No. 90
Generating Station)	

SOUTHERN CALIFORNIA EDISON COMPANY, ET AL. pursuant to 10 CFR 50.90, hereby submit Amendment Application No. 90.

This amendment application consists of Proposed Technical Specification Change No. NPF-15-352 to Facility Operating License No. NPF-15. Proposed Technical Specification Change No. NPF-15-352 is a request to revise Technical Specification 3/4.7.6, "Snubbers." The proposed Technical Specification change will replace the existing visual inspection schedule in Surveillance Requirement 4.7.6.b (Visual Inspection) with the snubber visual inspection schedule recommended in NRC Generic Letter 90-09 and will revise Surveillance Requirement 4.7.6.c (Visual Inspection Acceptance Criteria) essentially as recommended in NRC Generic Letter 90-09.

Subscribed on this 1ST day of MAY, 1991.

Respectfully submitted,

SOUTHERN CALIFORNIA EDISON COMPANY

By:

Harold B. Ray
Harold B. Ray
Senior Vice President


State of California
County of Orange

On 5/1/91 before me, BARBARA A. MCCARTHY,
personally appeared HAROLD B. RAY, personally known
to me (~~or proved to me on the basis of satisfactory evidence~~) to be the
person whose name is subscribed to the within instrument and
acknowledged to me that he executed the same in his authorized capacity,
and that by his signature on the instrument the person, or the entity
upon behalf of which the person acted, executed the instrument.

WITNESS my hand and official seal.

Signature

Barbara A. McCarthy



James A. Beoletto
Attorney for Southern
California Edison Company

By:

James A. Beoletto
James A. Beoletto