

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9112020042 DOC. DATE: 91/11/25 NOTARIZED: YES DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362

AUTH. NAME AUTHOR AFFILIATION
 RAY, H.B. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Amend Applications 112 & 96 to Licenses NPF-10 & NPF-15, respectively. Amend applications consist of Proposed Change Number (PCN) PCN-363, requesting rev to TSS 3/4.7.8, "Fire Suppression Sys" & 3/4.8.1, "Electrical Power Sys."

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+18
 TITLE: OR Submittal: General Distribution

NOTES:


	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD5 LA		1	1		PD5 PD		1	1
	KOKAJKO, L.		2	2					
INTERNAL:	ACRS		6	6		NRR/DET/ECMB 7D		1	1
	NRR/DET/ESGB		1	1		NRR/DOEA/OTSB11		1	1
	NRR/DST 8E2		1	1		NRR/DST/SELB 7E		1	1
	NRR/DST/SICB8H7		1	1		NRR/DST/SRXB 8E		1	1
	NUDOCS-ABSTRACT		1	1		OC/LFMB		1	0
	OGC/HDS3		1	0		REG FILE 01		1	1
	RES/DSIR/EIB		1	1					
EXTERNAL:	NRC PDR		1	1		NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 22

APJ



Southern California Edison Company

23 PARKER STREET

IRVINE, CALIFORNIA 92718

HAROLD B. RAY
SENIOR VICE PRESIDENT

November 25, 1991

TELEPHONE
714-458-4400

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
Amendment Application Nos. 112 and 96
Change to Technical Specifications 3/4.7.8, "Fire
Suppression System" and 3/4.8.1, "Electrical Power
Systems"
San Onofre Nuclear Generating Station
Units 2 and 3

Enclosed are Amendment Application Nos. 112 and 96 to Facility Operating Licenses NPF-10 and NPF-15, respectively, for the San Onofre Nuclear Generating Station, Units 2 and 3. These Amendment Applications consist of Proposed Change Number (PCN) 363. PCN-363 is a request to revise Technical Specifications (TSs) 3/4.7.8, "Fire Suppression Systems" and 3/4.8.1, "Electrical Power Systems". Southern California Edison proposes to delete the phrase "during shutdown" from the fire pump diesel engine surveillance requirement 4.7.8.1.2.c. This is an administrative change for compliance purposes to clarify that surveillance of the fire pump diesel engine is allowed at any time, including when one or both Units 2 and 3 are in operation. Also, an editorial change to the Unit 3 electrical power system surveillance requirement 4.8.1.1.1.a is requested to correct the misidentification of breakers 2A0619 and 2A0417.

If you would like additional information on this Technical Specification change request, please let me know.

Sincerely,

cc: J. B. Martin, Regional Administrator, NRC Region V
C. Caldwell, NRC Senior Resident Inspector, San Onofre Units
1, 2 and 3
J. H. Hickman, California Department of Health Services

9112020042 911125
PDR ADOCK 05000361
PDR

Aool
111