

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8602130178 DOC. DATE: 86/02/07 NOTARIZED: YES DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 BASKIN, K. P. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125)

SUBJECT: Forwards application for Amends 33 & 19 to ^{see 615} Licenses NPF-10 & NPF-15, respectively, consisting of Proposed Tech Spec Change NPF-10/15-198 deleting refueling water storage tank isolation valve from surveillance requirement. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 43 SIZE: 2 + 118
 TITLE: OR Submittal: General Distribution

NOTES: ELD Chandler 1cy.
 OL: 02/16/82
 ELD Chandler 1cy.
 OL: 11/15/82

05000361

05000362

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PWR-B ADTS	1 0	PWR-B PD7 PD 01	5 5
PWR-B EB	1 1	PWR-B PEICSB	1 1
PWR-B FOB	1 1	ROOD, H	1 1
PWR-B PEICSB	1 1	PWR-B RSB	1 1

INTERNAL: ACRS 09
 ELD/HDS2
 NRR/DSRO/RRAB
REG FILE 04

ADM/LFMB
 NRR/DHFT/TSCB
 NRR/ORAS
 RGN5

EXTERNAL: 24X
 LPDR 03
 NSIC 05

EG&G BRUSKE, S
 NRC PDR 02

NOTES:

1 1

Rec'd w/cheer #150.00
 # A573651

Southern California Edison Company

SCE

P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

KENNETH P. BASKIN
VICE PRESIDENT

TELEPHONE
818-302-1401

February 7, 1986

Director, Office of Nuclear Reactor Regulation
Attention: Mr. H. R. Denton
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 2 and 3

Enclosed are three executed and forty conformed copies of Amendment Application No. 33 to Facility Operating License NPF-10 and Amendment Application No. 19 to Facility Operating License NPF-15 for San Onofre Nuclear Generating Station, Units 2 and 3, respectively.

Amendment Application No. 33 for Unit 2 and No. 19 for Unit 3 consist of the following proposed changes:

1. Proposed Change NPF-10/15-198 is a request to revise Technical Specification 3/4.5.2 "ECCS Sub-Systems, Tavg greater than or equal to 350° F." The proposed change would delete RWST Isolation Valve 10-068 from surveillance requirement 4.5.2.a. Currently, the position of this valve must be verified as locked open once every 12 hours. A design change will remove this valve from the system, therefore, the surveillance requirement will no longer be performed.
2. Proposed Change NPF-10/15-207 is a request to revise Technical Specifications 3/4.3.2 "ESFAS Instrumentation," 3/4.6.3 "Containment Isolation Valves," and 3/4.7.1.5 "Main Steam Isolation Valves." The proposed change would increase the MSIV response time from 5 to 8 seconds.
3. Proposed Change NPF-10/15-209 is a request to revise Technical Specification 3/4.9.6 "Refueling Machine." The proposed change would add limiting conditions for operation and surveillance requirements for the auxiliary hoist which is being added to the refueling machine. This proposed change was previously submitted by the Southern California Edison Company's (SCE) letter dated December 10, 1985.

8602130178 860207
PDR ADOCK 05000361
PDR

Rec'd w/ktel #150.00
#A573651

A201
1/43

Mr. H. R. Denton

-2-

4. Proposed Change NPF-10/15-210 is a request to revise Technical Specification 3/4.6.2 "Iodine Removal System." The proposed change would delete existing requirements related to the spray chemical addition system and add new requirements for the use of trisodium phosphate for post-accident containment sump pH control. This change supersedes Proposed Change NPF-10/15-125 which was submitted by SCE's letter dated April 27, 1984.
5. Proposed Change NPF-10/15-212 is a request to revise Technical Specification 3/4.7.6 "Snubbers." The proposed change revises requirements relating to visual inspection and refueling interval inspections of snubbers to reflect current NRC Staff positions. This proposed change was previously submitted by SCE's letter dated December 12, 1985.
6. Proposed Change NPF-10/15-213 is a request to revise Technical Specification 3/4.1.1.2 "Moderator Temperature Coefficient." The proposed change would increase the negative MTC limit from -2.5×10^{-4} delta k/k/°F to -3.0×10^{-4} delta k/k/°F. This proposed change was previously submitted by SCE's letter dated November 27, 1985.
7. Proposed Change NPF-10/15-214 is a request to revise Technical Specification 3/4.4.7 "RCS Specific Activity." The proposed change would revise actions and reporting requirements relating to RCS specific activity to be consistent with NRC Generic Letter 85-19.

Pursuant to 10 CFR 170.12, an amendment application fee of \$150.00 is required for each license amendment request. Accordingly, SCE's check for \$150.00 is enclosed.

Very truly yours,

Kenneth P. Boston

Enclosures

cc: Harry Rood, NRC (to be opened by addressee only)
Joseph O. Ward, California Department of Health Services
F. R. Huey, USNRC Senior Resident Inspector, Units 1, 2 and 3
J. B. Martin, Regional Administrator, USNRC Region V