

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8803300415 DOC. DATE: 88/03/11 NOTARIZED: NO DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 MORGAN, H. E. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 MARTIN, J. B. Region 5, Ofc of the Director

SUBJECT: Forwards followup rept of Tech Spec fire rated assemblies
 (specifically fire doors) found inoperable during routine
 surveillances in Feb 1988. Rept provides updated info
 associated w/ongoing condition initially reported in 1983.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES | | | RECIPIENT ID CODE/NAME | COPIES | |
|-----------|---------------------------|--------|------|--|---------------------------|--------|------|
| | | LTTR | ENCL | | | LTTR | ENCL |
| | PDS PD | 1 | 1 | | HICKMAN, D | 2 | 2 |
| INTERNAL: | ACRS | 2 | 2 | | AEOD | 1 | 1 |
| | DEDRO | 1 | 1 | | NRR MORISSEAU, D | 1 | 1 |
| | NRR/DLPQ/PEB11B | 1 | 1 | | NRR/DLPQ/QAB10A | 1 | 1 |
| | NRR/DOEA DIR11E | 1 | 1 | | NRR/DREP/EPB10D | 1 | 1 |
| | NRR/DREP/RPB10A | 2 | 2 | | NRR/DRIS DIR9A2 | 1 | 1 |
| | NRR/PMAS/ILRB12 | 1 | 1 | | OE LIEBERMAN, J | 1 | 1 |
| | OGC 15-B-18 | 1 | 1 | | REG FILE 02 | 1 | 1 |
| | RES/DRPS DIR | 1 | 1 | | RGNS FILE 01 | 1 | 1 |
| EXTERNAL: | LPDR | 1 | 1 | | NRC PDR | 1 | 1 |
| | NSIC | 1 | 1 | | | | |

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 24

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN
STATION MANAGER

March 11, 1988

TELEPHONE
(714) 368-6241

RECEIVED
NRC
REGION V
183 MAR 13 P 12:51

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - February 1988
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),
dated February 18, 1988

In accordance with our referenced letter, this submittal provides the follow-up report of Technical Specification fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in February 1988.

Fire doors found inoperable during the February routine surveillances are identified in the Attachment under Sections I, II and III, and include: 15 latching mechanism failures and 5 closure mechanism failures. Section IV addresses miscellaneous deficiencies other than those of Section I, II and III, which were identified either during routine or special inspections. No doors were found blocked open in February.

As each of these deficiencies was identified, compensatory fire watches pursuant to Technical Specification 3.7.9, Action Statement "a", were established and will remain in effect until the door is restored to operable status.

8803300415 880311
PDR ADOCK 05000361
F PDR

11
IF-81

Mr. J. B. Martin

-2-

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in March 1988 will be submitted during April 1988.

If you require any additional information, please so advise.

Sincerely,

HEMog

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)
U. S. Nuclear Regulatory Commission Document Control Desk
Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF FEBRUARY 1988
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 15, as follows:

| <u>Door Number</u> | <u>Inoperable</u> | <u>Operable</u> |
|--------------------|-------------------|-----------------|
| AC-349 | 09/18/87 | 02/11/88 |
| FH3-103 | 12/09/87 | 02/04/88 |
| AC-416 | 12/16/87 | - - - |
| AC-122 | 12/30/87 | 02/06/88 |
| AR-301 | 01/13/88 | 02/01/88 |
| AR-305 | 01/16/88 | 02/01/88 |
| FH3-304 | 01/22/88 | 02/04/88 |
| AC-442 | 01/24/88 | - - - |
| AC-417 | 01/27/88 | - - - |
| AR-502 | 02/01/88 | 02/18/88 |
| FH2-103 | 02/11/88 | 02/18/88 |
| AC-415 | 02/14/88 | 02/18/88 |
| FH3-404 | 02/16/88 | 02/28/88 |
| AC-314 | 02/17/88 | - - - |
| AC-350 | 02/28/88 | - - - |

II. Closure Mechanism Failures:

Number of doors inoperable - 5, as follows:

| <u>Door Number</u> | <u>Inoperable</u> | <u>Operable</u> |
|--------------------|-------------------|-----------------|
| FH2-404 | 11/16/87 | 02/13/88 |
| AR-301 | 01/16/88 | 02/01/88 |
| AR-305 | 01/16/88 | 02/01/88 |
| C2-406 | 01/22/88 | - - - |
| FH2-103 | 01/26/88 | 02/11/88 |

III. Doors Blocked Open:

Number of doors blocked open - None

IV. Technical Specification Fire Doors Determined To Have Been Inoperable Due To Miscellaneous Deficiencies:

A. Door with Top Frame Support Insufficient Under Fire Test Conditions

| <u>Door Number</u> | <u>Inoperable</u> | <u>Operable</u> |
|--------------------|-------------------|-----------------|
| AC-351 | 05/21/87 | - - - |