

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8805090152 DOC. DATE: 88/05/05 NOTARIZED: NO DOCKET #  
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern California 05000361  
 50-362 San Onofre Nuclear Station, Unit 3, Southern California 05000362

AUTH. NAME AUTHOR AFFILIATION  
 MEDFORD, M.O. Southern California Edison Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC request for addl info supporting util 880405  
 justification for continued operation w/ C-E tube plugs.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: OR Submittal: Inservice Inspection/Testing/Relief from ASME Code

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES			RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL			LTTR	ENCL
	PD5 LA	1	0		PD5 PD	5	5
	HICKMAN, D	1	1				
INTERNAL:	ACRS	10	10		AEOD/DOA	1	1
	AEOD/DSP/TPAB	1	1		ARM/DAF/LFMB	1	0
	NRR/DEST/MEB 9H	1	1		NRR/DEST/MTB 9H	1	1
	NRR/PMAS/ILRB12	1	1		NUDOCS-ABSTRACT	1	1
	OGC 15-B-18	1	0		<u>REG FILE</u> 01	1	1
	RES/DE/EIB	1	1				
EXTERNAL:	EG&G ROCKHOLD, H	1	1		LPDR	1	1
	NL 007 HEMMING	1	1		NRC PDR	1	1
	NSIC	1	1				

TOTAL NUMBER OF COPIES REQUIRED: LTTR 32 ENCL 2

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
  
  
  
  
  
  
  
  
  
R  
I  
D  
S  
/  
A  
D  
D  
S



*Southern California Edison Company*

P. O. BOX 800  
2244 WALNUT GROVE AVENUE  
ROSEMEAD, CALIFORNIA 91770

M. O. MEDFORD  
MANAGER OF NUCLEAR ENGINEERING  
AND LICENSING

May 5, 1988

TELEPHONE  
(818) 302-1749

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362  
San Onofre Nuclear Generating Station  
Units 2 and 3

Reference: Letter, Mr. M. O. Medford to NRC dated April 5, 1988;  
Subject: same as above

In our letter of April 5, 1988 the Southern California Edison Company (SCE) transmitted the Justification for Continued Operation (JCO) with Combustion Engineering (CE) steam generator tube plugs. During discussions of the issue with NRC, SCE was requested to address plans with respect to future activities at Unit 2 and steam generator tube inspections on Unit 3. Our April 5, 1988 letter indicated that the requested information would be provided within thirty days. The purpose of this letter is to provide the requested information.

Future activities at San Onofre Unit 2 regarding the rolled CE steam generator tube plugs will include inspection of each plug during the Cycle 5 refueling outage. That outage is currently scheduled for the third quarter of 1989. This inspection will ensure that every plug is in place and there are no apparent abnormalities. Further actions will depend on the results of both this inspection and the inspection planned for the Unit 3 Cycle 4 refueling outage in May 1988.

The current San Onofre Unit 3 Cycle 4 outage steam generator tube inspection plan is to conduct a Technical Specification inspection. This inspection will consist of eddy current testing the full length of more than 3% of the inservice tubes in each steam generator. In addition to these tube inspections, an inspection of all of the installed tube plugs will be done to ensure that they are in place and there are no apparent abnormalities.

A647  
1/0

8805090152 880505  
PDR ADOCK 05000361  
Q DCD

May 5, 1988

If you have any questions or would like additional information, please do not hesitate to contact me.

Very truly yours,



cc: D. Hickman, NRR Project Manager, San Onofre Units 2 and 3  
J. B. Martin, Regional Administrator, NRC Region V  
F. R. Huey, Senior Resident Inspector, San Onofre Units 1, 2 and 3