

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8902280505 DOC.DATE: 89/02/13 NOTARIZED: NO DOCKET #
 FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH.NAME AUTHOR AFFILIATION
 MORGAN,H.E. Southern California Edison Co.
 RECIP.NAME RECIPIENT AFFILIATION
 MARTIN,J.B. Region 5, Ofc of the Director

SUBJECT: Monthly followup rept re Tech Spec fire-rated fire doors
 found inoperable during Jan 1989 surveillances.

DISTRIBUTION CODE: IE22D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD5 LA	1 1	PD5 PD	1 1
HICKMAN,D	1 1		
INTERNAL: ACRS MICHELSON	1 1	ACRS MOELLER	2 2
ACRS WYLIE	1 1	AEOD/DOA	1 1
AEOD/DSP/TPAB	1 1	AEOD/ROAB/DSP	2 2
ARM/DCTS/DAB	1 1	DEDRO	1 1
NRR/DEST/ADE 8H	1 1	NRR/DEST/ADS 7E	1 0
NRR/DEST/CEB 8H	1 1	NRR/DEST/ESB 8D	1 1
NRR/DEST/ICSB 7	1 1	NRR/DEST/MEB 9H	1 1
NRR/DEST/MTB 9H	1 1	NRR/DEST/PSB 8D	1 1
NRR/DEST/RSB 8E	1 1	NRR/DEST/SGB 8D	1 1
NRR/DLPQ/HFB 10	1 1	NRR/DLPQ/QAB 10	1 1
NRR/DOEA/EAB 11	1 1	NRR/DREP/RAB 10	1 1
NRR/DREP/RPB 10	2 2	NRR/DRIS/SIB 9A	1 1
NUDOCS-ABSTRACT	1 1	<u>REG FILE</u> 02	1 1
RES/DSIR/EIB	1 1	RES/DSR/PRAB	1 1
RGN5 FILE 01	1 1		
EXTERNAL: EG&G WILLIAMS,S	4 4	FORD BLDG HOY,A	1 1
H ST LOBBY WARD	1 1	LPDR	1 1
NRC PDR	1 1	NSIC HARRIS,J	1 1
NSIC MAYS,G	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 45 ENCL 44

F
I
I
S
/
A
D
D
S
/
A
D
D
S

mla



Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN
STATION MANAGER

TELEPHONE
(714) 368-6241

February 13, 1989

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

89 FEB 21 AIO: 54

RECEIVED
FEB 21 1989
REGION V

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - January 1989
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),
dated January 18, 1989

In accordance with our referenced letter, this submittal provides the follow-up report of Technical Specification fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in January 1989.

Fire doors found inoperable during the January routine surveillances are identified in the Attachment and include: 12 latching mechanism failures and 14 closure mechanism failures. No doors were found blocked open in January. As each of these deficiencies was identified, compensatory fire watches pursuant to Technical Specification 3.7.9, Action Statement "a", were established and will remain in effect until the door is restored to operable status.

8902280505 890213
PDR ADOCK 05000361
S PNU

~~1101~~
DE22


Mr. J. B. Martin

-2-

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in February will be submitted during March 1989.

If you require any additional information, please so advise.

Sincerely,

A handwritten signature in black ink, appearing to read "H. E. May", followed by a horizontal line.

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)
U. S. Nuclear Regulatory Commission Document Control Desk
Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JANUARY 1989
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 12, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
S2-016	11/22/88	01/10/89
S2-001	12/01/88	01/13/89
AC-106	12/29/88	01/04/89
AC-223	01/01/89	01/07/89
DG3-201	01/10/89	01/11/89
AC-118	01/21/89	- - -
T3-104	01/27/89	01/28/89
T3-210	01/27/89	01/28/89
T2-104	01/27/89	01/28/89
T2-210	01/27/89	01/28/89
S2-018	01/27/89	- - -
FH3-404	01/30/89	- - -

II. Closure Mechanism Failures:

Number of doors inoperable - 14, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-401	10/05/88	- - -
AC-423	10/06/88	- - -
S2-016	11/22/88	01/10/89
S2-001	12/01/88	01/13/89
AC-236	12/08/88	01/07/89
AC-507	12/10/88	01/27/89
C3-406	12/18/88	01/01/89
AC-106	12/29/88	01/04/89
DG3-201	01/10/89	01/11/89
FH2-404	01/17/89	- - -
AC-218	01/18/89	01/24/89
AC-119	01/18/89	01/27/89
AC-105	01/25/89	- - -
FH3-404	01/30/89	- - -

III. Doors Blocked Open:

Number of doors blocked open - None

fdr/jan