

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ATA SXL

ACCESSION NBR: 8301100103 DOC. DATE: 83/01/06 NOTARIZED: NO DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern California 05000361
 AUTH. NAME AUTHOR AFFILIATION
 DIETCH, R. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards Amend Application 16 to License NPF-10, revising
 Tech Specs re DNBR, turbine overspeed protection, safety
 valves operating, fire hose stations, special test program &
 ESF response times.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 40 SIZE: 2+51
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: J. Hanchett 1cy PDR Documents. ELD Chandler 1cy. 05000361
 NRR Scaletti 1cy.

W/Check: \$200.00

RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
NRR/DL/ADL	1 0	NRR LB3 BC	1 0
NRR LB3 LA	1 0	ROOD, H.	01 1 1
INTERNAL: ELD/HDS2	1 0	IE FILE	1 1
IE/DEP EPDS 35	1 1	IE/DEP/EPLB 36	3 3
NRR/DE/AEAB	1 0	NRR/DE/CEB 11	1 1
NRR/DE/eqB 13	2 2	NRR/DE/GB 28	2 2
NRR/DE/HGEB 30	1 1	NRR/DE/MEB 18	1 1
NRR/DE/MTEB 17	1 1	NRR/DE/QAB 21	1 1
NRR/DE/SAB 24	1 1	NRR/DE/SEB 25	1 1
NRR/DHFS/HFEB40	1 1	NRR/DHFS/LQB 32	1 1
NRR/DHFS/OLB 34	1 1	NRR/DL/SSPB	1 0
NRR/DSI/AEB 26	1 1	NRR/DSI/CPB 10	1 1
NRR/DSI/CSB 09	1 1	NRR/DSI/ICSB 16	1 1
NRR/DSI/METB 12	1 1	NRR/DSI/PSB 19	1 1
NRR/DSI/RAB 22	1 1	NRR/DSI/RSB 23	1 1
REG FILE 04	1 1	RGN5	3 3
RM/DDAMI/MIB	1 0		

EXTERNAL:	ACRS 41	6 6	BNL (AMDTS ONLY)	1 1
DMB/DSS (AMDTS)	1 1	FEMA-REP DIV 39	1 1	
LPDR 03	1 1	NRC PDR 02	1 1	
NSIC 05	1 1	NTIS	1 1	

NOTES: 3 3

8

TOTAL NUMBER OF COPIES REQUIRED: LTR 55 ENCL 48

Southern California Edison Company



P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

ROBERT DIETCH

VICE PRESIDENT

January 6, 1983

TELEPHONE

213-572-4144

Mr. H. R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Gentlemen:

Subject: Docket No. 50-361
Amendment Application No. 16
San Onofre Nuclear Generating Station
Unit 2

Enclosed are three executed and forty conformed copies of Amendment Application No. 16 to Facility Operating License NPF-10 for the San Onofre Nuclear Generating Station. Amendment Application No. 16 consists of the following proposed changes to Appendix A, Technical Specifications:

<u>Proposed Change</u>	<u>Description</u>
NPF-10-33	Technical Specifications 2.2.1 (Table 2.2-1), 3.2.4, 4.2.4.4 and associated bases, DNBR Limits
NPF-10-55	Technical Specification 3.3.4, Turbine Overspeed Protection
NPF-10-56	Technical Specification 3.4.2, Safety Valves-Operating, and 3.7.8.3, Fire Hose Stations
NPF-10-59	Technical Specification 7.0, Special Test Program
NPF-10-60	Technical Specification 3.3.2, (Table 3.3-5), Engineered Safety Features Response Times

By letter dated December 3, 1982, SCE requested early approval of Proposed Change NPF-10-55 to allow uninterrupted continuation of the 50% power test program. Early NRC approval of Proposed Change NPF-10-55 was given on December 6, 1982. In accordance with SCE's letter of December 3, 1982, Proposed Change NPF-10-55 is hereby formally submitted.

Boo!
1/40

w/attach:

\$1200.00

8301100103 830106
PDR ADDCK 05000361
PDR

January 6, 1983



By letters dated December 20, 21 and 22, 1982, SCE requested early approval of Proposed Change NPF-10-60 to allow removal of Pressurizer Pressure - Low actuation from the component cooling water (CCW) non-critical loop containment isolation valves and CCW critical/non-critical loop isolation valves. Formal NRC approval of Proposed Change NPF 10-60 was given on December 23, 1982. In contrast with SCE's letter of December 20, 1982, Proposed Change NPF-10-60 is formally submitted now instead of the week of January 17, 1982.

It is respectfully requested that Amendment Application No. 16 be reviewed promptly and appropriate action taken. Direct distribution of Amendment Application No. 16 to Facility Operating License No. NPF-10 will be made in accordance with the service list provided by SCE's letter of August 2, 1982 to the Commission. An affidavit attesting to the fact that distribution has been completed will be submitted within ten days of amendment docketing.

The proposed changes contained in Amendment Application No. 16 are considered to constitute a Class II amendment based on the determination that these changes have no safety or environmental significance. Accordingly, enclosed is Southern California Edison Company's check in the amount of \$1,200.00 as required by 10 CFR 170.22.

Very truly yours,

A handwritten signature in cursive script, appearing to read "Robert Smith", is written below the typed name.

cc: Mr. H. Rood, Project Manager
Licensing Branch 3