

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8304190334 DOC. DATE: 83/04/15 NOTARIZED: NO DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 DIETCH, R. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards application for amend to License NPF-10 & NPF-15,
 revising Tech Specs re radioactive liquid effluent
 monitoring instrumentation, control room emergency air
 cleanup sys & fire detection instrumentation.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 40 SIZE: 13 + 71
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: J Hanchett 1cy PDR Documents, ELD Chandler 1cy. 05000361
 NRR Scaletti 1cy.
 J Hanchett 1cy PDR Documents, ELD Chandler 1cy. 05000362

w/ check 7600.00

RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
NRR/DL/ADL	1 0	NRR LB3 BC	1 0
NRR LB3 LA	1 0	ROOD, H. 01	1 1

INTERNAL: ELD/HDS2			IE FILE		
IE/DEPER/EPB 36	3	3	IE/DEPER/IRB 35	1	1
IE/DEQA/QAB 21	1	1	NRR/DE/AEAB	1	0
NRR/DE/CEB 11	1	1	NRR/DE/EHEB	1	1
NRR/DE/eqB 13	2	2	NRR/DE/GB 28	2	2
NRR/DE/HGEB 30	1	1	NRR/DE/MEB 18	1	1
NRR/DE/MTEB 17	1	1	NRR/DE/SAB 24	1	1
NRR/DE/SGEB 25	2	2	NRR/DHFS/HFEB40	1	1
NRR/DHFS/LQB 32	1	1	NRR/DL/SSPB	1	0
NRR/DSI/AEB 26	1	1	NRR/DSI/ASB	1	1
NRR/DSI/CPB 10	1	1	NRR/DSI/CSB 09	1	1
NRR/DSI/ICSB 16	1	1	NRR/DSI/METB 12	1	1
NRR/DSI/PSB 19	1	1	NRR/DSI/RAB 22	1	1
NRR/DSI/RSB 23	1	1	REG FILE 04	1	1
RGN5	3	3	RM/DDAMI/MIB	1	0

EXTERNAL: ACRS			BNL (AMDTs ONLY)		
DMB/DSS (AMDTs)	41	6	6	1	1
LPDR	03	1	1	1	1
NSIC	05	1	1	1	1
			NTIS	1	1

NOTES: 3 3

TOTAL NUMBER OF COPIES REQUIRED: LTR 57 ENCL 10

Southern California Edison Company



P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

ROBERT DIETCH

VICE PRESIDENT

TELEPHONE

213-572-4144

April 15, 1983

Mr. H. R. Denton
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 2 and 3

Enclosed are three executed and forty conformed copies of Amendment Application No. 20 to Operating License NPF-10 and Amendment Application No. 6 to Operating License NPF-15 for San Onofre Nuclear Generating Station Units 2 and 3. Amendment Applications Nos. 20 and 6 consist of the following proposed changes:

1. Proposed Changes NPF-10-54 and NPF-15-54 are requests to revise Technical Specification 3.0.4 to forestall the applicability of this specification until one month after first achieving 100% power.
2. Proposed Changes NPF-10-65 and NPF-15-65 are requests to revise Technical Specification Sections 3/4.3.3.8 RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION and 3/4.11.1 LIQUID EFFLUENTS. The proposed changes reflect the addition of a steam generator blowdown bypass line, identify this as an additional release path and provide operational and surveillance requirements for the associated effluent sampling and monitoring.
3. Proposed Changes NPF-10-68 and NPF-15-68 are requests to revise Technical Specification 3/4.7.5 CONTROL ROOM EMERGENCY AIR CLEANUP SYSTEM to allow increased air flow in order to demonstrate control room positive pressure requirements.
4. Proposed Changes NPF-10-72 and NPF-15-72 are requests to revise Technical Specifications 3/4.3.3.7 FIRE DETECTION INSTRUMENTATION and 3/4.7.8.2 SPRAY AND/OR SPRINKLER SYSTEMS to reflect the additional fire protection equipment.

Boo!
1/40

w/check:

\$ 7600.00

8304190334 830415
PDR ADOCK 05000361
PDR

April 15, 1983



5. Proposed Changes NPF-10-73 and NPF-15-73 are requested to revise Technical Specifications 3/4.3.3.1 RADIATION MONITORING ALARM INSTRUMENTATION to increase the alarm setpoints for containment high range monitors.

Southern California Edison Company's (SCE) letter of February 11, 1983 requested early approval for Proposed Changes NPF-10-68 and NPF-15-68. Early approval was granted on February 18, 1983 with the issuance of Amendments Nos. 14 and 3 to Operating Licenses NPF-10 and NPF-15 respectively. Amendment Applications Nos. 20 and 6 constitute the formal submittal of Proposed Changes NPF-10-68 and NPF-15-68 referred to in the February 11 letter.

License Condition 2.C(12)b of the Unit 3 Operating License NPF-15 required, in part, that prior to exceeding five (5) percent power SCE submit a license amendment request to reflect in the Technical Specifications the addition of the following fire protection equipment:

1. Fire detection in five zones 11, 28, 45, 62 and 72.
2. Additional sprinklers in the AFW pump room.
3. Fire detection and portable extinguishers in the technical support center (TSC).

Proposed Changes NPF-10-72 and NPF-15-72 request that these items be added to the Units 2 and 3 Technical Specifications with the exception of the TSC fire extinguishers. The addition of fire extinguishers to technical specifications is inconsistent with standard technical specifications and therefore not requested. SCE considers that Proposed Changes NPF-10-72 and NPF-15-72 fully satisfy the License Condition 2.C(12)b requirement to request a license amendment.

Direct distribution of Amendment Application No. 20 to Operating License NPF-10 and Amendment Application No. 6 to Operating License NPF-15 will be made in accordance with the service list provided in SCE's August 2, 1982 letter to the Commission. An affidavit attesting to the fact that distribution as been completed will be submitted within ten days of amendment docketing.

Pursuant to 10 CFR 170.22 the following determinations have been made regarding the class of license amendment constituted by each of the proposed changes:

Amendment Application No. 20 to NPF-10

<u>Proposed Change</u>	<u>Class</u>	<u>Fee</u>
NPF-10-54	II	\$1,200.00
NPF-10-65	III	\$4,000.00
NPF-10-68	III	\$4,000.00
NPF-10-72	II	\$1,200.00
NPF-10-73	II	\$1,200.00

April 15, 1983

The logo for the Southern California Edison (SCE) utility company, consisting of the letters "SCE" in a stylized, bold, sans-serif font.Amendment Application No. 6 to NPF-15

<u>Proposed Change</u>	<u>Class</u>	<u>Fee</u>
NPF-15-54	I	\$400.00
NPF-15-65	I	\$400.00
NPF-15-68	I	\$400.00
NPF-15-72	I	\$400.00
NPF-15-73	I	\$400.00

The fees for Proposed Changes NPF-10-68 and NPF-15-68 were remitted with SCE's February 11, 1983 submittal which requested early approval of these changes. Additionally, no fees are required to be remitted for Proposed Changes NPF-10-72 and NPF-15-72, because these changes result from an NRC request. Therefore, SCE's check in the amount of \$7,600.00 to cover the remaining fees is enclosed as required by 10 CFR 170.22.

Very truly yours,

A handwritten signature in cursive script, appearing to read "Robert Ditch".

Enclosures

cc: Harry Rood, NRC (To be opened by addressee only)