

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

Application of SOUTHERN CALIFORNIA EDISON)	
COMPANY, <u>ET AL.</u> for a Class 103 License to)	Docket No. 50-361
Acquire, Possess, and Use a Utilization)	
Facility as Part of Unit No. 2 of the San)	Amendment Application
Onofre Nuclear Generating Station)	No. 30

SOUTHERN CALIFORNIA EDISON COMPANY, ET AL. pursuant to 10 CFR 50.90,
hereby submit Amendment Application No. 30.

This amendment application consists of the following proposed
changes to Facility Operating License No. NPF-10:

1. Proposed Change NPF-10-96 is a request to revise Technical Specification (TS) Sections 3/4.3.2 "Engineered Safety Feature Actuation System Instrumentation" and 3/4.7.1.5 "Mainsteam Line Isolation Valves." The Proposed Change revises Table 3.3-5 of T.S. Section 3/4.3.2 to: a) provide increased response time testing requirements for the containment spray isolation valves, mainsteam line isolation valves and auxiliary feedwater isolation valves; b) include only those steam, blowdown, sample and drain isolation valves required to be response time tested on a mainsteam isolation signal; c) include response time testing requirements for the mainsteam isolation valves, main feedwater isolation valves and minipurge isolation valves on a containment isolation actuation signal; d) include the noncritical loop component cooling water valves not required to be response time tested on a safety injection actuation signal; and e) include the power-operated auxiliary

feedwater isolation valves HV 4762 and HV 4763 in the response time testing requirements on a mainsteam isolation signal, following implementation of DCP 195J. The Proposed Change also revises T.S. Section 3/4.7.1.5 to increase the mainsteam isolation valve closure time, consistent with the changes specified in a) above.

2. Proposed Change NPF-10-149 is a request to revise T.S. Section 3.2.6 "Reactor Coolant Cold Leg Temperature" to reduce the minimum required cold leg temperature between 30% and 70% of Rated Thermal Power. Southern California Edison Company previously submitted this proposed change to the NRC by letter dated October 11, 1984.

Pursuant to 10 CFR 170.12, an amendment application fee of \$150.00 is required for each license amendment request. A check for \$150 is enclosed corresponding to the request for Proposed Change 96 to Unit 2 Facility Operating License NPF-10. A request for Proposed Change NPF-10-149 was previously submitted by letter dated October 11, 1984. Accordingly, the required \$150.00 amendment application fee was remitted with that submittal.

Subscribed on this 30th day of November 1984.

Respectfully submitted,


SOUTHERN CALIFORNIA EDISON COMPANY

By Wmuth P. Bastin

Subscribed and sworn to before me this
30th day of November 1984.

Agnes Crabtree
Notary Public in and for the County of
Los Angeles, State of California

My Commission Expires: Aug 27, 1986



Charles R. Kocher
James A. Beoletto
Attorneys for Southern
California Edison Company

By Charles R. Kocher

SAN DIEGO GAS & ELECTRIC COMPANY

By

J. Adcom


David R. Pigott
Samuel B. Casey
Orrick, Herrington & Sutcliffe
Attorneys for San Diego
Gas & Electric Company

By

David R. Pigott

Subscribed and sworn to before me this

28th day of November 1984.



Loraine E. Gray
Notary Public in and for the County of
San Diego, State of California

THE CITY OF ANAHEIM


By Dale L Pohlman

Alan R. Watts
Rourke & Woodruff
Attorney for the City of Anaheim

By Alan R. Watts

Subscribed and sworn to before me
this 21st day of November, 1984

E. Lucille Moses
Notary Public in and for the County
of Orange, State of California



THE CITY OF RIVERSIDE

By Fred Kragg

Alan R. Watts
Rourke & Woodruff
Attorney for the City of Riverside

By Alan R. Watts

Subscribed and sworn to before me
this 19th day of November, 1984.

Margaret I. Allen
Notary Public in and for the County
of Riverside, State of California

