

REFUELING OPERATIONS

3/4.9.12 FUEL HANDLING BUILDING POST-ACCIDENT CLEANUP FILTER SYSTEM

LIMITING CONDITION FOR OPERATION

3.9.12 Two independent fuel handling building post-accident cleanup filter systems shall be OPERABLE.

APPLICABILITY: Whenever irradiated fuel is in the storage pool.

ACTION:

- a. With one fuel handling building post-accident cleanup filter system inoperable, fuel movement within the storage pool or operation of fuel handling machine over the storage pool may proceed provided the OPERABLE fuel handling building post-accident cleanup filter system is capable of being powered from an OPERABLE emergency power source. Demonstrate the operability of the OPERABLE fuel handling building post-accident cleanup filter system within 12 hours and at least once per 7 days thereafter by initiating, from the control room, flow through the HEPA filters and charcoal adsorbers and verifying that the system operates for at least 15 minutes.
- b. With no fuel handling building post-accident cleanup filter system OPERABLE, suspend all operations involving movement of fuel within the storage pool or operation of fuel handling machine over the storage pool until at least one fuel handling building post-accident cleanup filter system is restored to OPERABLE status.
- c. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.12 The above required fuel handling building post-accident cleanup filter system shall be demonstrated OPERABLE:

- a. At least once per 31 days on a STAGGERED TEST BASIS by initiating, from the control room, flow through the HEPA filters and charcoal adsorbers and verifying that the system operates for at least 10 hours with the heaters on.
- b. At least once per 18 months or (1) after any structural maintenance on the HEPA filters or charcoal adsorber housings, or (2) following painting, fire or chemical release in any ventilation zone communicating with the system by:

ATTACHMENT D

PROPOSED SPECIFICATION - UNIT 3

REFUELING OPERATIONS

3/4.9.12 FUEL HANDLING BUILDING POST-ACCIDENT CLEANUP FILTER SYSTEM

LIMITING CONDITION FOR OPERATION

3.9.12 Two independent fuel handling building post-accident cleanup filter systems shall be OPERABLE.

APPLICABILITY: Whenever irradiated fuel is in the storage pool.

ACTION:

- a. With one fuel handling building post-accident cleanup filter system inoperable, fuel movement within the storage pool or operation of fuel handling machine over the storage pool may proceed provided the OPERABLE fuel handling building post-accident cleanup filter system is capable of being powered from an OPERABLE emergency power source.
✓ Demonstrate the operability of the OPERABLE fuel handling building post-accident cleanup filter system within 12 hours and at least once per 7 days thereafter by initiating, from the control room, flow through the HEPA filters and charcoal adsorbers and verifying that the system operates for at least 15 minutes.
- b. With no fuel handling building post-accident cleanup filter system OPERABLE, suspend all operations involving movement of fuel within the storage pool or operation of fuel handling machine over the storage pool until at least one fuel handling building post-accident cleanup filter system is restored to OPERABLE status.
- c. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.12 The above required fuel handling building post-accident cleanup filter system shall be demonstrated OPERABLE:

- a. At least once per 31 days on a STAGGERED TEST BASIS by initiating, from the control room, flow through the HEPA filters and charcoal adsorbers and verifying that the system operates for at least 10 hours with the heaters on.
- b. At least once per 18 months or (1) after any structural maintenance on the HEPA filters or charcoal adsorber housings, or (2) following painting, fire or chemical release in any ventilation zone communicating with the system by: