

ENCLOSURE "A"

REVISED PAGES FOR NPF-10/15-91 AND NPF-10/15-137

8508220079	850820
PDR	ADOCK 05000361
P	PDR

ELECTRICAL POWER SYSTEMSSURVEILLANCE REQUIREMENTS (Continued)

3. Verifying the generator capability to reject a load of 4700 kW without tripping. The generator voltage shall not exceed 5450 volts during and following the load rejection.
4. Simulating a loss of offsite power by itself, and:
 - a) Verifying de-energization of the emergency busses and load shedding from the emergency busses.
 - b) Verifying the diesel starts on the auto-start signal, energizes the emergency busses with permanently connected loads within 10 seconds and operates for greater than or equal to 5 minutes while its generator is loaded with the permanently connected loads. After energization, the steady state voltage and frequency of the emergency busses shall be maintained at 4360 ± 436 volts and 60 ± 1.2 Hz during this test.
5. Verifying that on an ESF test signal (without loss of offsite power) the diesel generator starts on the auto-start signal and operates on standby for greater than or equal to 5 minutes. The steady state generator voltage and frequency shall be 4360 ± 436 volts and 60 ± 1.2 Hz within 10 seconds after the auto-start signal; the generator voltage and frequency shall be maintained within these limits during this test.
6. Deleted.
7. Simulating a loss of offsite power in conjunction with an ESF test signal, and
 - a) Verifying de-energization of the emergency busses and load shedding from the emergency busses.
 - b) Verifying the diesel starts on the auto-start signal, energizes the emergency busses with permanently connected loads within 10 seconds, energizes the auto connected emergency (accident) loads through the load sequence and operates for greater than or equal to 5 minutes while its generator is loaded with the emergency loads. After loading, the steady state voltage and frequency of the emergency busses shall be maintained at 4360 ± 436 volts and $60 + 1.2/-0.3$ Hz during this test.

ELECTRICAL POWER SYSTEMSSURVEILLANCE REQUIREMENTS (Continued)

3. Verifying the generator capability to reject a load of 4700 kW without tripping. The generator voltage shall not exceed 5450 volts during and following the load rejection.
4. Simulating a loss of offsite power by itself, and:
 - a) Verifying de-energization of the emergency busses and load shedding from the emergency busses.
 - b) Verifying the diesel starts on the auto-start signal, energizes the emergency busses with permanently connected loads within 10 seconds and operates for greater than or equal to 5 minutes while its generator is loaded with the permanently connected loads. After energization, the steady-state voltage and frequency of the emergency busses shall be maintained at 4360 ± 436 volts and 60 ± 1.2 Hz during this test.
5. Verifying that on an ESF test signal (without loss of offsite power) the diesel generator starts on the auto-start signal and operates on standby for greater than or equal to 5 minutes. The steady-state generator voltage and frequency shall be 4360 ± 436 volts and 60 ± 1.2 Hz within 10 seconds after the auto-start signal; the generator voltage and frequency shall be maintained within these limits during this test.
6. Deleted.
7. Simulating a loss of offsite power in conjunction with an ESF test signal, and
 - a) Verifying de-energization of the emergency busses and load shedding from the emergency busses.
 - b) Verifying the diesel starts on the auto-start signal, energizes the emergency busses with permanently connected loads within 10 seconds, energizes the auto connected emergency (accident) loads through the load sequence and operates for greater than or equal to 5 minutes while its generator is loaded with the emergency loads. After loading, the steady state voltage and frequency of the emergency busses shall be maintained at 4360 ± 436 volts and $60 + 1.2/-0.3$ Hz during this test.

NOV 15 1982

ELECTRICAL POWER SYSTEMSAC SOURCESSHUTDOWNLIMITING CONDITION FOR OPERATION

3.8.1.2 As a minimum, the following AC electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the onsite Class 1E distribution system, and
- b. One diesel generator with:
 1. Day fuel tanks containing a minimum volume of 325 gallons of fuel,
 2. A fuel storage system containing a minimum volume of 37,600 gallons of fuel, and
 3. A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above minimum AC electrical power sources OPERABLE, immediately suspend all operations involving CORE ALTERATIONS or positive reactivity changes and movement of irradiated fuel, or operation of the fuel handling machine with loads over the fuel storage pool. In addition, when in MODE 5 with the Reactor Coolant loops not filled, or in MODE 6 with the water level less than 23 feet above the reactor vessel flange, immediately initiate corrective action to restore the required sources to OPERABLE status as soon as possible.

SURVEILLANCE REQUIREMENTS

4.8.1.2.1 The above required circuit between the offsite transmission network and the onsite Class 1E distribution system shall be determined OPERABLE at

ELECTRICAL POWER SYSTEMSAC SOURCESSHUTDOWNSURVEILLANCE REQUIREMENTS (continued)

least once per 7 days by verifying correct breaker alignment and indicated power availability.

- a. If the above required offsite source is supplied through the Unit 3 4160 volt Emergency Bus #3A04, the following buses are required:

480 volt Emergency Bus #3B04
125 volt Emergency Bus #3D1

- b. If the above required offsite source is supplied through the Unit 3 4160 volt Emergency Bus #3A06, the following buses are required:

480 volt Emergency Bus #3B06
125 volt Emergency Bus #3D2

4.8.1.2.2 The above required diesel generator shall be demonstrated OPERABLE by performing the Surveillance Requirements of 4.8.1.1.2 (except 4.8.1.1.2 a.5, d.5, d.7, d.9, d.10, d.11 and d.13) and 4.8.1.1.3.

ELECTRIC POWER SYSTEMSBASESAC SOURCES, DC SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS (continued)

as well as operation of loss of voltage logic, is the same as for the primary connection using the reserve auxiliary transformer, with the exception of no transfer to the companion unit.

The Surveillance Requirements for demonstrating the OPERABILITY of the diesel generators are in accordance with the recommendations of Regulatory Guides 1.9 "Selection of Diesel Generator Set Capacity for Standby Power Supplies," March 10, 1971, and 1.108 "Periodic Testing of Diesel Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants," Revision 1, August 1977, and 1.137, "Fuel Oil Systems for Standby Diesel Generators," Revision 1, October 1979. Reg. Guide 1.137 recommends testing of fuel oil samples in accordance with ASTM-D270-1975. However, ASTM-D270-1965 was reverified in 1975 rather than re-issued. The reverified 1965 standard is therefore the appropriate standard to be used.

Additionally, Regulatory Guide 1.9 allows loading of the diesel generator to its 2000 hour rating in an accident situation. The full load, continuous operation rating for each diesel generator is 4700 kW, while the calculated accident loading in Modes 1 through 4 is 4000 kW. The largest anticipated load (including loads which are required to mitigate the consequences of a design basis accident or facilitate plant operation and maintenance) in Modes 5 and 6 is calculated to be less than 80% of the full rated capacity. No 2000 hour loading has been specified by the diesel generator manufacturer and, as a result the full loading rating of 4700 kW is conservatively established as the 2000 hour rating. Diesel frequency droop restrictions are established due to HPSI flow rate considerations.

The Surveillance Requirement for demonstrating the OPERABILITY of the Station batteries are based on the recommendations of Regulatory Guide 1.129, "Maintenance Testing and Replacement of Large Lead Storage Batteries for Nuclear Power Plants," February 1978, and IEEE Std. 450-1980, "IEEE Recommended Practice for Maintenance, Testing, and Replacement of Large Lead Storage Batteries for Generating Stations and Substations."

Verifying average electrolyte temperature above the minimum for which the battery was sized, total battery thermal voltage onfloat charge, connection resistance values and the performance of battery service and discharge tests ensures the effectiveness of the charging system, the ability to handle high discharge rates and compares the battery capacity at that time with the rated capacity.

ELECTRIC POWER SYSTEMSBASES

AC SOURCES, DC SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS (continued)

Table 4.8-2 specifies the normal limits for each designated pilot cell and each connected cell for electrolyte level, float voltage and specific gravity. The limits for the designated pilot cells float voltage and specific gravity, greater than 2.13 volts and 0.15 below the manufacturer's full charge specific gravity or a battery charger current that had stabilized at a low value, is characteristic of a charged cell with adequate capacity. The normal limits for each connected cell for float voltage and specific gravity, greater than 2.13 volts and not more than .020 below the manufacturer's full charge specific gravity with an average specific gravity of all the connected cells not more than .010 below the manufacturer's full charge specific gravity, ensures the OPERABILITY and capability of the battery.

ELECTRICAL POWER SYSTEMSAC SOURCESSHUTDOWNLIMITING CONDITION FOR OPERATION

3.8.1.2 As a minimum, the following AC electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the onsite Class 1E distribution system, and
- b. One diesel generator with:
 1. Day fuel tanks containing a minimum volume of 325 gallons of fuel,
 2. A fuel storage system containing a minimum volume of 37,600 gallons of fuel, and
 3. A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above minimum AC electrical power sources OPERABLE, immediately suspend all operations involving CORE ALTERATIONS or positive reactivity changes and movement of irradiated fuel, or operation of the fuel handling machine with loads over the fuel storage pool. In addition, when in MODE 5 with the Reactor Coolant loops not filled, or in MODE 6 with the water level less than 23 feet above the reactor vessel flange, immediately initiate corrective action to restore the required sources to OPERABLE status as soon as possible.

SURVEILLANCE REQUIREMENTS

4.8.1.2.1 The above required circuit between the offsite transmission network and the onsite Class 1E distribution system shall be determined OPERABLE at

ELECTRICAL POWER SYSTEMSAC SOURCESSHUTDOWNSURVEILLANCE REQUIREMENTS (continued)

least once per 7 days by verifying correct breaker alignment and indicated power availability.

- a. If the above required offsite source is supplied through the Unit 2 4160 volt Emergency Bus #2A04, the following buses are required:

480 volt Emergency Bus #2B04
125 volt Emergency Bus #2D1

- b. If the above required offsite source is supplied through the Unit 2 4160 volt Emergency Bus #2A06, the following buses are required:

480 volt Emergency Bus #2B06
125 volt Emergency Bus #2D2

4.8.1.2.2 The above required diesel generator shall be demonstrated OPERABLE by performing the Surveillance Requirements of 4.8.1.1.2 (except 4.8.1.1.2 a.5, d.5, d.7, d.9, d.10, d.11 and d.13) and 4.8.1.1.3.

ELECTRIC POWER SYSTEMSBASESAC SOURCES, DC SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS (continued)

as well as operation of loss of voltage logic, is the same as for the primary connection using the reserve auxiliary transformer, with the exception of no transfer to the companion unit.

The Surveillance Requirements for demonstrating the OPERABILITY of the diesel generators are in accordance with the recommendations of Regulatory Guides 1.9 "Selection of Diesel Generator Set Capacity for Standby Power Supplies," March 10, 1971, and 1.108 "Periodic Testing of Diesel Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants," Revision 1, August 1977, and 1.137, "Fuel Oil Systems for Standby Diesel Generators," Revision 1, October 1979. Reg. Guide 1.137 recommends testing of fuel oil samples in accordance with ASTM-D270-1975. However, ASTM-D270-1965 was reverified in 1975 rather than re-issued. The reverified 1965 standard is therefore the appropriate standard to be used.

Additionally, Regulatory Guide 1.9 allows loading of the diesel generator to its 2000 hour rating in an accident situation. The full load, continuous operation rating for each diesel generator is 4700 kW, while the calculated accident loading in Modes 1 through 4 is 4000 kW. The largest anticipated load (including loads which are required to mitigate the consequences of a design basis accident or facilitate plant operation and maintenance) in Modes 5 and 6 is calculated to be less than 80% of the full rated capacity. No 2000 hour loading has been specified by the diesel generator manufacturer and, as a result the full loading rating of 4700 kW is conservatively established as the 2000 hour rating. Diesel frequency droop restrictions are established due to HPSI flow rate considerations.

The Surveillance Requirement for demonstrating the OPERABILITY of the Station batteries are based on the recommendations of Regulatory Guide 1.129, "Maintenance Testing and Replacement of Large Lead Storage Batteries for Nuclear Power Plants," February 1978, and IEEE Std. 450-1980, "IEEE Recommended Practice for Maintenance, Testing, and Replacement of Large Lead Storage Batteries for Generating Stations and Substations."

Verifying average electrolyte temperature above the minimum for which the battery was sized, total battery thermal voltage onfloat charge, connection resistance values and the performance of battery service and discharge tests ensures the effectiveness of the charging system, the ability to handle high discharge rates and compares the battery capacity at that time with the rated capacity.

ELECTRIC POWER SYSTEMSBASES

AC SOURCES, DC SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS (continued)

Table 4.8-2 specifies the normal limits for each designated pilot cell and each connected cell for electrolyte level, float voltage and specific gravity. The limits for the designated pilot cells float voltage and specific gravity, greater than 2.13 volts and 0.15 below the manufacturer's full charge specific gravity or a battery charger current that had stabilized at a low value, is characteristic of a charged cell with adequate capacity. The normal limits for each connected cell for float voltage and specific gravity, greater than 2.13 volts and not more than .020 below the manufacturer's full charge specific gravity with an average specific gravity of all the connected cells not more than .010 below the manufacturer's full charge specific gravity, ensures the OPERABILITY and capability of the battery.