

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8706010099 DOC. DATE: 87/05/13 NOTARIZED: NO DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 MORGAN, H. E. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 MARTIN, J. B. Region 5, Office of Director

SUBJECT: Forwards followup rept of Tech Spec fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in Apr 1987. Rept updates ongoing condition initially reported in 1983. Next rept anticipated by 870615.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES: ELD Chandler lcy. 05000361
 ELD Chandler lcy. 05000362

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD5 LA	1 1	PD5 PD	1 1
ROOD, H	1 1		

INTERNAL: ACRS MICHELSON	1 1	ACRS MOELLER	2 2
AEOD/DOA	1 1	AEOD/DSP/ROAB	2 2
AEOD/DSP/TPAB	1 1	DEDRO	1 1
NRR/DEST/ADE	1 0	NRR/DEST/ADS	1 0
NRR/DEST/CEB	1 1	NRR/DEST/ELB	1 1
NRR/DEST/ICSB	1 1	NRR/DEST/MEB	1 1
NRR/DEST/MTB	1 1	NRR/DEST/PSB	1 1
NRR/DEST/RSB	1 1	NRR/DEST/SGB	1 1
NRR/DLPQ/HFB	1 1	NRR/DLPQ/QAB	1 1
NRR/DOEA/EAB	1 1	NRR/DREP/RAB	1 1
NRR/DREP/RPB	2 2	NRR/PMAS/ILRB	1 1
NRR/PMAS/PTSB	1 1	REG FILE 02	1 1
RES DEPY GI	1 1	RGN5 FILE 01	1 1
EXTERNAL: EG&G GROH, M	5 5	H ST LOBBY WARD	1 1
LPDR	1 1	NRC PDR	1 1
NSIC HARRIS, J	1 1	NSIC MAYS, G	1 1

NOTES: 1 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 43 ENCL 41

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

May 13, 1987

H. E. MORGAN
STATION MANAGER

TELEPHONE
(714) 368-6241

RECEIVED
129

MAY 30 A 10:10

REGION V

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - April 1987
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),
dated April 14, 1987

In accordance with our referenced letter, this submittal provides the follow-up report of Technical Specification fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in April 1987.

Fire doors found inoperable during the April routine surveillances are identified in the Attachment and include: 8 latching mechanism failures, and 3 closure mechanism failures. No doors were found blocked open in April. As each of these deficiencies was identified, compensatory fire watches, pursuant to Technical Specification 3.7.9, Action Statement 'a', were established.

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in May 1987 will be submitted by June 15, 1987.

8706010099 870513
PDR ADDCK 05000361
S PDR

11 IF-22

Mr. J. B. Martin

-2-

If you require any additional information, please so advise.

Sincerely,

H. E. Morgan

Enclosure:

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)

U. S. Nuclear Regulatory Commission
Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF APRIL 1987
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 8, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AR-502	11/16/86	- - -
C2-406	01/01/87	- - -
AR-301	03/21/87	- - -
C3-406	04/01/87	- - -
AC-415	04/02/87	- - -
AC-213	04/09/87	04/11/87
FH3-103	04/23/87	04/26/87
AC-417	04/28/87	- - -

II. Closure Mechanism Failures:

Number of doors inoperable - 3, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
C2-406	01/01/87	- - -
C3-406	01/03/87	- - -
AC-223	04/16/87	- - -

III. Doors Blocked Open:

Number of doors blocked open - None