

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:7908130467 DOC.DATE: 79/08/06 NOTARIZED: NO DOCKET #
 FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH.NAME AUTHOR AFFILIATION
 MOORE,J.B. Southern California Edison Co.
 RECIP.NAME RECIPIENT AFFILIATION
 ENGELKEN,R.H. Region 5, San Francisco, Office of the Director

SUBJECT: Amends 790409 final deficiency rept re staking of Limitorque valve operators as 248 valves, not 96 as initially reported, required insp on proper staking of lock nuts.

DISTRIBUTION CODE: B0193 COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: CONSTRUCTION DEFICIENCY REPORT (10CFR50.55E).

NOTES: SEND ALL FSAR & ER AMENDS TO L. CHANDLER.

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	
ACTION:	14 PM R00D	1 1	15 BC LWR #2	1 1	
	20 LA LWR #2	1 1	21 AD LWR	1 1	
INTERNAL:	01 REG FILE	1 1	02 NRC PDR	1 1	
	05 I&E	2 2	07 EDO & STAFF	1 1	
	08 MPA	1 1	09 DEPY DIR DPM	1 1	
	10 QAB	1 1	11 STANDRDS DEV	1 1	
	12 JORDAN,E/IE	1 1	13 FIELD COOR/IE	1 1	
	16 AD FOR ENGR	1 1	17 AD PLANT SYS	1 1	
	17 AD REAC SFTY	1 1	19 AD SYS/PROJ	1 1	
	22 DIR DPM	1 1	23 OELD	1 1	
	AD/SITE TECH	1 1	DIRECTOR DSE	1 1	
	GEOSCIENCES BR	1 1	MATL ENG BR	1 1	
	MECH ENG BR	1 1	S HANAUER	1 1	
	STRUCT ENG BR	1 1			
	EXTERNAL:	03 LPDR	1 1	04 NSIC	1 1
		24 ACRS	16 16		

Aug 15 1979

MAI

60

TOTAL NUMBER OF COPIES REQUIRED: LTR 46 ENCL 0

Southern California Edison Company



P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

JACK B. MOORE
VICE PRESIDENT

TELEPHONE
213-572-2292

August 6, 1979

Mr. R. H. Engelken, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Region V
Suite 202, Walnut Creek Plaza
1990 North California Boulevard
Walnut Creek, California 94596

Dear Mr. Engelken:

Subject: Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station, Units 2 and 3

In a letter to your office dated April 9, 1979, we submitted a final report dealing with staking of Limitorque valve operators. The conditions described in the report were considered reportable in accordance with 10CFR50.55(e).

We would like to clarify one area of our initial report. In that report, we indicated that ninety-six (96) valves procured for use at San Onofre Units 2 and 3 with Limitorque operators were being inspected for proper staking of lock nuts. This quantity of valves included only valves which had been delivered at the time the report was submitted. A further review of valves in manufacturing or in transit indicated that an additional quantity of valves was involved in the investigation. Accordingly, we hereby amend our previous report to indicate that two hundred and forty-eight (248) valves will require inspection for proper staking of lock nuts. Inspection is being performed as valves become available for inspection at the jobsite. All valves which have been identified as requiring inspection will be inspected and reworked, if necessary, before turnover from Construction to Startup.

7908130 467

3019
S 1/0

SE


Mr. R. H. Engelken

-2-

August 6, 1979

If you have any questions regarding our initial report or the supplemental information provided above, we would be pleased to discuss this matter with you at your convenience.

Very truly yours,

A handwritten signature in dark ink, appearing to read "J. J. Moore". The signature is fluid and cursive, with a long horizontal stroke extending to the right.

cc: Victor Stello (NRC, Director I&E) ✓
R. J. Pate (NRC, San Onofre)