

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8006240440 DOC. DATE: 80/06/24 NOTARIZED: NO DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern California 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern California 05000362
 AUTH. NAME AUTHOR AFFILIATION
 BASKIN, K. P. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 3

SUBJECT: Responds to NRC 800421 request for info re use of concrete masonry walls in any seismic Category 1 plant structures. No concrete masonry walls exist in any facility seismic Category 1 plant structures.

DISTRIBUTION CODE: 8001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: _____

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTR	ENCL		ID	CODE/NAME	LTR	ENCL
ACTION:	AD	LICENSING	1	0		BC	SCHWENCER	1	0
	LA	LEE, J.	1	0		PM	ROOD, H. 05	1	1
INTERNAL:	A/D	CORE & CS13	1	0		ACCID	EVAL BR	1	1
	AUX	SYS BR 18	1	1		CHEM	ENG BR	1	1
	CONT	SYS BR	1	1		CORE	PERF BR 17	1	1
	DIRECTOR	NRR	1	0		EFF	TR SYS BR	1	1
	EMERG	PREP 22	1	0		ENV	ENG BR	1	1
	GEOSCIEN	BR 09	4	4		HANAUER, S.		1	1
	HYD/GEO	BR 11	1	1		I&C	SYS BR 20	1	1
	I&E	06	3	3		KIRKWOOD, R.	29	1	1
	MATL	ENG BR	1	1		MECH	ENG BR	1	1
	MPA		1	0		NRC	PDR 02	1	1
	OELD		1	0		POWER	SYS BR	1	1
	PROC/TST	REV BR	1	1		QA	BR 10	1	1
	RAD	ASSESS BR12	1	1		REAC	SYS BR	1	1
	REG	FILE 01	1	1		SIT	ANAL BR 27	1	1
	STRUCT	ENG BR	1	1					
EXTERNAL:	ACRS	30	10	10		LPDR	03	1	1
	NSIC	04	1	1					

JUN 25 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 50 ENCL 42

MA
4

60

Southern California Edison Company



P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

K. P. BASKIN
MANAGER, NUCLEAR ENGINEERING
AND LICENSING

TELEPHONE
(213) 572-1401

Director of Nuclear Reactor Regulation
Attention: Mr. Albert Schwencer, Acting Branch Chief
Licensing Projects Branch 3, DPM
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 2 and 3

In the April 21, 1980 NRC letter to all Construction Permit and Operating License Applicants information was requested concerning the use of concrete masonry walls in any of the Seismic Category I plant structures. As there are no concrete masonry walls in any of the San Onofre Units 2 and 3 Seismic Category I plant structures the questions are not relevant to San Onofre Units 2 and 3, and, as directed in the April 21, 1980 NRC letter, no response to the questions concerning the design of such walls will be provided.

If you have any questions, please let me know.

Very truly yours,

K. P. Baskin

3001
S
1/0

A 8006240 440