

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

Application of SOUTHERN CALIFORNIA)	
EDISON COMPANY, <u>ET AL.</u> for a Class 103)	Docket No. 50-361
License to Acquire, Possess, and Use)	
a Utilization Facility as Part of)	Amendment Application
Unit No. 2 of the San Onofre Nuclear)	No. 121
Generating Station)	

SOUTHERN CALIFORNIA EDISON COMPANY, ET AL. pursuant to 10 CFR 50.90, hereby submit Amendment Application No. 121.

This Amendment Application consists of Proposed Change Number (PCN) NPF-10-410 to Facility Operating License No. NPF-10. PCN NPF-10-410 is a request to revise Technical Specification 3/4.4.5 "Reactor Coolant System Leakage." PCN 410 proposes to change Surveillance Requirement 4.4.5.2.1.c to allow a transient evolution to continue and the required water inventory balance be performed within 120 hours of the last water inventory balance in lieu of performing the water inventory balance every 72 hours.

9211250124 921120
PDR ADOCK 05000361
P PDR

Subscribed on this 20th day of November, 1992.

Respectfully submitted,

SOUTHERN CALIFORNIA EDISON COMPANY

By: Harold B. Ray
Harold B. Ray
Senior Vice President

State of California
County of Orange

On 11/20/92 before me, Mariane Sanchez, Notary Public
personally appeared Harold B. Ray, personally known
to me to be the person whose name is subscribed to the within instrument
and acknowledged to me that he executed the same in his authorized capacity,
and that by his signature on the instrument the person, or the entity upon
behalf of which the person acted, executed the instrument.

WITNESS my hand and official seal.

Signature Mariane Sanchez



James A. Beoletto
Attorney for Southern
California Edison Company

By: James A. Beoletto
James A. Beoletto

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

Application of SOUTHERN CALIFORNIA)	
EDISON COMPANY, <u>ET AL.</u> for a Class 103)	Docket No. 50-362
License to Acquire, Possess, and Use)	
a Utilization Facility as Part of)	Amendment Application
Unit No. 3 of the San Onofre Nuclear)	No. 105
Generating Station)	

SOUTHERN CALIFORNIA EDISON COMPANY, ET AL. pursuant to 10 CFR 50.90, hereby submit Amendment Application No. 105.

This Amendment Application consists of Proposed Change Number (PCN) NPF-15-410 to Facility Operating License No. NPF-15. PCN NPF-15-410 is a request to revise Technical Specification 3/4.4.5 "Reactor Coolant System Leakage." PCN 410 proposes to change Surveillance Requirement 4.4.5.2.1.c to allow a transient evolution to continue and the required water inventory balance be performed within 120 hours of the last water inventory balance in lieu of performing the water inventory balance every 72 hours.

Subscribed on this 20th day of November, 1992.

Respectfully submitted,

SOUTHERN CALIFORNIA EDISON COMPANY

By: Harold B. Ray
Harold B. Ray
Senior Vice President

State of California
County of Orange

On 11/20/92 before me, Mariane Sanchez, Notary Public,
personally appeared Harold B. Ray, personally known
to me to be the person whose name is subscribed to the within instrument
and acknowledged to me that he executed the same in his authorized capacity,
and that by his signature on the instrument the person, or the entity upon
behalf of which the person acted, executed the instrument.

WITNESS my hand and official seal.

Signature

Mariane Sanchez



James A. Beoletto
Attorney for Southern
California Edison Company

By: James A. Beoletto
James A. Beoletto