

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8305170278 DOC. DATE: 83/05/13 NOTARIZED: NO JACKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern California 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern California 05000362
 AUTH. NAME: AUTHOR AFFILIATION
 BASKIN, K.P. Southern California Edison Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 KNIGHTON, G.W. Licensing Branch 3

SUBJECT: Confirms no safety-related applications of integral
 undervoltage trip devices other than in reactor trip
 switchgear, in response to NRC request for info re 830415
 reactor trip break rect.

DISTRIBUTION CODE: 30015 COPIES RECEIVED: LTR 1 ENCL 2 SIZE: 1
 TITLE: Licensing Submittals: PSAR/FSAR Amts & Related Correspondence

NOTES: J. Hanchett 1cc. PDR Documents. ELD Chandler 1cc. 05000361
 NRR Scaletti 1cc.
 J. Hanchett 1cc. PDR Documents. ELD Chandler 1cc. 05000362

RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
NRR/DL/ADLI	1 0	NRR LB3 BC	1 0
NRR LB3 LA	1 0	RODD, H. 01	1 1
INTERNAL: ELD/H032	1 0	IE FILE	1 1
IE/DEPER/EPB 36	3 3	IE/DEPER/IRB 35	1 1
IE/DEBAV/QAB 21	1 1	NRR/DE/AEAB	1 0
NRR/DEVCEB 11	1 1	NRR/DE/EHEB	1 1
NRR/DEVEBB 13	2 2	NRR/DEVGB 23	2 2
NRR/DEVHGB 30	1 1	NRR/DE/MEB 18	1 1
NRR/DEVMTEB 17	1 1	NRR/DE/SAB 24	1 1
NRR/DEVSGEB 25	2 2	NRR/DHFS/HFEB40	1 1
NRR/DHFS/LNB 32	1 1	NRR/DL/SSPB	1 0
NRR/DSI/AEB 25	1 1	NRR/DSI/ASB	1 1
NRR/DSI/CPB 10	1 1	NRR/DSI/CSB 09	1 1
NRR/DSI/ICB 16	1 1	NRR/DSI/MEB 12	1 1
NRR/DSI/PSB 19	1 1	NRR/DSI/RAB 22	1 1
NRR/DSI/RB 23	1 1	REG. FILE 04	1 1
RGN5	3 3	RM/DDAMI/MIB	1 0
EXTERNAL: ACRS 41	6 6	BNLICAMOTS ONLY	1 1
DMB/DSS (AMOTS)	1 1	FEMA-REP DIV 39	1 1
LPDR 03	1 1	NRC PDR 02	1 1
NSIC 05	1 1	NTIS	1 1
NOTES:	3 3		

TOTAL NUMBER OF COPIES REQUIRED: LTR 57 ENCL 50

Southern California Edison Company



P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

BASKIN
NUCLEAR ENGINEERING,
AND LICENSING

TELEPHONE
(213) 572-1401

May 13, 1983

Director, Office of Nuclear Reactor Regulation
Attention: Mr. George W. Knighton, Branch Chief
Licensing Branch No. 3
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 2 and 3

In response to the NRC's request for additional clarification relative to SCE's April 15, 1983 reactor trip breaker (RTB) report, SCE's letter dated April 20, 1983, informed the NRC that SCE has a high degree of confidence that there are no safety related applications of integral undervoltage trip devices other than in the reactor trip switchgear at San Onofre Units 2 and 3. The April 20, 1983 letter also indicated that SCE was performing a detailed review for verification and that confirmation would be provided.

Consistent with SCE's commitment, the purpose of this letter is to inform you that we have completed our review and have confirmed that there are no safety related applications of integral undervoltage trip devices other than in the reactor trip switchgear at San Onofre Units 2 and 3.

If you have any questions or comments, please let me know.

Very truly yours,

VP Baskin

Boo!

cc: Mr. J. B. Martin, Regional Administrator
U.S. Nuclear Regulatory Commission, Region V
Mr. H. Rood, Project Manager (Open by addressee only)

8305170278 830513
PDR ADDCK 05000361
S PDR

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8305170278 DOC DATE: 93/05/13 NOTARIZED: NO DOCKET #: 05000361
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern California 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern California 05000362
 AUTH. NAME: AUTHOR AFFILIATION:
 BASKIN, K.P. Southern California Edison Co.
 RECIP. NAME: RECIPIENT AFFILIATION:
 KNIGHTON, G.W. Licensing Branch 3

SUBJECT: Confirms no safety-related applications of integral
 under-voltage trip devices other than in reactor trip
 switchgear, in response to NRC request for info re 830415
 reactor trip break reset.

DISTRIBUTION CODE: 80018 COPIES RECEIVED: LITR 1 ENCL 2 SIZE: 1
 TITLE: Licensing Submittals: PSAR/FSAR Amdts & Related Correspondence

NOTES: J. Hanchett 1cy POR Documents. ELDI Chandler 1cy. 05000361
 NRR-Scaletti 1cy.
 J. Hanchett 1cy POR Documents. ELDI Chandler 1cy. 05000362

RECIPIENT ID CODE/NAME	COPIES LITR ENCL	RECIPIENT ID CODE/NAME	COPIES LITR ENCL
NRR/DL/ADLI	1 0	NRR/LB3/BCI	1 0
NRR/LB3/LAI	1 0	RODD/H.	1 1
INTERNAL: ELD/HDS2	1 0	IEI FILEI	1 1
IEV/DEPER/EPB 36	3 3	IEV/DEPER/IRB 35	1 1
IEV/DEQA/QAB 21	1 1	NRR/DE/AEAB	1 0
NRR/DEVCEB 11	1 1	NRR/DE/EHEB	1 1
NRR/DEVEQB 13	2 2	NRR/DE/GB 28	2 2
NRR/DEVHGB 30	1 1	NRR/DE/MEB 18	1 1
NRR/DEVMTEB 17	1 1	NRR/DE/SAB 24	1 1
NRR/DEVSGB 25	2 2	NRR/DHFS/HFEB40	1 1
NRR/DHFS/LQB 32	1 1	NRR/DL/SSPB	1 0
NRR/DSI/AEB 26	1 1	NRR/DSI/ASB	1 1
NRR/DSI/CPB 10	1 1	NRR/DSI/CSB 09	1 1
NRR/DSI/ICSB 16	1 1	NRR/DSI/MEIB 12	1 1
NRR/DSI/PSB 19	1 1	NRR/DSI/RAB 22	1 1
NRR/DSI/RSB 23	1 1	REG. FILEI 04	1 1
RGNS	3 3	RM/DDAMI/MIB	1 0

EXTERNAL: ACRS 41 6 6 BNLC(AMDT) ONLY 1 1
 DMB/DSS (AMDT) 1 1 FEMA-REPL DIVI 39 1 1
 LPDR 03 1 1 NRCI POR 02 1 1
 NSICI 05 1 1 NTIS 1 1

NOTES: 3 3

TOTAL NUMBER OF COPIES REQUIRED: LITR 57 ENCL 50

Southern California Edison Company



P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

K. P. BASKIN
MANAGER OF NUCLEAR ENGINEERING,
SAFETY, AND LICENSING

TELEPHONE
(213) 572-1401

May 13, 1983

Director, Office of Nuclear Reactor Regulation
Attention: Mr. George W. Knighton, Branch Chief
Licensing Branch No. 3
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 2 and 3

In response to the NRC's request for additional clarification relative to SCE's April 15, 1983 reactor trip breaker (RTB) report, SCE's letter dated April 20, 1983, informed the NRC that SCE has a high degree of confidence that there are no safety related applications of integral undervoltage trip devices other than in the reactor trip switchgear at San Onofre Units 2 and 3. The April 20, 1983 letter also indicated that SCE was performing a detailed review for verification and that confirmation would be provided.

Consistent with SCE's commitment, the purpose of this letter is to inform you that we have completed our review and have confirmed that there are no safety related applications of integral undervoltage trip devices other than in the reactor trip switchgear at San Onofre Units 2 and 3.

If you have any questions or comments, please let me know.

Very truly yours,

KP Baskin

Boo1

cc: Mr. J. B. Martin, Regional Administrator
U.S. Nuclear Regulatory Commission, Region V
Mr. H. Rood, Project Manager (Open by addressee only)

8305170278 830513
PDR ADOCK 05000361
S PDR