

# REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8407100408      DOC. DATE: 84/06/11      NOTARIZED: NO      DOCKET #  
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ      05000361  
       50-362 San Onofre Nuclear Station, Unit 3, Southern Californ      05000362  
 AUTH. NAME      AUTHOR AFFILIATION  
 MEDFORD, M.O.      Southern California Edison Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
 KNIGHTON, G.W.      Licensing Branch 3

SUBJECT: Forwards auxiliary feedwater sys (AFWS) monthly outage rept  
 for 840416-0515. during reporting period, AFWS availability  
 was 100%.

DISTRIBUTION CODE: A001S      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 2  
 TITLE: OR Submittal: General Distribution

NOTES: J Hanchett 1cy PDR Documents. ELD Chandler 1cy.      05000361  
       OL: 02/16/82  
       J Hanchett 1cy PDR Documents. ELD Chandler 1cy.      05000362  
       OL: 11/15/82

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR LB3 BC	01	7	7			
INTERNAL:	ELD/HDS2		1	0	NRR/DE/MTEB		1 1
	NRR/DL DIR		1	1	NRR/DL/ORAB		1 0
	NRR/DSI/METB		1	1	NRR/DSI/RAB		1 1
	<u>REG FILE</u>	04	1	1	RGN5		1 1
EXTERNAL:	ACRS	09	6	6	LPDR	03	1 1
	NRC PDR	02	1	1	NSIC	05	1 1
	NTIS		1	1			
NOTES:			2	2			

HR

**Southern California Edison Company**

**SCE**

P. O. BOX 800  
2244 WALNUT GROVE AVENUE  
ROSEMEAD, CALIFORNIA 91770

**M.O. MEDFORD**  
MANAGER, NUCLEAR LICENSING

June 11, 1984

TELEPHONE  
(213) 572-1749

Director, Office of Nuclear Reactor Regulation  
Attention: Mr. George W. Knighton, Branch Chief  
Licensing Branch No. 3  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362  
Auxiliary Feedwater System Monthly Outage Report  
San Onofre Nuclear Generating Station, Units 2 and 3

Pursuant to License Condition 2.C(26) of Facility Operating License NPF-15 for San Onofre Unit 3, this submittal provides the required monthly report describing any occurrence resulting in the degradation of the Units 2 and 3 Auxiliary Feedwater Systems (AFWS). This report covers the period from April 16, 1984, to May 15, 1984. The component involved, cause of outage, outage duration, and corrective actions taken to return the equipment to operable status are listed.

During the reporting period, AFWS availability was 100%. Component unavailability during the period was 1.1% for Unit 2 and .3% for Unit 3. The enclosure to this letter delineates the specific outages.

In accordance with License Condition 2.C(26), our next report will cover the period from May 16, 1984, to June 15, 1984.

If there are any questions regarding this report, please contact me.

Sincerely,

*M.O. Medford*

8407100408 840611  
PDR ADDCK 05000361  
R PDR

Enclosure

cc: J. B. Martin, (Regional Administrator  
U.S. Nuclear Regulatory Commission, Region V)

H. Rood, Project Manager, SONGS 2/3, NRR

A. E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)  
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

*Aool*

San Onofre Nuclear Generating Station, Units 2 and 3

Monthly AFWS Outage Report  
April 16, 1984 to May 15, 1984

Date	Unit	Outage	Duration [(hours)]	Outage Cause	Corrective Action
05/01/84	2	Corrective Maintenance	7 3/4	2HV4714 was removed from service to investigate and repair hydraulic pump controller.	Pressure switch 2PSL4714-2 was recalibrated.
05/02/84	3	Corrective Maintenance	2	S31305MP140 was removed from service to adjust speed from 3690 to 3570 rpm.	Governor control adjusted to maintain proper speed.