

RECEIVED
NRC

Southern California Edison Company JUL 25 AM 11:25

SCE

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

REGION V IAE

July 19, 1984

TELEPHONE
(714) 492-7700

J. G. HAYNES
STATION MANAGER

IE HQ FILE COPY

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - June 1984
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, J. G. Haynes (SCE) to J. B. Martin (NRC),
dated June 18, 1984

In accordance with our referenced letter, this submittal provides the follow-up report of fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in June 1984.

Fire doors found inoperable during the June routine surveillances are identified in the Attachment and include: 6 latching mechanism failures; 8 closure mechanism failures; and 12 doors blocked open typically for construction or maintenance activities. As each of these deficiencies was identified, compensatory fire watches, pursuant to Technical Specification 3.7.9, Action Statement 'a', were established. We are continuing corrective actions to upgrade door latches and closure mechanisms.

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in July 1984 will be submitted by August 21, 1984.

B407310349 B40719
PDR ADDCK 05000341
S PDR

IE-28

Mr. J. B. Martin

-2-

If you require any additional information, please so advise.

Sincerely,

JG Haynes/DEM

Enclosure

cc: A. E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U. S. Nuclear Regulatory Commission
Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JUNE 1984
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 6, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
*AR-104		
AC-105	6/13	Work in Progress
FH2-302	6/1	6/15
FH2-304	6/25	6/26
AC-351	6/1	6/3
AR-402	6/29	Work in Progress

*These fire doors were identified in May and remained inoperable during June. Corrective action is in progress.

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JUNE 1984
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

II. Closure Mechanism Failures:

Number of doors inoperable - 8, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-219	6/7	6/9
AC-223	6/7	6/13
AC-239	6/7	6/13
*FH3-302		
FH2-303	6/13	6/14
FH3-304	6/4	6/5
AC-345	6/4	6/5
AR-501	6/9	6/12

*These fire doors were identified in May and remained inoperable during June. Corrective action is in progress.

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JUNE 1984
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

III. Doors Blocked Open:

Number of doors inoperable - 12, as follows:

<u>Door Number</u>	<u>Date Found Inoperable (fire watches established within one hour)</u>
AR-101	6/7
FH2-101	6/7
AC-118	6/27
AC-133	6/15
	6/18
AC-260	6/1
AR-313	6/10
AC-331	6/22
AC-344	6/22
C2-403	6/15
C3-403	6/13
AR-406	6/15
AR-504	6/13