

Southern California Edison Company



SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES
STATION MANAGER

September 18, 1984

IE FILE COPY

TELEPHONE
(714) 492-7700

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - August 1984
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, J. G. Haynes (SCE) to J. B. Martin (NRC),
dated August 21, 1984

In accordance with our referenced letter, this submittal provides the follow-up report of fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in August 1984.

Fire doors found inoperable during the August routine surveillances are identified in the Attachment and include: 4 latching mechanism failures; 9 closure mechanism failures; and 6 doors blocked open typically for construction or maintenance activities. As each of these deficiencies was identified, compensatory fire watches, pursuant to Technical Specification 3.7.9, Action Statement 'a', were established.

We are continuing the corrective actions to upgrade door latches and closure mechanisms. A disciplinary action policy was implemented August 15, 1984, by Station Management, in order to eliminate occurrences of blocked open fire doors without the required Fire Barrier Removal and Reinstallation Request.

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in September 1984 will be submitted by October 19, 1984.

8410090327 840918
PDR ADOCK 05000361
F PDR

IE-28 11

Mr. J. B. Martin

-2-

If you require any additional information, please so advise.

Sincerely,

J. H. Haynes

Enclosure

cc: A. E. Chaffee (USNRC Senior Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U. S. Nuclear Regulatory Commission
Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF AUGUST 1984
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 4, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-111	8/9	8/17
AC-123	8/29	Work in Progress
AC-348	8/1	8/6
AR-504	8/20	8/22

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF August 1984
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

II. Closure Mechanism Failures:

Number of doors inoperable - 9, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
FH2-103	8/13	8/14
AC-133	8/13	8/14
FH2-207	8/13	8/14
FH3-207	8/4	8/22
	8/29	Work in progress
FH2-304	8/13	8/14
FH3-304	8/5	8/8
AC-345	8/1	8/9
C3-405	8/5	8/8
AR-504	8/10	8/11

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF AUGUST 1984
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

III. Doors Blocked Open:

Number of doors inoperable - 6, as follows:

<u>Door Number</u>	<u>Date Found Inoperable (fire watches established within one hour)</u>
AC-110	8/13
AC-259	8/3
AC-260	8/1
AC-310	8/7
AC-311	8/7
AC-339	8/7