

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8412280027 DOC.DATE: 84/12/26 NOTARIZED: NO DOCKET #
 FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH.NAME AUTHOR AFFILIATION
 MEDFORD,M.O. Southern California Edison Co.
 RECIP.NAME RECIPIENT AFFILIATION
 KNIGHTON,G.W. Licensing Branch 3

SUBJECT: Forwards auxiliary feedwater sys monthly outage rept for
 841016-1115.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES:J Hanchett 1cy PDR Documents. ELD Chandler 1cy. 05000361
 OL:02/16/82
 J Hanchett 1cy PDR Documents. ELD Chandler 1cy. 05000362
 OL:11/15/82

RECIPIENT			COPIES		RECIPIENT			COPIES	
ID	CODE/NAME		LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL	
NRR	LB3 BC	01	7	7					
INTERNAL:	ACRS	09	6	6	ADM/LFMB		1	0	
	ELD/HDS2		1	0	NRR/DE/MTEB		1	1	
	NRR/DL DIR		1	1	NRR/DL/ORAB		1	0	
	NRR/DSI/METB		1	1	NRR/DSI/RAB		1	1	
	<u>REG FILE</u>	04	1	1	RGNS		1	1	
EXTERNAL:	LPDR	03	1	1	NRC PDR	02	1	1	
	NSIC	05	1	1	NTIS		1	1	
NOTES:			2	2					

Southern California Edison Company



P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

M. O. MEDFORD
MANAGER, NUCLEAR LICENSING

December 26, 1984

TELEPHONE
(818) 572-1749

Director, Office of Nuclear Reactor Regulation
Attention: Mr. George W. Knighton, Branch Chief
Licensing Branch No. 3
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
Auxiliary Feedwater System Monthly Outage Report
San Onofre Nuclear Generating Station, Units 2 and 3

Pursuant to License Condition 2.C(26) of Facility Operating License NPF-15 for San Onofre Unit 3, this submittal provides the required monthly report describing any occurrence resulting in the degradation of the Units 2 and 3 Auxiliary Feedwater Systems (AFWS). This report covers the period from October 16, 1984, to November 15, 1984. The component involved, cause of outage, outage duration, and corrective actions taken to return the equipment to operable status are listed.

During the period from October 16, 1984 to October 22, 1984, Unit 2 operated in Modes 1, 2 and 3 and AFWS availability was 100%. During the period from October 16, 1984 to October 28, 1984, Unit 3 operated in Modes 1, 2 and 3 and AFWS availability was 100%. Component unavailability for those periods was 0% for both units. For the remainder of the reporting period both units were in Modes 4, 5 or 6. For these periods the duration of equipment outages is not specified and the AFWS is not required to be operable per the Technical Specifications.

In accordance with License Condition 2.C(26), our next report will cover the period from November 16, 1984, to December 15, 1984.

If there are any questions regarding this report, please contact me.

Sincerely,

M. O. Medford

8412280027 841226
PDR ADDCK 05000361
R PDR

Enclosure

cc: J. B. Martin, (Regional Administrator
U.S. Nuclear Regulatory Commission, Region V)

H. Rood, Project Manager, SONGS 2/3, NRR

F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

*Aool
11*

San Onofre Nuclear Generating Station, Units 2 and 3
 Monthly AFWS Outage Report
 October 16, 1984 to November 15, 1984

Date	Unit	Outage	Duration (hours)	Outage Cause	Corrective Action
10/26/	2	Preventative Maintenance and Design Change Packages (DCP 127m, DCP 1257.OE, DCP 1396.OP)	--	Auxiliary Feedwater Pumps (P-140; P-504) were removed from service to modify the steam inlet piping per DCP 1396.OP, modify the governor controls per DCP 1257.OE, modify the Pump Motor Bear- ings and install a gravity feed lube oil system per DCP 127m, and miscellaneous surveillances	None Required