

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8502190261 DOC.DATE: 85/02/06 NOTARIZED: NO DOCKET #  
 FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361  
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362  
 AUTH.NAME: AUTHOR AFFILIATION  
 MEDFORD,M.O. Southern California Edison Co.  
 RECIP.NAME: RECIPIENT AFFILIATION  
 KNIGHTON,G.W. Licensing Branch 3

SUBJECT: Provides required monthly outage rept for 841216-850115  
 describing occurrence resulting in degradation of auxiliary  
 feedwater sys,per License Condition 2.C.Component involved  
 & corrective actions taken listed.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2  
 TITLE: OR Submittal: General Distribution

NOTES:J Hanchett 1cy PDR Documents. ELD Chandler 1cy. 05000361  
 OL:02/16/82  
 J Hanchett 1cy PDR Documents. ELD Chandler 1cy. 05000362  
 OL:11/15/82

|           | RECIPIENT<br>ID CODE/NAME |    | COPIES<br>LTTR ENCL |   | RECIPIENT<br>ID CODE/NAME |    | COPIES<br>LTTR ENCL |
|-----------|---------------------------|----|---------------------|---|---------------------------|----|---------------------|
|           | NRR LB3 BC                | 01 | 7                   | 7 |                           |    |                     |
| INTERNAL: | ACRS                      | 09 | 6                   | 6 | ADM/LFMB                  |    | 1 0                 |
|           | ELD/HDS2                  |    | 1                   | 0 | NRR/DE/MTEB               |    | 1 1                 |
|           | NRR/DL DIR                |    | 1                   | 1 | NRR/DL/ORAB               |    | 1 0                 |
|           | NRR/DL/TSRG               |    | 1                   | 1 | NRR/DSI/METB              |    | 1 1                 |
|           | NRR/DSI/RAB               |    | 1                   | 1 | <u>REG FILE</u>           | 04 | 1 1                 |
|           | RGNS                      |    | 1                   | 1 |                           |    |                     |
| EXTERNAL: | LPDR                      | 03 | 1                   | 1 | NRC PDR                   | 02 | 1 1                 |
|           | NSIC                      | 05 | 1                   | 1 |                           |    |                     |
| NOTES:    |                           |    | 2                   | 2 |                           |    |                     |

*Southern California Edison Company*

P. O. BOX 800  
2244 WALNUT GROVE AVENUE  
ROSEMEAD, CALIFORNIA 91770

M. O. MEDFORD  
MANAGER, NUCLEAR LICENSING

February 6, 1985

TELEPHONE  
(818) 302-1749

Director, Office of Nuclear Reactor Regulation  
Attention: Mr. George W. Knighton, Branch Chief  
Licensing Branch No. 3  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362  
Auxiliary Feedwater System Monthly Outage Report  
San Onofre Nuclear Generating Station, Units 2 and 3

Pursuant to License Condition 2.C(26) of Facility Operating License NPF-15 for San Onofre Unit 3, this submittal provides the required monthly report describing any occurrence resulting in the degradation of the Units 2 and 3 Auxiliary Feedwater Systems (AFWS). This report covers the period from December 16, 1984, to January 15, 1985. The component involved, cause of outage, outage duration, and corrective actions taken to return the equipment to operable status are listed.

During the entire reporting period Unit 3 was operating in Mode 1 with 100% AFWS availability and a component unavailability of 0%. For the same period Unit 2 was defueled for which the AFWS is not required to be operable per the Technical Specifications and the duration of equipment outages is not specified.

In accordance with License Condition 2.C(26), our next report will cover the period from January 16, 1984, to February 15, 1985.

If there are any questions regarding this report, please contact me.

Sincerely,

*M. O. Medford*

8502190261 850206  
PDR ADDCK 05000361  
R PDR

Enclosure

cc: J. B. Martin (Regional Administrator  
U.S. Nuclear Regulatory Commission, Region V)

H. Rood (Project Manager SONGS 2/3,  
U.S. Nuclear Regulatory Commission, NRR)

F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)  
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

*Ad*

San Onofre Nuclear Generating Station, Units 2 and 3  
 Monthly AFWS Outage Report  
 December 16, 1984 to January 15, 1985

| Date     | Unit | Outage   | Duration<br>(hours) | Outage<br>Cause  | Corrective<br>Action |
|----------|------|--|---------------------|--|----------------------|
| 12/16/84 | 2    | Preventative<br>Maintenance<br>and<br>Design Change<br>Packages<br>(DCP 127.OM,<br>DCP 1257.OE,<br>DCP 1396.OP,<br>DCP 195.OJ) | --                  | Auxiliary Feedwater Pumps<br>(P-140; P-504) were<br>removed from service to<br>modify the steam inlet<br>piping per DCP 1396.OP,<br>modify the governor<br>controls per DCP 1257.OE,<br>modify the Pump Motor Bear-<br>ings per DCP 195.OJ,<br>install a gravity feed lube<br>oil system per DCP 127.OM,<br>and miscellaneous<br>surveillances | None<br>Required     |

53415:3376□