

RECEIVED
NRC

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

1985 JUN 17 PM 12:44

REGION V IAE

J. G. HAYNES
STATION MANAGER

June 12, 1985

TELEPHONE
(714) 492-7700

SCE

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - May 1985
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, J. G. Haynes (SCE) to J. B. Martin (NRC),
dated April 15, 1985

In accordance with our referenced letter, this submittal provides the follow-up report of fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in May 1985.

Fire doors found inoperable during the May routine surveillances are identified in the Attachment and include: 7 latching mechanism failures; 11 closure mechanism failures; and 11 doors blocked open typically for construction or maintenance activities. As each of these deficiencies was identified, compensatory fire watches, pursuant to Technical Specification 3.7.9, Action Statement 'a', were established. We are continuing previously reported corrective actions to upgrade door latches and closure mechanisms.

An investigation was conducted for the blocked open fire doors. This investigation determined that the doors were found blocked open due to a lack of signage identifying these doors as requiring appropriate authorization and the posting of a fire watch, prior to being blocked open. The signage was installed on June 11, 1985. As interim corrective action, each of the fire doors which had deficient signage had the required fire watch established to meet the action statement requirements of Technical Specification 3.7.9.

8506280043 850612
PDR ADCK 05000361
S PDR

IE-01

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in June 1985 will be submitted by July 15, 1985.

If you require any additional information, please so advise.

Sincerely,

A handwritten signature in dark ink, appearing to read "J. B. Martin", with a stylized flourish at the end.

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U. S. Nuclear Regulatory Commission
Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF MAY
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 7, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-331	5/09	5/10
	5/11	5/13
AC-350	5/09	5/10
AC-442	5/27	5/28
AR-203	5/20	5/21
AR-402	5/11	5/14
FH2-103	5/01	5/02

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF MAY
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

II. Closure Mechanism Failures:

Number of doors inoperable - 11, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-301	5/30	----
AC-339	5/28	5/29
AC-344	5/28	5/29
AC-442	5/11	5/18
	5/19	5/20
	5/27	5/28
AC-458	5/29	5/30
AC-459	5/15	5/16
	5/17	5/18
	5/19	5/20
	5/27	----

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF MAY
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

II. Doors Blocked Open:

Number of doors inoperable - 11, as follows:

<u>Door Number</u>	<u>Date Found Inoperable (fire watches established within one hour)</u>
AC-122	5/20
	5/21
AR-312	5/25
FH2-103	5/01
S2-018	5/01
	5/04
	5/14
S3-018	5/02
	5/05
	5/10
	5/19