

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8212230325 DOC. DATE: 82/12/21 NOTARIZED: NO DOCKET #  
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern California 05000361  
 AUTH. NAME AUTHOR AFFILIATION  
 BASKIN, K.P. Southern California Edison Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 KNIGHTON, G.W. Licensing Branch 3

SUBJECT: Suppls 821220 ltr re proposed change to License NPF-10.  
 Component cooling water sys adequate simultaneously serve  
 all essential & nonessential loads except shutdown cooling  
 HX. Safety analyses not affected by change.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: J Hanchett 1cy PDR Documents, ELD Chandler 1cy. 05000361  
 NRR Scaletti 1cy.

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
NRR/DL/ADL		1	0	NRR LB3 BC		1	0
NRR LB3 LA		1	0	ROOD, H.	01	1	1
INTERNAL: ELD/HDS2		1	0	IE FILE		1	1
IE/DEP EPDS	35	1	1	IE/DEP/EPLB	36	3	3
NRR/DE/AEAB		1	0	NRR/DE/CEB	11	1	1
NRR/DE/eqB	13	2	2	NRR/DE/GB	28	2	2
NRR/DE/HGEB	30	1	1	NRR/DE/MEB	18	1	1
NRR/DE/MTEB	17	1	1	NRR/DE/QAB	21	1	1
NRR/DE/SAB	24	1	1	NRR/DE/SEB	25	1	1
NRR/DHFS/HFEB40		1	1	NRR/DHFS/LQB	32	1	1
NRR/DHFS/OLB	34	1	1	NRR/DL/SSPB		1	0
NRR/DSI/AEB	26	1	1	NRR/DSI/CPB	10	1	1
NRR/DSI/CSB	09	1	1	NRR/DSI/ICSB	16	1	1
NRR/DSI/METB	12	1	1	NRR/DSI/PSB	19	1	1
NRR/DSI/RAB	22	1	1	NRR/DSI/RSB	23	1	1
REG FILE	04	1	1	RGNS		3	3
RM/DDAMI/MIB		1	0				
EXTERNAL: ACRS	41	6	6	BNL (AMDTs ONLY)		1	1
DMB/DSS (AMDTs)		1	1	FEMA-REP DIV	39	1	1
LPDR	03	1	1	NRC PDR	02	1	1
NSIC	05	1	1	NTIS		1	1
NOTES:		3	3				

*Southern California Edison Company*



P. O. BOX 800  
2244 WALNUT GROVE AVENUE  
ROSEMEAD, CALIFORNIA 91770

K. P. BASKIN  
MANAGER OF NUCLEAR ENGINEERING,  
SAFETY, AND LICENSING

December 21, 1982

TELEPHONE  
(213) 572-1401

Director, Office of Nuclear Reactor Regulation  
Attention: Mr. George W. Knighton, Branch Chief  
Licensing Branch No. 3  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-361  
San Onofre Nuclear Generating Station  
Unit 2

The purpose of this letter is to supplement SCE's letter to the NRC of December 20, 1982 concerning proposed change NPF-10-60 to Operating License NPF-10. The supplementary information covers two areas: (1) review of the FSAR Chapter 15 Safety Analyses and (2) Analyses of Component Cooling Water (CCW) System Heat Loads.

The Chapter 15 Safety Analyses have been reviewed to assess the impact of the subject design change. The result of this assessment is that the safety analyses are not impacted by the proposed change. A more detailed discussion of this review will be provided during the week of January 17, 1983.

The CCW System design has been reviewed and has been verified that flow and heat capacity are adequate to simultaneously serve all essential and non-essential loads with the exception of the Shutdown Cooling Heat Exchanger (SDCHX). The SDCHX are isolated until they receive Containment Spray Actuation Signal at approximately 16 psig containment pressure.

Because the proposed signal to isolate the essential from the non-essential loads occurs at approximately 3 psig containment pressure (on Containment Isolation Actuation Signal), the CCW system capacity will not be exceeded.

If you have any questions concerning the above information, please call me.

Very truly yours,

*KP Baskin*

*Boo!*

cc: Harry Rood, NRC (to be opened by addressee only)

8212230325 821221  
PDR ADOCK 05000361  
P PDR