

**Southern California Edison Company**



P. O. BOX 800  
2244 WALNUT GROVE AVENUE  
ROSEMEAD, CALIFORNIA 91770

JACK B. MOORE  
VICE PRESIDENT

TELEPHONE  
213-572-2292

December 1, 1978

Mr. R. H. Engelken, Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Region V  
Suite 202, Walnut Creek Plaza  
1990 North California Boulevard  
Walnut Creek, California 94596

Dear Mr. Engelken:

Subject: Docket Nos. 50-361 and 50-362  
San Onofre Nuclear Generating Station, Units 2 and 3

In a jobsite meeting with Mr. R. G. Pate on November 17, 1978, we reported a condition discovered in construction which we consider to be reportable in accordance with 10CFR50.55(e). This condition involves defects identified in ASME B&PV Section III Class 2 pipe manufactured in accordance with SA-312 Type 304 and installed in portions of the Unit 3 Low Pressure Safety Injection System.

Enclosed in accordance with 10CFR50.55(e)(3) are twenty-five (25) copies of a final report entitled, "Final Report Concerning Deficiencies in SA-312 Type 304 Pipe Manufactured by Youngstown Welding and Engineering Company, San Onofre Nuclear Generating Station, Units 2 and 3."

If you have any questions regarding this report, we would be pleased to discuss this matter with you at your convenience.

Very truly yours,

Enclosures

cc: John G. Davis (NRC, Acting Director I&E)  
R. J. Pate (NRC, San Onofre)

7812210263