

25

Hardies, Robert

From: Poehler, Jeffrey *nr*
Sent: Tuesday, December 18, 2012 5:17 PM
To: 'TOMBUYES Beatrice'; Ekström, Peter; VAN WONTERGHEM Frederik; A.Zeman@iaea.org; WEYN Andre; bernard.monnot@irsn.fr; fvanherck@vincotte.be; g.diego@ciemat.es; Gareth.Hopkin@hse.gsi.gov.uk; jesus.lg@ciemat.es; kanno-masanori@jnes.go.jp; marc.pic@asn.fr; Ralf.ahlstrand@ec.europa.eu; Hardies, Robert; sebastien.crombez@asn.fr; Stephen.Druce@hse.gsi.gov.uk; Uwe.Jendrich@grs.de; ybkim@kins.re.kr
Cc: WEYN Andre; WERTELAERS An; VAN WONTERGHEM Frederik; OULIDDREN Kamreddine; pierre.briegleb@belv.be; guy.roussel@Belv.be; daniel.marloye@Belv.be; SCHRAUBEN Manfred; marc.deprez@belv.be; DE ROOVERE Willy; vincent.deledicque@belv.be
Subject: RE: Doel 3 & Tihange 2 RPV Issue - WG2 - Laborelec notes

Beatrice,

Will FANC or Laborelec publish a comprehensive root cause analysis report on the Doel 3 and Tihange 2 indications? Although I am convinced the observed indications are the result of hydrogen flaking during fabrication, I still have significant questions regarding why these particular forgings were affected. It may not be possible to ever know for sure due to lack of documentation on practices such as dehydrogenation heat treatment after forging.

It is also unlikely that I will be able to travel to any meetings in the near term.

Best regards,

Jeffrey Poehler
Senior Materials Engineer
Vessel & Internals Integrity Branch
Office of Nuclear Reactor Regulation
Nuclear Regulatory Commission
(301) 415-8353

From: TOMBUYES Beatrice [mailto:Beatrice.TOMBUYES@FANC.FGOV.BE]
Sent: Wednesday, November 28, 2012 1:55 PM
To: Ekström, Peter; VAN WONTERGHEM Frederik; A.Zeman@iaea.org; WEYN Andre; bernard.monnot@irsn.fr; fvanherck@vincotte.be; g.diego@ciemat.es; Gareth.Hopkin@hse.gsi.gov.uk; Poehler, Jeffrey; jesus.lg@ciemat.es; kanno-masanori@jnes.go.jp; marc.pic@asn.fr; Ralf.ahlstrand@ec.europa.eu; Hardies, Robert; sebastien.crombez@asn.fr; Stephen.Druce@hse.gsi.gov.uk; Uwe.Jendrich@grs.de; ybkim@kins.re.kr
Cc: WEYN Andre; WERTELAERS An; VAN WONTERGHEM Frederik; OULIDDREN Kamreddine; pierre.briegleb@belv.be; guy.roussel@Belv.be; daniel.marloye@Belv.be; SCHRAUBEN Manfred; marc.deprez@belv.be; DE ROOVERE Willy; vincent.deledicque@belv.be
Subject: Doel 3 & Tihange 2 RPV Issue - WG2 - Laborelec notes

Dear Member of Working Group 2,

(b)(4).(b)(7)(D)

E/48

(b)(4).(b)(7)(D)

On the basis of these notes, are you interested to meet the authors to discuss the various topics? We could organise such a meeting. For efficiency, we would like to ask you to send in advance questions and topics that you would like to discuss with them in more detail.

Best regards,

Béatrice Tombuyses
Technical Secretary WG2

FEDERAL AGENCY FOR NUCLEAR CONTROL
Ravensteinstraat 36, 1000 Brussel
www.fanc.fgov.be
Tel.: +32 (0)2 289 21 75
Fax: +32 (0)2 289 21 12

