

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8208030201 DOC.DATE: 82/07/29 NOTARIZED: NO DOCKET #
FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
AUTH.NAME AUTHOR AFFILIATION
BASKIN,K.P. Southern California Edison Co.
RECIP.NAME RECIPIENT AFFILIATION
MIRAGLIA,F. Licensing Branch 3

SUBJECT: Revises position in 820727 ltr re fire separation of
auxiliary feedwater pumps.Metal barrier will be installed
in pump room.Util cannot commit to change completion prior
to startup following second refueling outage.

DISTRIBUTION CODE: B001S COPIES RECEIVED:LTR 1 ENCL 1 SIZE:-----
TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES:J Hanchett 1cy PDR Documents. ELD Chandler 1cy. 05000361
NRR Scaletti 1cy.
J Hanchett 1cy PDR Documents. ELD Chandler 1cy. 05000362
NRR Scaletti 1cy.

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID CODE/NAME		LTTR	ENCL	ID CODE/NAME		LTTR	ENCL
A/D LICENSNG		1	0	LIC BR #3 BC		1	0
LIC BR #3 LA		1	0	ROOD,H.	01	1	1
INTERNAL: ELD/HDS2		1	0	IE FILE		1	1
IE/DEP EPDS	35	1	1	IE/DEP/EPLB	36	3	3
NRR/DE/CEB	11	1	1	NRR/DE/EQB	13	3	3
NRR/DE/GB	28	2	2	NRR/DE/HGEB	30	2	2
NRR/DE/MEB	18	1	1	NRR/DE/MTEB	17	1	1
NRR/DE/QAB	21	1	1	NRR/DE/SAB	24	1	1
NRR/DE/SEB	25	1	1	NRR/DHFS/HFEB40		1	1
NRR/DHFS/LQB	32	1	1	NRR/DHFS/OLB	34	1	1
NRR/DHFS/PTRB20		1	1	NRR/DSI/AEB	26	1	1
NRR/DSI/ASB	27	1	1	NRR/DSI/CPB	10	1	1
NRR/DSI/CSB	09	1	1	NRR/DSI/ETSB	12	1	1
NRR/DSI/ICSB	16	1	1	NRR/DSI/PSB	19	1	1
NRR/DSI/RAB	22	1	1	NRR/DSI/RSB	23	1	1
NRR/DST/LGB	33	1	1	REG FILE	04	1	1
RGN5		2	2	RM/DDAMI/MIB		1	0
EXTERNAL: ACRS	41	10	10	BNL(AMDTs ONLY)		1	1
DMB/DSS (AMDTs)		1	1	FEMA-REP DIV	39	1	1
LPDR	03	1	1	NRC PDR	02	1	1
NSIC	05	1	1	NTIS		1	1
NOTES:		3	3				

TOTAL NUMBER OF COPIES REQUIRED: LTTR 61 ENCL 56

Southern California Edison Company



P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

K. P. BASKIN
MANAGER OF NUCLEAR ENGINEERING,
SAFETY, AND LICENSING

July 29, 1982

TELEPHONE
(213) 572-1401

Director, Office of Nuclear Reactor Regulation
Attention: Mr. Frank Miraglia, Branch Chief
Licensing Branch No. 3
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 2 and 3

Reference is made to Southern California Edison Company's (SCE) letter of July 27, 1982, relating to fire protection at San Onofre Nuclear Generating Station, Units 2 and 3. The purpose of this letter is to revise the SCE position taken in the referenced letter regarding Item 5, Fire Separation of Auxilliary Feedwater Pumps.

Southern California Edison is commencing to design and will install a metal barrier in the auxilliary feedwater pump room. The metal barrier will be approximately six feet tall and eight feet long and will separate the second motor driven auxilliary feedwater pump from the turbine driven auxilliary feedwater pump.

As stated in the July 27, 1982 letter, because of the limited time available for evaluation of this change, SCE cannot commit at this time to completion of this change prior to startup following the second refueling outage. SCE will provide the NRC with a firm schedule for completion of this change by August 31, 1982 (this date was erroneously stated as August 31, 1981 in the July 27 letter), and will make every effort to expedite the completion of this change once the schedule is established.

If you have any questions concerning the information contained in this letter, please call me.

Very truly yours,

KP Baskin

8001

8208030201 820729
PDR ADDCK 05000361
F PDR