



Scott L. Batson
Vice President
Oconee Nuclear Station

Duke Energy
ON01VP | 7800 Rochester Hwy
Seneca, SC 29672

o: 864.873.3274
f: 864.873.4208
Scott.Batson@duke-energy.com

ONS-2013-036

10 CFR 50.4

December 12, 2013

ATTN: Document Control Desk
U. S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, Maryland 20852-2746

Subject: Duke Energy Carolinas, LLC
Oconee Nuclear Station (ONS), Units 1, 2, and 3
Renewed Facility Operating License Numbers DPR-38, 47, and 55
Docket Numbers 50-269, 50-270, and 50-287
Completion of Protected Service Water System Milestone 2

Reference: NRC letter to Duke Energy, "NOTICE OF VIOLATION AND CONFIRMATORY ORDER RELATED TO A FIRE PROTECTION PROGRAM LICENSE CONDITION (OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3)," dated July 1, 2013

The confirmatory order (Reference) related to an ONS fire protection program license condition requires Duke Energy to report the completion of each milestone within 30 days of completion. Duke Energy completed Milestone 2 on November 15, 2013. Milestone 2 requires Duke Energy to provide ONS the capability to supply electrical power from each of the Keowee Hydro Units to the PSW building switchgear and from there to the SSF switchgear, with sufficient capacity to operate all credited SSF equipment in the event of a failure of the SSF diesel generator during a fire for which the SSF is credited. The order requires this modification, along with approved plant procedures and the completion of operator training necessary to accomplish this lineup, and a combination of testing and engineering evaluation in accordance with station procedures which verifies this capability, to be completed and operational no later than July 18, 2014.

If there are any additional questions, please contact Terry Patterson, ONS Safety Assurance, at (864) 873-3163.

I declare under penalty of perjury that the foregoing is true and correct. Executed on December 12, 2013.

Sincerely,

Scott L. Batson
Vice President
Oconee Nuclear Station

A006
NRK

cc:

Mr. Victor McCree, Regional Administrator
U. S. Nuclear Regulatory Commission - Region II
Marquis One Tower
245 Peachtree Center Ave., NE, Suite 1200
Atlanta, GA 30303-1257

Mr. Richard Guzman, Senior Project Manager
(by electronic mail only)
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
11555 Rockville Pike
Mail Stop O-8C2
Rockville, MD 20852

Mr. Eddy Crowe
Senior Resident Inspector
Oconee Nuclear Site

Ms. Susan E. Jenkins, Manager
Radioactive & Infectious Waste Management
Division of Waste Management
South Carolina Department of Health and Environmental Control
2600 Bull St.
Columbia, SC 29201