

# REGULATORY GUIDE

## OFFICE OF STANDARDS DEVELOPMENT

### REGULATORY GUIDE 4.10

## IRREVERSIBLE AND IRRETRIEVABLE COMMITMENTS OF MATERIAL RESOURCES

### A. INTRODUCTION

In accordance with 10 CFR Part 51, applicants are required to discuss any irreversible and irretrievable commitments of resources that would be involved in a proposed action should it be implemented. The construction and operation of nuclear power stations involves commitments of such resources as water, fuel, and materials. This guide identifies a report on material resources that forms a basis acceptable to the NRC staff for required discussions of irreversible and irretrievable commitments of material resources involved in the construction of a 1000 MWe pressurized water reactor.

### B. DISCUSSION

A discussion of material resources acceptable to the NRC staff is presently described in Section 4.3 of Regulatory Guide 4.2, "Preparation of Environmental Reports for Nuclear Power Plants." In addition, a discussion of such commitments relating to alternative energy sources is described in Section 9.3 and to alternative plant designs in Chapter 10 of the same guide. This guide describes numerical estimates useful in all such discussions. It also provides methods of computation that may be referenced in Section 10 f. of Regulatory Guide 4.2, which treats supporting details for the consideration of plant design alternatives; it does not, however, provide a basis for a discussion of resource commitments required for fossil plant alternatives.

Oak Ridge National Laboratory has published a report (Ref. 1) based on work carried out under contract with the Atomic Energy Commission's Directorates of Regulatory Standards and Licensing on the problem of material resource commitment. This report gives a detailed estimate of the materials contained in a typical 1000-MWe pressurized water reactor power plant, where typical parameters are defined in terms of a

referenced model plant. Reference plant features, methods used in making the estimate, accuracy of the estimates, and the accounting system employed are discussed in the report. Estimated quantities of the composite materials and their constituents are summarized and presented in detail for each portion of the power plant.

The estimates given in Tables 1 and 2 of Reference 1 can be utilized to assess approximate maximum use (assuming no recycling) of material resources for plants of the type studied, and for other sizes or types of plants by using appropriate scaling factors, where feasible, or other reasonable adjustment assumptions. For PWRs sufficiently similar to the model, a linear scale factor is acceptable.

It is desirable to augment the required discussion by comparing materials used at one station to total national use and national reserves as reported in standard references such as Reference 2.

### C. REGULATORY POSITION

Reference 1 forms a basis acceptable to the NRC staff for required discussions of irreversible and irretrievable commitments of material resources involved in plant construction.

Material quantity estimates should be judged by comparison with the reference plant model described in Section 2 of Reference 1, a typical PWR power plant rated at 1000 MWe net output with run-of-river cooling. Not all materials connected with the construction of a nuclear power station were included in the model. It should be especially noted that electric power transmission systems, switchyards, shipping casks, and fuel element and absorber materials were not included in the analysis as part of the reference plant model and may require separate discussion; a fuller description of

### USNRC REGULATORY GUIDES

Regulatory Guides are issued to describe and make available to the public methods acceptable to the NRC staff of implementing specific parts of the Commission's regulations, to delineate techniques used by the staff in evaluating specific problems or postulated accidents, or to provide guidance to applicants. Regulatory Guides are not substitutes for regulations, and compliance with them is not required. Methods and solutions different from those set out in the guides will be acceptable if they provide a basis for the findings requisite to the issuance or continuance of a permit or license by the Commission.

Comments and suggestions for improvements in these guides are encouraged at all times, and guides will be revised, as appropriate, to accommodate comments and to reflect new information or experience. However, comments on this guide, if received within about two months after its issuance, will be particularly useful in evaluating the need for an early revision.

Comments should be sent to the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Section.

The guides are issued in the following ten broad divisions

- |                                   |                        |
|-----------------------------------|------------------------|
| 1. Power Reactors                 | 6. Products            |
| 2. Research and Test Reactors     | 7. Transportation      |
| 3. Fuels and Materials Facilities | 8. Occupational Health |
| 4. Environmental and Siting       | 9. Antitrust Review    |
| 5. Materials and Plant Protection | 10. General            |

Copies of published guides may be obtained by written request indicating the divisions desired to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Office of Standards Development.

systems excluded or included in the reference plant is given in Section 4 of Reference 1.

Appropriate modifications should be made for differences between the reference plant model and the plant design proposed by the applicant. Such deviations from the model plant and site definitions should be treated in a way consistent with Section 3 of Reference 1, using the standardized accounting system described in Appendixes A, B, and D of the report and identifying the incremental amount of materials involved. Assumed basic constituents of composite materials should be taken from Appendix C of Reference 1.

The numerical estimates of basic constituent material resource commitments given in Table 1 for the 1000-MWe PWR model plant are acceptable to the NRC staff.

#### D. IMPLEMENTATION

The guidance presented herein on the discussion of irreversible and irretrievable commitments of material resources required by 10 CFR Part 51 may be used by any person submitting an application for a license to construct a nuclear power station. Other effective means of providing the required discussion of the commitment of material resources may also be used.

Table 1  
Numerical Estimates of Material Resource  
Commitments for 1000 MWe PWR Model Plant

Material	Total estimated quantity (metric tons, except where noted)
Aluminum	18
Antimony	Negligible
Asbestos	138
Chromium	415
Copper	726
Iron	34,662
Lead	47
Manganese	467
Molybdenum	164
Nickel	484
Silver	<1
Tin	2
Titanium	Negligible
Zinc	2
Magnesia	783
Cement	30,133
Aggregate (coarse)	90,361
Aggregate (fine)	45,855
Wood	4.8 x 10 <sup>6</sup> (board feet)

#### REFERENCES

1. R.H. Bryan and I.T. Dudley, "Estimated Quantities of Materials Contained in a 1000-MW(e) PWR Plant," ORNL-TM-4515, June 1974. Copies may be obtained from the Oak Ridge National Laboratory or from the ERDA Technical Information Center, P.O. Box E, Oak Ridge, Tennessee 37830.

2. U.S. Bureau of Mines *Mineral Yearbook*; copies may be obtained from the Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402, (published yearly).



POSTAGE AND FEES PAID  
U.S. NUCLEAR REGULATORY  
COMMISSION

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555  
OFFICIAL BUSINESS  
PENALTY FOR PRIVATE USE, \$300