



REGULATORY GUIDE

OFFICE OF STANDARDS DEVELOPMENT

REGULATORY GUIDE 1.129

MAINTENANCE, TESTING, AND REPLACEMENT OF LARGE LEAD STORAGE BATTERIES FOR NUCLEAR POWER PLANTS

A. INTRODUCTION

Criterion 18, "Inspection and Testing of Electric Power Systems," of Appendix A, "General Design Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Licensing of Production and Utilization Facilities," requires that electric power systems important to safety be designed with a capability to test periodically the operability and functional performance of the components of the systems, such as on-site power sources. Criterion XI, "test Control," of Appendix B, "Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants," to 10 CFR Part 50 requires that a test program be established to ensure that all testing required to demonstrate that structures, systems, and components will perform satisfactorily in service is identified and performed in accordance with written test procedures that incorporate the requirements and acceptance limits contained in applicable design documents. Paragraph 50.34(b)(6) of 10 CFR Part 50 requires that the final safety analysis report include, among other things, plans for conduct of normal operations, including maintenance, surveillance, and periodic testing of structures, systems, and components. This regulatory guide describes a method acceptable to the NRC staff for performing the maintenance, testing, and replacement of large lead storage batteries for all types of nuclear power plants.

B. DISCUSSION

IEEE Std 450-1975, "IEEE Recommended Practice for Maintenance, Testing and Replacement of Large Lead Storage Batteries for Generating Stations and Substations," dated May 29, 1975, was prepared by the Working Group on Batteries, Station Design Subcommittee, of the Power Generation Committee and was approved by the Institute of Electrical and Electronics Engineers Standards Board on February

27, 1975. It was subsequently approved and designated N41.15-1976 by the American National Standards Institute on January 8, 1976.

The provisions of the standard include maintenance, test schedules, testing procedures, and replacement criteria for large lead storage batteries. The standard does not include surveillance and testing of the d.c. system, even though the battery is part of that system. This standard contains requirements indicated by the verb "shall" and recommendations indicated by the verb "should."

C. REGULATORY POSITION

Conformance with the requirements and recommendations for the maintenance, testing, and replacement of large lead storage batteries for nuclear power plants that are specified by IEEE Std 450-1975, "IEEE Recommended Practice for Maintenance, Testing and Replacement of Large Lead Storage Batteries for Generating Stations and Substations," provides an adequate basis for complying with the requirements of the Commission's regulations with respect to the maintenance, testing, and replacement of large lead storage batteries, subject to the following:

1. The battery service test discussed in Subsection 4.3, "Service," and described in Subsection 5.6, "Service Test Description," should be performed with the intervals between tests in accordance with Regulatory Guide 1.32, "Criteria for Safety-Related Electric Power Systems for Nuclear Power Plants." In addition, if the system design is changed so that the previous service test is no longer a valid test of the capability of the battery to meet the changed design

Copies may be obtained from the Institute of Electrical and Electronics Engineers, United Engineering Center, 345 East 47th Street, New York, New York 10017.

USNRC REGULATORY GUIDES

Regulatory Guides are issued to describe and make available to the public methods acceptable to the NRC staff of implementing specific parts of the Commission's regulations, to delineate techniques used by the staff in evaluating specific problems or postulated accidents, or to provide guidance to applicants. Regulatory Guides are not substitutes for regulations, and compliance with them is not required. Methods and solutions different from those set out in the guides will be acceptable if they provide a basis for the findings requisite to the issuance or continuance of a permit or license by the Commission.

Comments and suggestions for improvements in these guides are encouraged at all times, and guides will be revised, as appropriate, to accommodate comments and to reflect new information or experience. However, comments on this guide, if received within about two months after its issuance, will be particularly useful in evaluating the need for an early revision.

Comments should be sent to the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Branch.

The guides are issued in the following ten broad divisions:

- | | |
|-----------------------------------|------------------------|
| 1. Power Reactors | 6. Products |
| 2. Research and Test Reactors | 7. Transportation |
| 3. Fuels and Materials Facilities | 8. Occupational Health |
| 4. Environmental and Siting | 9. Antitrust Review |
| 5. Materials and Plant Protection | 10. General |

Requests for single copies of issued guides (which may be reprinted) or for placement on an automatic distribution list for single copies of future guides in specific divisions should be made in writing to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Document Control.

requirements of the system, the user should conduct the service test for the new system design.

2. Section 8, "Standards References," of IEEE Std 450-1975 lists additional standards. The specific applicability or acceptability of these referenced standards has been or will be covered separately in other regulatory guides, where appropriate.

D. IMPLEMENTATION

The purpose of this section is to provide information to applicants regarding the NRC staff's plans for using this regulatory guide.

Except in those cases in which the applicant proposes an acceptable alternative method for complying with specified portions of the Commission's regulations, the method described herein will be used in the evaluation of submittals in connection with construction permit applications docketed after December 1, 1977, unless this guide is revised as a result of suggestions from the public or additional staff review.

If an applicant wishes to use this regulatory guide in developing submittals for applications docketed on or before December 1, 1977, the pertinent portions of the application will be evaluated on the basis of this guide.



POSTAGE AND FEES PAID
U.S. NUCLEAR REGULATORY
COMMISSION

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300