

REGULATORY GUIDE

OFFICE OF STANDARDS DEVELOPMENT

REGULATORY GUIDE 1.106

THERMAL OVERLOAD PROTECTION FOR ELECTRIC MOTORS ON MOTOR-OPERATED VALVES

A. INTRODUCTION

Criterion 1, "Quality Standards and Records," of Appendix A, "General Design Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Licensing of Production and Utilization Facilities," requires, in part, that components important to safety be designed, fabricated, erected, and tested to quality standards commensurate with the importance of the safety functions to be performed.

Criterion 4, "Environmental and Missile Design Bases," of Appendix A to 10 CFR Part 50 requires, in part, that components important to safety be designed to accommodate the effects of and be compatible with the environmental conditions associated with normal operation, maintenance, testing, and postulated accidents, including loss-of-coolant accidents.

Criterion 13, "Instrumentation and Control," of Appendix A to 10 CFR Part 50 requires that instrumentation be provided to monitor variables and systems over their anticipated ranges for normal operation, and for postulated accident conditions and that controls be provided to maintain these variables and systems within prescribed operating ranges.

Criterion XI, "Test Control," of Appendix B, "Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants," to 10 CFR Part 50 requires, in part, that a test program be established to ensure that systems and components perform satisfactorily and that the test program include operational tests during nuclear power plant operation.

This regulatory guide describes a method acceptable to the NRC staff for complying with the above criteria with regard to the application of thermal overload protection devices for electric motors on motor-operated valves controlled by motor starters to ensure that the

thermal overload protection devices will not needlessly prevent the motor from performing its safety-related function.

B. DISCUSSION

Motor-operated valves with thermal overload protection devices for the valve motors are used in safety systems and their auxiliary supporting systems. Operating experience has shown that indiscriminate application of thermal overload protection devices to these valve motors could result in needless hindrance to successful completion of safety functions.

Thermal overload relays are designed primarily to protect continuous-duty motors while they are running, rather than during starting. Use of these overload devices to protect intermittent-duty motors may therefore result in undesired actuation of the devices if the cumulative effect of heating caused by successive starts at short intervals is not taken into account in determining the overload trip setting.

It is generally very difficult for any thermally sensitive device to approximate adequately the varying thermal characteristics of an intermittent-duty motor over its full range of starting and loading conditions. This is mainly caused by the wide variations in motor heating curves for various sizes and designs and also by the difficulty in obtaining motor heating data to an acceptable accuracy.

Since the trip function in a thermal overload device is dependent on temperature, the degree of overload protection provided is affected by change in ambient temperature at the motor or starter location. This aspect becomes more complex in nuclear power plant applications where the motor to be protected is inside the containment and the overload protection devices are outside the containment. In such a situation, the

USNRC REGULATORY GUIDES

Regulatory Guides are issued to describe and make available to the public methods acceptable to the NRC staff of implementing specific parts of the Commission's regulations, to delineate techniques used by the staff in evaluating specific problems or postulated accidents, or to provide guidance to applicants. Regulatory Guides are not substitutes for regulations, and compliance with them is not required. Methods and solutions different from those set out in the guides will be acceptable if they provide a basis for the findings requisite to the issuance or continuance of a permit or license by the Commission.

Comments and suggestions for improvements in these guides are encouraged at all times, and guides will be revised, as appropriate, to accommodate comments and to reflect new information or experience. However, comments on this guide, if received within about two months after its issuance, will be particularly useful in evaluating the need for an early revision.

Comments should be sent to the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Section.

The guides are issued in the following ten broad divisions:

- | | |
|----------------------------------|-----------------------|
| 1 Power Reactors | 6 Products |
| 2 Research and Test Reactors | 7 Transportation |
| 3 Fuels and Materials Facilities | 8 Occupational Health |
| 4 Environmental and Siting | 9 Antitrust Review |
| 5 Materials and Plant Protection | 10 General |

Copies of published guides may be obtained by written request indicating the divisions desired to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Office of Standards Development.

temperature difference between the motor and the overload device could be as high as 200°F under design basis conditions. Thus the selection of an appropriate trip setpoint for such a valve motor should take into consideration operation of the valve under various temperatures for both normal and postulated accident conditions, including loss-of-coolant accidents.

The accuracy obtainable with the thermal overload relay trip generally varies from -5% to 0% of trip setpoint. Since the primary concern in the application of overload devices is to protect the motor windings against excessive heating, the above negative tolerance in trip characteristics of the protection device is considered in the safe direction for motor protection. However, this conservative design feature built into these overload devices for motor protection could interfere in the successful functioning of a safety-related system; i.e., the thermal overload device could open to remove power from a motor before the safety function has been completed or even initiated. In nuclear power plant application, the criterion for establishing an overload trip setpoint should be to complete the safety function (e.g., drive the valve to its proper position to mitigate the effects of an accident) rather than merely to protect the motor from destructive heating. In some plants, the thermal overload devices are bypassed during normal plant operation, except that they are temporarily placed in force when the valve motors are undergoing periodic testing.

C. REGULATORY POSITION

1. In order to ensure that motor-operated valves whose motors are equipped with thermal overload protection devices will perform their safety-related function, those thermal overload protection devices that

are normally in force during plant operation should be bypassed under accident conditions. The bypass initiation circuitry should conform to the criteria of IEEE 279-1971, Sections 4.1, 4.2, 4.3, 4.4, 4.5, 4.10, and 4.13 and should be periodically tested.

2. As an acceptable alternative to regulatory position C.1, the trip setpoint of the thermal overload protection devices should be established with all uncertainties resolved in favor of completing the safety-related action. With respect to those uncertainties, consideration should be given to (1) variations in the ambient temperature at the installed location of the overload protection devices and the valve motors, (2) inaccuracies in motor heating data and the overload protection device trip characteristics and the matching of these two items, and (3) setpoint drift. In order to ensure continued functional reliability and the accuracy of the trip point, the thermal overload protection device should be periodically tested.

D. IMPLEMENTATION

The purpose of this section is to provide information to applicants and licensees regarding the NRC staff's plans for using this regulatory guide.

Except in those cases in which the applicant proposes an acceptable alternative method for complying with specified portions of the Commission's regulations, the method described herein will be used in the evaluation of submittals in connection with construction permit applications docketed after July 15, 1976.

If an applicant wishes to use this regulatory guide in developing submittals for applications docketed on or before July 15, 1976, the pertinent portions of the application will be evaluated on the basis of this guide.



POSTAGE AND FEES PAID
U. S. NUCLEAR REGULATORY
COMMISSION

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300