

NRC/PG&E Public Meeting Humboldt Bay Power Plant December 5, 2013

Eplan Discussion





Emergency Plan Changes

2

- Significant source term reduction
- Analysis shows no longer reach Alert or NUE for radiological events – would like to eliminate
- Elimination of EAL requires prior approval
- Would still have security and tsunami events and all ISFSI emergencies
- Reduction in Emergency Advisor 1 hour response to the site
- Would still maintain Part 50 reporting requirements (i.e., transport of a radioactively contaminated person to an offsite medical facility)
- Submittal planned for late 2nd quarter 2014