

NRR-PMDAPEm Resource

From: Lyon, Fred
Sent: Friday, December 20, 2013 11:09 AM
To: 'Elwood, Thomas B' (TElwood@ameren.com)
Cc: Maglio, Scott A (SMaglio@ameren.com)
Subject: Question for TS 3.7.9 UHS LAR (TAC No. MF0378)

Staff has a question on the *safety status* of the setpoints for cooling tower fan speed control and cooling tower bypass valve automatic closure. You've credited manual operator actions for these functions. If it is determined that these items *are not* safety-related, then we have less review to do. If they *are* safety-related, we need the calculations for each setpoint; a statement of whether each is, or is not, a limiting safety system setting (LSSS), and a TSTF-493 statement.

Thanks, Fred

P.S. This is one that fell behind due to its priority versus Fukushima-related activities

Hearing Identifier: NRR_PMDA
Email Number: 965

Mail Envelope Properties (Fred.Lyon@nrc.gov20131220110800)

Subject: Question for TS 3.7.9 UHS LAR (TAC No. MF0378)
Sent Date: 12/20/2013 11:08:30 AM
Received Date: 12/20/2013 11:08:00 AM
From: Lyon, Fred

Created By: Fred.Lyon@nrc.gov

Recipients:

"Maglio, Scott A (SMaglio@ameren.com)" <SMaglio@ameren.com>

Tracking Status: None

"Elwood, Thomas B' (TElwood@ameren.com)" <TElwood@ameren.com>

Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	607	12/20/2013 11:08:00 AM

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received: