

## CHAPTER 6: ENGINEERED SAFETY FEATURES TABLE OF CONTENTS

<b>CHAPTER 6</b>	<b>ENGINEERED SAFETY FEATURES</b>	<b>6.0-1</b>
6.0	ENGINEERED SAFETY FEATURES	6.0-1
6.1	ENGINEERED SAFETY FEATURES MATERIALS	6.1-1
6.1.1.2	Fabrication Requirements	6.1-1
6.1.3	COMBINED LICENSE INFORMATION ITEMS	6.1-3
6.1.3.1	Procedure Review	6.1-3
6.1.3.2	Coating Program	6.1-3
6.1.4	REFERENCES	6.1-3
6.2	CONTAINMENT SYSTEMS	6.2-1
6.2.2.3	Safety Evaluation	6.2-1
6.2.5.1	Design Basis	6.2-1
6.2.6	COMBINED LICENSE INFORMATION FOR CONTAINMENT LEAK RATE TESTING	6.2-4
6.3	PASSIVE CORE COOLING SYSTEM	6.3-1
6.3.8	COMBINED LICENSE INFORMATION	6.3-1
6.3.8.1	Containment Cleanliness Program	6.3-1
6.4	HABITABILITY SYSTEMS	6.4-1
6.4.1.1	Main Control Room Design Basis	6.4-1
6.4.3	SYSTEM OPERATION	6.4-1
6.4.4	SYSTEM SAFETY EVALUATION	6.4-2
6.4.4.1	Dual Unit Analysis	6.4-2
6.4.4.2	Toxic Chemical Habitability Analysis	6.4-3
6.4.7	COMBINED LICENSE INFORMATION	6.4-4
6.5	FISSION PRODUCT REMOVAL AND CONTROL SYSTEMS	6.5-1
6.6	INSERVICE INSPECTION OF CLASS 2, 3, AND MC COMPONENTS	6.6-1
6.6.1	COMPONENTS SUBJECT TO EXAMINATION	6.6-1
6.6.2	ACCESSIBILITY	6.6-1
6.6.3	EXAMINATION TECHNIQUES AND PROCEDURES	6.6-2
6.6.3.1	Examination Methods	6.6-2
6.6.3.2	Qualification of Personnel and Examination Systems for Ultrasonic Examination	6.6-3
6.6.3.3	Relief Requests	6.6-4
6.6.4	INSPECTION INTERVALS	6.6-4
6.6.6	EVALUATION OF EXAMINATION RESULTS	6.6-4
6.6.9	COMBINED LICENSE INFORMATION ITEMS	6.6-5
6.6.9.1	Inspection Programs	6.6-5
6.6.9.2	Construction Activities	6.6-5
APPENDIX 6A	FISSION PRODUCT DISTRIBUTION IN THE AP1000 POST-DESIGN BASIS ACCIDENT CONTAINMENT ATMOSPHERE	6A-1

## CHAPTER 6 LIST OF TABLES

<u>Number</u>	<u>Title</u>
6.4-201	Main Control Room Habitability Evaluations of Onsite Toxic Chemicals Standard Onsite Toxic Chemicals

## **CHAPTER 6   ENGINEERED SAFETY FEATURES**

### **6.0   ENGINEERED SAFETY FEATURES**

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

## 6.1 ENGINEERED SAFETY FEATURES MATERIALS

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

---

### 6.1.1.2 Fabrication Requirements

---

Add the following information to the end of **DCD Subsection 6.1.1.2**:

STD COL 6.1-1 In accordance with Appendix B to 10 CFR Part 50, the quality assurance program establishes measures to provide control of special processes. One element of control is the review and acceptance of vendor procedures that pertain to the fabrication, welding, and other quality assurance methods for safety related component to determine both code and regulatory conformance. Included in this review and acceptance process are those vendor procedures necessary to provide conformance with the requirements of Regulatory Guides 1.31 and 1.44 for engineered safety features components as discussed in **DCD Section 6.1** and reactor coolant system components as discussed in **DCD Subsection 5.2.3**.

---

#### 6.1.2.1.6 Quality Assurance Features

---

STD COL 6.1-2 Replace the third paragraph under the subsection titled “Service Level I and Service Level III Coatings” within **DCD Subsection 6.1.2.1.6** with the following information.

During the design and construction phase, the coatings program associated with selection, procurement and application of safety related coatings is performed to applicable quality standards. The requirements for the coatings program are contained in certified drawings and/or standards and specifications controlling the coating processes of the designer (Westinghouse) (these design documents will be available prior to the procurement and application of the coating material by the constructor of the plant). Regulatory Guide 1.54 and ASTM D5144 (**Reference 201**) form the basis for the coating program.

During the operations phase, the coatings program is administratively controlled in accordance with the quality assurance program implemented to satisfy 10 CFR

Turkey Point Units 6 & 7  
COL Application  
Part 2 — FSAR

Part 50, Appendix B, and 10 CFR Part 52 requirements. The coatings program provides direction for the procurement, application, inspection, and monitoring of safety related coating systems. Prior to initial fuel loading, a consolidated plant coatings program will be in place to address procurement, application, and monitoring (maintenance) of those coating system(s) for the life of the plant.

Coating system monitoring requirements for the containment coating systems are based on ASTM D5163 ([Reference 202](#)), “Standard Guide for Establishing Procedures to Monitor the Performance of Coating Service Level I Coating Systems in an Operating Nuclear Power Plant,” and ASTM D7167 ([Reference 203](#)), “Standard Guide for Establishing Procedures to Monitor the Performance of Safety-Related Coating Service Level III Lining Systems in an Operating Nuclear Power Plant.” Any anomalies identified during coating inspection or monitoring are resolved in accordance with applicable quality assurance requirements.

Include a new second paragraph under the subsection titled “Service Level II Coatings” within [DCD Subsection 6.1.2.1.6](#) with the following information.

Such Service Level II coatings used inside containment are procured to the same standards as Service Level I coatings with regard to radiation tolerance and performance under design basis accident conditions as discussed below.

Replace the second sentence of the third paragraph under the subsection titled “Service Level II Coatings” within [DCD Subsection 6.1.2.1.6](#) with the following information.

Coating system application, inspection and monitoring requirements for the Service Level II coatings used inside containment will be performed in accordance with a program based on ASTM D5144 ([Reference 201](#)), “Standard Guide for Use of Protective Coating Standards in Nuclear Power Plants,” and the guidance of ASTM D5163 ([Reference 202](#)), “Standard Guide for Establishing Procedures to Monitor the Performance of Coating Service Level I Coating Systems in an Operating Nuclear Power Plant.” Any anomalies identified during coating inspection or monitoring are resolved in accordance with applicable quality requirements.

---

Turkey Point Units 6 & 7  
COL Application  
Part 2 — FSAR

6.1.3 COMBINED LICENSE INFORMATION ITEMS

6.1.3.1 Procedure Review

---

STD COL 6.1-1 This COL Item is addressed in **Subsection 6.1.1.2.**

---

6.1.3.2 Coating Program

---

STD COL 6.1-2 This COL Item is addressed in **Subsection 6.1.2.1.6.**

---

The following information supplements the information provided in **DCD Subsection 6.1.4.**

6.1.4 REFERENCES

---

201. ASTM International, *Standard Guide for Use of Protective Coating Standards in Nuclear Power Plants*, 5144-08.
  202. ASTM International, *Standard Guide for Establishing Procedures to Monitor the Performance of Coating Service Level I Coating Systems in an Operating Nuclear Power Plant*, D5163-05a.
  203. ASTM International, *Standard Guide for Establishing Procedures to monitor the Performance of Safety-Related Coating Service Level III Lining Systems in an Operating Nuclear Power Plant*, D7167-05.
-

## 6.2 CONTAINMENT SYSTEMS

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

---

### 6.2.1.1.3 Design Evaluation

---

Add the following information after the fourth paragraph of **DCD Subsection 6.2.1.1.3**.

- PTN DEP 2.0-3 The maximum safety noncoincident wet bulb temperature for Turkey Point Units 6 & 7 is increased from 86.1°F to 87.4°F; however, there are no impacts on the performance of the safety systems.

---

### 6.2.2.3 Safety Evaluation

---

Add the following information at the end of **DCD Subsection 6.2.2.3**.

- PTN DEP 2.0-3 There are no changes to the AP1000 design required to address any safety issues associated with the Turkey Point Units 6 & 7 increased maximum safety wet bulb temperature of 87.4°F. The peak containment pressure at the maximum safety wet bulb temperature of 87.4°F for the Turkey Point Units 6 & 7 site is bounded by the results of the current AP1000 analysis.

The pressure decay curve for the containment using the Turkey Point Units 6 & 7 safety wet bulb value of 87.4°F is the same as the containment response for wet bulb temperatures equal to the standard maximum safety wet bulb value.

---

### 6.2.5.1 Design Basis

---

Add the following information at the end of **DCD Subsection 6.2.5.1**, as identified in Appendix A to NuStart Technical Report AP-TR-NS01-A, Rev 2, "Containment Leak Rate Test Program Description."

STD COL 6.2-1 The Containment Leak Rate Test Program using 10 CFR Part 50, Appendix J Option B is established in accordance with NEI 94-01 ([DCD Subsection 6.2.7, Reference 30](#)), as modified and endorsed by the NRC in Regulatory Guide 1.163. [Table 13.4-201](#) provides milestones for containment leak rate testing implementation.

---

#### 6.2.5.2.2 System Operation

---

STD COL 6.2-1 Add the following information at the end of the subsection "Scheduling and Reporting of Periodic Tests" within [DCD Subsection 6.2.5.2.2](#), as identified in Appendix A to NuStart Technical Report AP-TR-NS01-A, Rev 2, "Containment Leak Rate Test Program Description."

Schedules for the performance of periodic Type A, B, and C leak rate tests are in accordance with NEI 94-01, as endorsed and modified by Regulatory Guide 1.163, and described below:

##### Type A Tests

A preoperational Type A test is conducted prior to initial fuel load. If initial fuel load is delayed longer than 36 months after completion of the preoperational Type A test, a second preoperational Type A test shall be performed prior to initial fuel load. The first periodic Type A test is performed within 48 months after the successful completion of the last preoperational Type A test. Periodic Type A tests are performed at a frequency of at least once per 48 months, until acceptable performance is established. The interval for testing begins at initial reactor operation. Each test interval begins upon completion of a Type A test and ends at the start of the next test. The extension of the Type A test interval is determined in accordance with NEI 94-01.

Type A testing is performed during a period of reactor shutdown at a frequency of at least once per 10 years based on acceptable performance history. Acceptable performance history is defined as successful completion of two consecutive Type A tests where the calculated performance leakage rate was less than  $1.0 L_a$ . A preoperational Type A test may be used as one of the two Type A tests that must be successfully completed to extend the test interval, provided that an engineering analysis is performed to document why a preoperational Type A test can be treated as a periodic test. Elapsed time between the first and last tests in a



series of consecutive satisfactory tests used to determine performance shall be at least 24 months.

#### Type B Tests (Except Containment Airlocks)

Type B tests are performed prior to initial entry into Mode 4. Subsequent periodic Type B tests are performed at a frequency of at least once per 30 months, until acceptable performance is established. The test intervals for Type B penetrations may be increased based upon completion of two consecutive periodic as-found Type B tests where results of each test are within allowable administrative limits. Elapsed time between the first and last tests in a series of consecutive satisfactory tests used to determine performance shall be 24 months or the nominal test interval (e.g., refueling cycle) for the component prior to implementing Option B of 10 CFR Part 50, Appendix J. An extended test interval for Type B tests may be increased to a specific value in a range of frequencies from greater than once per 30 months up to a maximum of once per 120 months. The extension of specific test intervals for Type B penetrations is determined in accordance with NEI 94-01.

#### Type B Tests (Containment Airlocks)

Containment airlock(s) are tested at an internal pressure of not less than  $P_{ac}$ . (Prior to a preoperational Type A test  $P_{ac} = P_a$ .) Subsequent periodic tests are performed at a frequency of at least once per 30 months. In addition, equalizing valves, door seals, and penetrations with resilient seals (i.e., shaft seals, electrical penetrations, view port seals and other similar penetrations) that are testable, are tested at a frequency of once per 30 months.

For periods of multiple containment entries where the airlock doors are routinely used for access more frequently than once every seven days (e.g., shift or daily inspection tours of the containment), door seals may be tested once per 30 days during this time period.

Airlock door seals are tested prior to a preoperational Type A test. When containment integrity is required, airlock door seals are tested within seven days after each containment access.

#### Type C Tests

Type C tests are performed prior to initial entry into Mode 4. Subsequent periodic Type C tests are performed at a frequency of at least once per 30 months, until adequate performance has been established. Test intervals for Type C valves may be increased based upon completion of two consecutive periodic as-found Type C

Turkey Point Units 6 & 7  
COL Application  
Part 2 — FSAR

tests where the result of each test is within allowable administrative limits. Elapsed time between the first and last tests in a series of consecutive passing tests used to determine performance shall be 24 months or the nominal test interval (e.g., refueling cycle) for the valve prior to implementing Option B of 10 CFR Part 50, Appendix J. Intervals for Type C testing may be increased to a specific value in a range of frequencies from 30 months up to a maximum of 60 months. Test interval extensions for Type C valves are determined in accordance with NEI 94-01.

#### Reporting

A post-outage report is prepared presenting results of the previous cycle's Type B and Type C tests, and Type A, Type B and Type C tests, if performed during that outage. The report is available on-site for NRC review. The report shows that the applicable performance criteria are met, and serves as a record that continuing performance is acceptable.

---

STD COL 6.2-1 Add the following subsection at the end of **DCD Subsection 6.2.5.2.2**, as identified in Appendix A to NuStart Technical Report AP-TR-NS01-A, Rev 2, "Containment Leak Rate Test Program Description."

#### Acceptance Criteria

Acceptance criteria for Type A, B and C Tests are established in Technical Specification 5.5.8.

---

### 6.2.6 COMBINED LICENSE INFORMATION FOR CONTAINMENT LEAK RATE TESTING

---

STD COL 6.2-1 This COL item is addressed in **Subsections 6.2.5.1** and **6.2.5.2.2**.

---

## 6.3 PASSIVE CORE COOLING SYSTEM

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

---

### 6.3.8 COMBINED LICENSE INFORMATION

#### 6.3.8.1 Containment Cleanliness Program

---

Insert the following information at the end of **DCD Subsection 6.3.8.1**:

This COL Item is addressed below.

STD COL 6.3-1

Administrative procedures implement the containment cleanliness program. Implementation of the program minimizes the amount of debris left in containment following personnel entry and exits. The program is consistent with the containment cleanliness program limits discussed in **DCD Subsection 6.3.8.1**. The program includes, as a minimum, the following:

#### Responsibilities

The program defines the organizational responsibilities for implementing the program; defines personnel and material controls; and defines the inspection and reporting requirements.

#### Implementation

##### Containment Entry/Exit

- Controls to account for the quantities and types of materials introduced into the containment.
- Limits on the types and quantities of materials, including scaffolding and tools, to ensure adequate accountability controls. This may be accomplished by the work management process. Storage of aluminum is prohibited without engineering authorization. Cardboard boxes or miscellaneous packing material is not brought into containment without approval.
- If entries are made at power, prohibited materials and limits on quantities of materials that may generate hydrogen are established.

Turkey Point Units 6 & 7  
COL Application  
Part 2 — FSAR

- Controls for loose items, such as keys and pens, which could be inadvertently left in containment.
- Methods and controls for securing any items and materials left unattended in containment.
- Administrative controls for accounting for tools, equipment and other material are established.
- Administrative controls for accounting of the permanent removal of materials previously introduced into the containment.
- Limits on the types and quantities of materials, including scaffolding and tools, that may be left unattended in containment during outages and power operation. Types of materials considered are tape, labels, plastic film, and paper and cloth products.
- Requirements and actions to be taken for unaccounted for material.
- Requirements for final containment cleanliness inspections consistent with the design bases provided in **DCD Subsection 6.3.8.1**.
- Record keeping requirements for entry/exit logs.

#### Housekeeping

Housekeeping procedures require that work areas be maintained in a clean and orderly fashion during work activities and returned to original conditions (or better) upon completion of work.

#### Sampling Program

A sampling program is implemented consistent with NEI Guidance Report 04-07, "Pressurized Water Reactor Sump Performance Evaluation Methodology" as supplemented by the NRC in the "Safety Evaluation by The Office of Nuclear Reactor Regulation Related to NRC Generic Letter 2004-02, Nuclear Energy Institute Guidance Report (Proposed Document Number NEI 04-07), 'Pressurized Water Reactor Sump Performance Evaluation Methodology.'" Latent debris sampling is implemented before startup. The sampling is conducted after containment exit cleanliness inspections to provide reasonable assurance that the plant latent debris design bases are met. Sampling frequency and scope may be

Turkey Point Units 6 & 7  
COL Application  
Part 2 — FSAR

adjusted based on sampling results. Results are evaluated post-start up and any nonconforming results will be addressed in the Corrective Action Program.

---

## 6.4 HABITABILITY SYSTEMS

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

---

Add the following information after the second paragraph of **DCD Subsection 6.4**.

PTN DEP 2.0-3

Based on system design margin of the VBS, the MCR temperature and humidity at the higher Turkey Point Units 6 & 7 maximum safety wet bulb temperature will remain at or below the desired design points during normal operation.

---

### 6.4.1.1 Main Control Room Design Basis

---

Add the following information after the last paragraph of **DCD Subsection 6.4.1.1**:

PTN DEP 2.0-3

The VBS system maintains design conditions in the MCR during all normal and accident conditions when the VBS system is operational. The VWS low capacity subsystem also serves the RNS and CVS pump room coolers. The nominal refrigeration capacity of each of the air-cooled chillers used in the VWS low capacity subsystem is 300 tons at an ambient dry bulb temperature of 115°F.

---

### 6.4.3 SYSTEM OPERATION

---

Add the following information at the end of **DCD Subsection 6.4.3**:

STD COL 6.4-2

Generic Issue 83 addresses the importance of maintaining control room habitability following an accidental release of external toxic or radioactive material or smoke and the capability of the control room operators to safely control the reactor. Procedures and training for control room habitability are written in accordance with **Section 13.5** for control room operating procedures, and **Section 13.2** for operator training. The procedures and training are verified to be consistent to the intent of Generic Issue 83.

The procedures and training address the toxic chemical events addressed in **Sections 2.2** and **6.4** consistent with the guidance provided in regulatory position C.5 of Regulatory Guide 1.78, including arrangements with Federal, State, and local agencies or other cognizant organizations for the prompt notification of the nuclear power plant when accidents involving hazardous chemicals occur within five miles of the plant. The procedures include the conduct of periodic surveys of

stationary and mobile sources of hazardous chemicals affecting the evaluations consistent with the guidance provided in regulatory position 2.5 of Regulatory Guide 1.196. The procedures include appropriate reviews of the configuration of the control room envelope and habitability systems consistent with the guidance provided in regulatory position 2.2.1 of Regulatory Guide 1.196. The procedures also include periodic assessments of the control room habitability systems' material condition, configuration controls, safety analyses, and operating and maintenance procedures consistent with the guidance provided in regulatory position 2.2.1 of Regulatory Guide 1.196.

Procedures for testing and maintenance are consistent with the design requirements of the DCD including the guidance provided in regulatory position 2.7.1 of Regulatory Guide 1.196.

---

#### 6.4.4 SYSTEM SAFETY EVALUATION

---

Insert the following subsection at the end of **DCD Subsection 6.4.4**.

##### 6.4.4.1 Dual Unit Analysis

STD SUP 6.4-1 Credible events that could put the control room operators at risk from a dose standpoint at a single AP1000 unit have been evaluated and addressed in the DCD. The dose to the control room operators at an adjacent AP1000 unit due to a radiological release from another unit is bounded by the dose to control room operators on the affected unit. While it is possible that a unit may be downwind in an unfavorable location, the dose at the downwind unit would be bounded by what has already been evaluated for a single unit AP1000. Simultaneous accidents at multiple units at a common site are not considered to be a credible event.

PTN SUP 6.4-2 The radiological dose(s) at Units 6 & 7 due to a Design Basis Accident (DBA) from Units 3 & 4 is discussed in Subsection 2.2.3.1.6.1.

---

Add the following subsection after the **Subsection 6.4.4.1**, at the end of **DCD Subsection 6.4.4**.

#### 6.4.4.2 Toxic Chemical Habitability Analysis

PTN COL 6.4-1 Regulatory Guide 1.78 establishes the Occupational Safety and Health Administration (OSHA) National Institute for Occupational Safety and Health (NIOSH) Immediately Dangerous to Life and Health (IDLH) guidelines for 30-minute exposure as the required screening criteria for airborne hazardous chemicals. Per Regulatory Guide 1.78, the NIOSH IDLH values were used to screen chemicals and to evaluate concentrations of hazardous chemicals requiring further evaluation to determine their effect on control room habitability.

Regulatory Guide 1.78 requires evaluation of control room habitability following a postulated external release of hazardous chemicals from mobile or stationary sources, onsite or offsite and indicates that the atmospheric transport of a released hazardous chemical should be calculated using a dispersion or diffusion model that permits temporal as well as spatial variations in release terms and concentrations. As described in [Subsection 2.2.3](#), the ALOHA<sup>®</sup> air dispersion model was used to evaluate the potential toxicity hazards from internal events associated with Units 1 through 5 and site-specific onsite chemical storage facilities associated with Units 6 & 7 along with external events. The ALOHA air dispersion model provides the required evaluation consistent with the requirements presented in RG 1.78 to predict the concentrations of toxic or asphyxiating chemical clouds as they disperse downwind for all facilities and sources.

For the indicated toxicity analyses in [Subsection 2.2.3](#), the maximum distance a cloud can travel before it disperses enough to fall below the IDLH or other determined toxicity limit concentration in the vapor cloud was determined using ALOHA. The IDLH is defined by NIOSH as a situation that poses a threat of exposure to airborne contaminants when that exposure is likely to cause death or immediate or delayed permanent adverse health effects, or prevent escape from such an environment. The IDLHs determined by NIOSH are established such that workers are able to escape such environments without suffering permanent health damage. As indicated in RG 1.78, the use of IDLH values as toxicity limits is appropriate since it provides an adequate margin of safety as long as control room operators use protective measures. Where an IDLH was unavailable for a toxic chemical, the time-weighted average or threshold limit value, promulgated by the OSHA or adopted by the American Conference of Governmental Hygienists, was used as the toxicity concentration level. As required in RG 1.78, asphyxiating chemicals were evaluated to determine if their release resulted in the displacement of a significant fraction of the control room air—defined by the OSHA definition of an oxygen-deficient atmosphere.



Turkey Point Units 6 & 7  
COL Application  
Part 2 — FSAR

The effects of toxic chemical releases from internal sources associated with Units 1 through 5 and site-specific onsite chemical storage facilities associated with Units 6 & 7 along with external sources are described and summarized in [Subsection 2.2.3](#) relative to the release sources. A site-specific analysis is included for those chemicals stored at Units 6 & 7 which were either not included in the standard AP1000 toxicity analysis ([Table 6.4-201](#)) or where the standard AP1000 toxicity analysis was not bounding for the identified chemical.

[Subsection 2.2.3](#) determined that there are no design basis events due to site-specific sources of hazardous materials in the vicinity of the plant that require mitigating actions to be undertaken to eliminate or lessen the likelihood and severity of potential accidents relating to toxic chemicals.

[Table 6.4-201](#) provides specific information concerning the toxicity analyses associated with the standard AP1000 chemicals for Units 6 & 7.

---

#### 6.4.7 COMBINED LICENSE INFORMATION

---

PTN COL 6.4-1 This COL Item is addressed in [Subsection 6.4.4.2](#).

---

STD COL 6.4-2 This COL Item is addressed in [Subsection 6.4.3](#).

---

Turkey Point Units 6 & 7  
COL Application  
Part 2 — FSAR

**Table 6.4-201 (Sheet 1 of 2)**  
**Main Control Room Habitability Evaluations of Onsite Toxic Chemicals<sup>(a)</sup>**  
**Standard Onsite Toxic Chemicals**

STD COL 6.4-1

Evaluated Material	Evaluated State	Evaluated Maximum Quantity	Evaluated Minimum Distance to MCR Intake	Evaluated Location	MCR Habitability Impact Evaluation
Hydrogen	Gas	500 scf	126.3 ft	Yard at turbine building	MCR
Hydrogen	Liquid	1500 gal	577 ft	Gas storage	MCR
Nitrogen	Liquid	3000 gal	577 ft	Gas Storage	MCR
Carbon Dioxide (CO <sub>2</sub> )	Liquid	6 tons	577 ft	Gas storage	MCR
Oxygen Scavenger [Hydrazine]	Liquid	1600 gal	203 ft	Turbine building	IH
pH Addition [Morpholine]	Liquid	1600 gal	203 ft	Turbine building	IH
Sulfuric Acid	Liquid	800 gal	203 ft	Turbine building	IH
Sulfuric Acid	Liquid	20,000 gal	436 ft	CWS area	IH
Sodium Hydroxide	Liquid	800 gal	203 ft	Turbine building	S
Sodium Hydroxide	Liquid	20,000 gal	436 ft	CWS area	S
Fuel Oil	Liquid	60,000 gal	197 ft	DG fuel oil storage tank, DG building, Annex building	IH
Corrosion Inhibitor [Sodium Molybdate]	Liquid	800 gal	203 ft	Turbine building	S
Corrosion Inhibitor [Sodium Molybdate]	Liquid	10,000 gal	436 ft	CWS area	S
Scale Inhibitor [Sodium Hexametaphosphate]	Liquid	800 gal	203 ft	Turbine building	S
Scale Inhibitor [Sodium Hexametaphosphate]	Liquid	10,000 gal	436 ft	CWS area	S
Biocide/Disinfectant [Sodium hypochlorite]	Liquid	800 gal	203 ft	Turbine building	S

Turkey Point Units 6 & 7  
COL Application  
Part 2 — FSAR

**Table 6.4-201 (Sheet 2 of 2)**  
**Main Control Room Habitability Evaluations of Onsite Toxic Chemicals<sup>(a)</sup>**  
**Standard Onsite Toxic Chemicals**

STD COL 6.4-1

Biocide/Disinfectant [Sodium hypochlorite]	Liquid	10,000 gal	436 ft	CWS area	S
Algaecide [Ammonium comp. Polyethoxylate]	Liquid	800 gal	203 ft	Turbine building	S
Algaecide [Ammonium comp. Polyethoxylate]	Liquid	10,000 gal	436 ft	CWS area	S

- (a) This table supplements **DCD Table 6.4-1**. Quantities are by largest evaluated container content for the evaluated location per unit. Quantities and distances are bounding evaluation values and may not be actual amounts and distances. Smaller quantities of a chemical at further distances from the MCR air intake are not shown on this table. Actual site locations are confirmed to be at or beyond the evaluated distance.

- S - Chemicals with an Impact Evaluation designation of "S" for the MCR Habitability Impact Evaluation were evaluated and screened out based on the chemical properties, distance, and quantities.
- IH - Chemicals with an Impact Evaluation designation of "IH" indicates the evaluation of this chemical considered the design detail of the main control room intake height.
- MCR - Chemicals with an Impact Evaluation designation of "MCR" indicates the evaluation of this chemical considered design details of the main control room such as volume, envelope boundaries, ventilation systems, and occupancy factor.

Turkey Point Units 6 & 7  
COL Application  
Part 2 — FSAR

6.5 FISSION PRODUCT REMOVAL AND CONTROL SYSTEMS

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

## 6.6 INSERVICE INSPECTION OF CLASS 2, 3, AND MC COMPONENTS

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

---

Add the following to **DCD Section 6.6** ahead of **Subsection 6.6.1** heading:

- STD COL 6.6-1 The initial inservice inspection program incorporates the latest edition and addenda of the ASME Boiler and Pressure Vessel Code approved in 10 CFR 50.55a(b) on the date 12 months before initial fuel load. Inservice examination of components and system pressure tests conducted during successive 120-month inspection intervals must comply with the requirements of the latest edition and addenda of the Code incorporated by reference in 10 CFR 50.55a(b) 12 months before the start of the 120-month inspection interval (or the optional ASME Code cases listed in Regulatory Guide 1.147, that are incorporated by reference in 10 CFR 50.55a(b), subject to the limitations and modifications listed in 10 CFR 50.55a(b)).
- 

### 6.6.1 COMPONENTS SUBJECT TO EXAMINATION

---

Add the following to the end of **DCD Subsection 6.6.1**:

- STD COL 6.6-1 Class 2 and 3 components are included in the equipment designation list and the line designation list contained in the inservice inspection program.
- 

### 6.6.2 ACCESSIBILITY

---

Revise the first and last sentences of the third paragraph in **DCD Subsection 6.6.2** to add supplemental information as follows:

- STD SUP 6.6-1 Considerable experience has been drawn on in designing, locating, and supporting Quality Group B and C (ASME Class 2 and 3) and Class MC pressure-retaining components to permit pre-service and inservice inspection required by Section XI of the ASME Code. Factors such as examination requirements, examination techniques, accessibility, component geometry, and material

selections are used in establishing the designs. The inspection design goals are to eliminate uninspectable components, reduce occupational radiation exposure, reduce inspection times, allow state-of-the-art inspection systems, and enhance detection and the reliability of flaw characterization. There are no Quality Group B and C components or Class MC components, which require inservice inspection during reactor operation.

---

Add the following to the end of **DCD Subsection 6.6.2**:

STD COL 6.6-2 During the construction phase of the project, anomalies and construction issues are addressed using change control procedures. Modifications reviewed following design certification adhere to the same level of review as the certified design per 10 CFR Part 50, Appendix B as implemented by the Westinghouse Quality Management System (QMS). The QMS requires that changes to approved design documents, including field changes, are subject to the same review and approval process as the original design. This explicitly requires the field change process to follow the same level of review that was required during the design process. Accessibility and inspectability are key components of the design process.

Control of accessibility for inspectability and testing during post-design certification activities is provided via procedures for design control and plant modifications.

---

### 6.6.3 EXAMINATION TECHNIQUES AND PROCEDURES

---

Add the following **Subsections 6.6.3.1, 6.6.3.2 and 6.6.3.3** to the end of **DCD Subsection 6.6.3**:

#### 6.6.3.1 Examination Methods

##### **Visual Examination**

STD COL 6.6-1 Visual examination methods VT-1, VT-2 and VT-3 are conducted in accordance with ASME Section XI, IWA-2210. In addition, VT-2 examinations meet the requirements of IWA-5240.

Where direct visual VT-1 examinations are conducted without the use of mirrors or with other viewing aids, clearance is provided in accordance with Table IWA-2210-1.

### **Surface Examination**

Magnetic particle, liquid penetrant, and eddy current examination techniques are performed in accordance with ASME Section XI, IWA-2221, IWA-2222, and IWA-2223 respectively. Direct examination access for magnetic particle (MT) and liquid penetrant (PT) examination is the same as that required for direct visual (VT-1) examination (see Visual Examination), except that additional access is provided as necessary to enable physical contact with the item in order to perform the examination. Remote MT and PT generally are not appropriate as a standard examination process; however, boroscopes and mirrors can be used at close range to improve the angle of vision.

### **Ultrasonic Examination**

Volumetric ultrasonic direct examination is performed in accordance with ASME Section XI, IWA-2232, which references mandatory Appendix I.

### **Alternative Examination Techniques**

As provided by ASME Section XI, IWA-2240, alternative examination methods, a combination of methods, or newly developed techniques may be substituted for the methods specified for a given item in this section, provided that they are demonstrated to be equivalent or superior to the specified method. This provision allows for the use of newly developed examination methods, techniques, etc., which may result in improvements in examination reliability and reductions in personnel exposure. In accordance with 10 CFR 50.55a(b)(2)(xix), IWA-2240 as written in the 1997 Addenda of ASME Section XI must be used when applying these provisions.

#### **6.6.3.2 Qualification of Personnel and Examination Systems for Ultrasonic Examination**

Personnel performing examinations shall be qualified in accordance with ASME Section XI, Appendix VII. Ultrasonic examination systems shall be qualified in accordance with industry accepted programs for implementation of ASME Section XI, Appendix VIII.

#### 6.6.3.3 Relief Requests

The specific areas where the applicable ASME Code requirements cannot be met are identified after the examinations are performed. Should relief requests be required, they will be developed through the regulatory process and submitted to the NRC for approval in accordance with 10 CFR 50.55a(a)(3) or 50.55a(g)(5). The relief requests include appropriate justifications and proposed alternative inspection methods.

---

#### 6.6.4 INSPECTION INTERVALS

---

Add the following to the end of **DCD Subsection 6.6.4**:

STD COL 6.6-1 Because 10 CFR 50.55a(g)(4) requires 120-month inspection intervals, Inspection Program B of IWB-2400 must be chosen. The inspection interval is divided into three periods. Period one comprises the first three years of the interval, period two comprises the next four years of the interval, and period three comprises the remaining three years of the inspection interval. The periods within each inspection interval may be extended by as much as one year to permit inspections to be concurrent with plant outages. The adjustment of period end dates shall not alter the rules and requirements for scheduling inspection intervals. It is intended that inservice examinations be performed during normal plant outages, such as refueling shutdown or maintenance shutdowns occurring during the inspection interval.

---

#### 6.6.6 EVALUATION OF EXAMINATION RESULTS

---

Add the following new paragraph at the end of **DCD Subsection 6.6.6**:

STD COL 6.6-1 Components containing flaws or relevant conditions and accepted for continued service in accordance with the requirements of IWC-3122.3 or IWC-3132.3 for Class 2 components, IWD-3000 for Class 3 components, IWE-3122.3 for Class MC components, or IWF-3112.2 or IWF-3122.2 for component supports, are subjected to successive period examinations in accordance with the requirements of IWC-2420, IWD-2420, IWE-2420, or IWF-2420, respectively. Examinations that



Turkey Point Units 6 & 7  
COL Application  
Part 2 — FSAR

reveal flaws or relevant conditions exceeding Table IWC-3410-1, IWD-3000, IWE-3000, or IWF-3400 acceptance standards are extended to include additional examinations in accordance with the requirements of IWC-2430, IWD-2430, or IWF-2430, respectively.

---

6.6.9 COMBINED LICENSE INFORMATION ITEMS

6.6.9.1 Inspection Programs

---

STD COL 6.6-1 This COL Item is addressed in **Section 6.6** introduction, and in **Subsections 6.6.1, 6.6.3.1, 6.6.3.2, 6.6.3.3, 6.6.4, and 6.6.6.**

---

6.6.9.2 Construction Activities

---

STD COL 6.6-2 This COL Item is addressed in **Subsection 6.6.2.**

---

**APPENDIX 6A      FISSION PRODUCT DISTRIBUTION IN  
THE AP1000 POST-DESIGN BASIS  
ACCIDENT CONTAINMENT  
ATMOSPHERE**

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.