

December 19, 2013
L-13-399

Department of Environmental Protection
Bureau of Water Quality Management
Attention: DMR Clerk
400 Waterfront Drive
Pittsburgh, PA 15222

SUBJECT:
Beaver Valley Power Station Discharge Monitoring Report (NPDES) Permit No. PA0025615

Enclosed is the November 2013 NPDES Discharge Monitoring Report (DMR) for FirstEnergy Nuclear Operating Company (FENOC), Beaver Valley Power Station, in accordance with the requirements of the Permit. Attachment 1 to this letter is supplemental monitoring data for Outfall 001 (dissolved oxygen).

A review of the data indicates no permit parameters were exceeded during the month.

Should you have any questions regarding the attached and enclosed documents, please direct them to Mrs. Beth Furdak, at 724-682-4114.

Sincerely,



Richard D. Bologna
Director, Site Operations

JE25
MR2

Beaver Valley Power Station, Unit Nos. 1 and 2
L-13-399
Page 2

Attachment(s):

1. Weekly Dissolved Oxygen Monitoring Results at Outfall 001

Enclosure(s)

- A. Discharge Monitoring Report

cc: Document Control Desk US NRC (*NOTE: No new US NRC commitments are contained in this letter.*)
US Environmental Protection Agency
Ms. Amanda Schmidt, PA DEP/Bureau of Water Quality Management

ATTACHMENT 1

Weekly Dissolved Oxygen Monitoring Results at Outfall 001

The following supplemental dissolved oxygen monitoring data for Outfall 001 is provided as agreed.

SAMPLE DATE	SAMPLE TIME	VALUE	UNITS
04-Nov-13	09:00	6	mg/L
12-Nov-13	08:30	7	mg/L
18-Nov-13	08:30	6	mg/L
25-Nov-13	08:40	7	mg/L

- Attachment 1 END -

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 1

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

001A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNITS 1&2 COOLG. TOWER BLWDN
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.3	N/A	8.4	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	N/A	N/A	mg/L	0	1 / 7	GRAB
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG		GG	GG / GG	24 HR COMP
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	31.6	37.6	MGD	N/A	N/A	N/A	N/A	-	DAILY	CONT
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Daily	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.1	0.06	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	5 AVERAGE	1/25 MAXIMUM	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02	0.0	mg/L	0	CONT	RCDR
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Continuous	RCORDR
Hydrazine	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	0	1 / 7	GRAB
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING. THE LIMIT IS 35 MG/L AS A DAILY MAX.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 2

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

002A
DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
INTAKE SCREEN BACKWASH
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.006	0.046	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	<small>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</small>		TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS			724	682-7773	12/ 19/ 2013
TYPED OR PRINTED			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Estimated flow.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 3

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

003A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
003
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.022	0.034	MGD	N/A	N/A	N/A	N/A	-	2 / 31	EST
	PERMIT REQUIREMENT	Req. Mon. MO:AVG	Req. Mon. DAILY:MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THE FLOWS FOR OUTFALLS 103, 203, 303, AND 403 ARE TO BE TOTALED AND REPORTED AS THE 003 FLOW.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 4

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

004A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT ONE COOLG TOWER OVERFLOW
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.4	N/A	7.9	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.89	3.85	MGD	N/A	N/A	N/A	N/A	-	1 / 7	MEAS
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A		0.0	0.03	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A		0.0	0.1	mg/L	0	1 / 7	GRAB
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724 682-7773		12/ 19/ 2013	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

There was no flow during the 3rd and 4th week of November.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 5

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

006A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
AUX. INTAKE SCREEN BACKWASH
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.002	0.016	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 6

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

007A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
AUX. INTAKE SYSTEM
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY-MX	Mgal/d	*****	*****	*****			Weekly	GRAB
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO-AVG	1.25 INST-MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT										
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724 682-7773		12/ 19/ 2013	
TYPED OR PRINTED		AREA Code		NUMBER	

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR
AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
MONITORING FOR FLOW, FREE AVAILABLE CHLORINE, AND TOTAL RESIDUAL CHLORINE ARE REQUIRED ONLY DURING THOSE PERIODS OF DISCHARGE FROM THE ALTERNATE FLOW PATH OF THE REACTOR PLANT RIVER WATER SYSTEM.

There was flow only during the third week of October. WMC 11-12-13

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 7

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

008A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 1 COOLING TOWER PUMPHOUSE
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 8

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

010A
DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 COOLING WATER
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.8	N/A	8.4	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	GG	GG / GG	24 HR COMP
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 INST MAX	mg/L		When Discharging	COMP 24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	5.6	9.4	MGD	N/A	N/A	N/A	N/A	-	1 / 7	MEAS
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg. Mon MO AVG	Reg. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.1	0.06	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.1	0.1	mg/L	0	1 / 7	GRAB
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS				12/ 19/ 2013
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY

724 682-7773
AREA Code NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 9

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

011A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
DIESEL GEN & TURBINE DRAINS
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.004	0.004	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY-MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 10

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

012A
DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
BLOWDOWN FROM THE HVAC UNIT
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.7	N/A	8.7	pH	0	2 / 31	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Once Per Month	GRAB
Copper, total (as Cu)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.0251	0.0401	mg/L	0	2 / 31	GRAB
01042 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	GRAB
Zinc, total (as Zn)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.1	<0.1	mg/L	0	2 / 31	GRAB
01092 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	1.5 MO AVG	1.5 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 31	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Once Per Month	ESTIMA
Solids, total dissolved	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	572	580	mg/L	0	2 / 31	GRAB
70295 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS				12/ 19/ 2013
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY

724	682-7773
AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 11

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

013A
DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR (SUBR05)
OUTFALL 013
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.4	N/A	8.0	N/A	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Cyanide, total (as CN)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.01	<0.01	N/A	0	2 / 31	24 HR COMP
00720 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Copper, total (as Cu)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.01	<0.01	N/A	0	2 / 31	24 HR COMP
01042 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Chlorobenzene	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.005	<0.005	N/A	0	2 / 31	24 HR COMP
34301 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	2 / 31	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS				12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

Sample for 11-18-13 was analyzed outside 40CFR Part136 hold times for Chlorobenzene.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 12

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

101A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
101 CHEMICAL WASTE TREATMENT
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	COMP-2
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT										
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			DAILY	CONTIN
Hydrazine	SAMPLE MEASUREMENT										
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS				12/ 19/ 2013
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. SAMPLES SHALL BE TAKEN AT THE DISCHARGE FROM THE CHEMICAL WASTE SUMP PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 13

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

102A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
102 INTAKE SCREEN HOUSE
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.8	N/A	8.0	pH	0	2 / 31	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	7	9	mg/L	0	2 / 31	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	2 / 31	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	2 / 31	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg. Mon. MO AVG	Reg. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF COLLECTED PUMP BEARING LEAKAGE PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 14

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

103A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
SLUDGE SETTLING BASIN
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM 11/ 01/ 2013		TO 11/ 30/ 2013	

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.9	N/A	8.1	pH	0	2 / 31	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	21	22	mg/L	0	2 / 31	24 HR COMP
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY-MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.022	0.034	MGD	N/A	N/A	N/A	N/A	-	2 / 31	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY-MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724 682-7773		12/ 19/ 2013	
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE BASIN PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 15

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

111A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
111 DIESEL GENERATOR BLDG
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.3	N/A	8.6	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req: Mon MO AVG	Req: Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 16

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

113A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 SEWAGE TMT PLANT
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	60 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	043 MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	1.4 MO AVG	3.3 INST MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general	SAMPLE MEASUREMENT										
74055 1 1 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	200 MO GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C	SAMPLE MEASUREMENT										
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 17

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

203A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
MAIN SEWAGE TMT PLANT
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		8 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	60 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	.023 MO AVG	Reg Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	1.4 MO AVG	3.3 INST MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general	SAMPLE MEASUREMENT										
74055 1 1 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	200 MO GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C	SAMPLE MEASUREMENT										
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL SEWAGE DISCHARGE ELIMINATION SYSTEM (NSDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 18

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

211A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
211 TURBINE BLDG
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.4	N/A	8.4	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	15	18	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO.AVG	100 DAILY.MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO.AVG	20 DAILY.MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A		-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req: Mon MO.AVG	Req: Mon DAILY.MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724 682-7773		12/ 19/ 2013
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 19

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

213A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 COOL TOWER PUMPHOUSE
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 201
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM THE PUMP HOUSE PRIOR TO MIXING WITH ANY OTHER WATER. NOTE: THE MONITORING OF THIS DISCHARGE IS NOT REQUIRED WHEN EFFLUENT FROM UNIT NO. 2 COOLING TOWER PUMP HOUSE FLOOR & EQUIPMENT DRAINS IS BEING RECYCLED TO THE UNIT NO. 2 WATER RECIRCULATION SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 20

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

301A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 AUX BOILER BLOWDOWN
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	2 / 31	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	2 / 31	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724 682-7773		12/ 19/ 2013	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF BOILER BLOWN DOWN PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 21

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

303A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 1 OIL WATER SEPARATOR
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY			MM/DD/YYYY
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724 682-7773		12/ 19/ 2013
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE OIL WATER SEPARATOR PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 22

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

313A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
313 TURBINE BLDG DRAIN
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.4	N/A	8.0	pH	1	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	8	8	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS.		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #21 PRIOR TO MIXING WITH ANY OTHER WATER.

See non-compliance form attached to the cover letter. WMC 11-12-13

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 23

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

401A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
CHEM.FEED AREA OF AUX BOILERS
Internal Outfall


ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	9.5	N/A	9.6	pH	0	2 / 31	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	8 MINIMUM	*****	Req: Mon MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	2 / 31	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO:AVG	100 DAILY:MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	2 / 31	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO:AVG	20 DAILY:MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req: Mon MO:AVG	Req: Mon DAILY:MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY


SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT CHEMICAL FEED AREA DRAINS PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 24

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

403A
DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
CONDENSATE BLOWDOWN & RIVR WAT
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO. AVG.	100 DAILY MX.	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO. AVG.	20 DAILY MX.	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT										
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon MO. AVG.	Req. Mon DAILY MX.	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT										
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	0 MO. AVG.	0 DAILY MX.	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO. AVG.	Req. Mon DAILY MX.	Mgal/d	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO. AVG.	1.25 INST. MAX.	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS				12/ 19/ 2013
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY
		AREA Code	NUMBER	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 25

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

403A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
CONDENSATE BLOWDOWN & RIVR WAT
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Hydrazine	SAMPLE MEASUREMENT										
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	0 MO AVG	0 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR
AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 26

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

413A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
BULK FUEL STORAGE DRAIN
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A		N/A		pH			
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	8 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A				mg/L			
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A			mg/L			
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT			MGD				N/A			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #24 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 27

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

501A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 1 GENRTR BLWDWN FILT BW
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724 682-7773		12/ 19/ 2013	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT INTERNAL MP 501 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 1

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

001A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNITS 1&2 COOLG. TOWER BLWDN
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.3	N/A	8.4	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	N/A	N/A	mg/L	0	1 / 7	GRAB
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG		GG	GG / GG	24 HR COMP
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	31.6	37.6	MGD	N/A	N/A	N/A	N/A	-	DAILY	CONT
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Daily	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.1	0.06	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	5 AVERAGE	1.25 MAXIMUM	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02	0.0	mg/L	0	CONT	RCRD
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Continuous	RCORDR
Hydrazine	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	0	1 / 7	GRAB
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING. THE LIMIT IS 35 MG/L AS A DAILY MAX.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 2

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

002A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
INTAKE SCREEN BACKWASH
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.006	0.046	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMATE

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Estimated flow.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 3

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

003A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
003
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.022	0.034	MGD	N/A	N/A	N/A	N/A	-	2 / 31	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg. Mon: MO AVG	Reg. Mon: DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
THE FLOWS FOR OUTFALLS 103, 203, 303, AND 403 ARE TO BE TOTALED AND REPORTED AS THE 003 FLOW.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 4

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

004A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT ONE COOLG TOWER OVERFLOW
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.4	N/A	7.9	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	7.9 MAXIMUM	pH		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.89	3.85	MGD	N/A	N/A	N/A	N/A	-	1 / 7	MEAS
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO/AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A		0.0	0.03	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A		0.0	0.1	mg/L	0	1 / 7	GRAB
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724 682-7773		12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

There was no flow during the 3rd and 4th week of November.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 5

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

006A
DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
AUX. INTAKE SCREEN BACKWASH
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.016	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon: MO AVG	Req. Mon: DAILY:MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMATE

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	<small>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</small>	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE	
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS			724	682-7773	12/ 19/ 2013	
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 6

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

007A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
AUX. INTAKE SYSTEM
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	GRAB
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT										
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724 682-7773		12/ 19/ 2013	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

MONITORING FOR FLOW, FREE AVAILABLE CHLORINE, AND TOTAL RESIDUAL CHLORINE ARE REQUIRED ONLY DURING THOSE PERIODS OF DISCHARGE FROM THE ALTERNATE FLOW PATH OF THE REACTOR PLANT RIVER WATER SYSTEM.

Computer Generated Version of EPA Form 3320-1 (rev. 01/06)

Page 1

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 7

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

008A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 1 COOLING TOWER PUMPHOUSE
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req: Mon MO AVG	Req: Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 8

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

010A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 COOLING WATER
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.8	N/A	8.4	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	GG	GG / GG	24 HR COMP
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 INST MAX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	5.6	9.4	MGD	N/A	N/A	N/A	N/A	-	1 / 7	MEAS
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.1	0.06	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.1	0.1	mg/L	0	1 / 7	GRAB
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 9

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

011A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
DIESEL GEN & TURBINE DRAINS
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.004	0.004	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG.	Req. Mon. DAILY-MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 10

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

012A
DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
BLOWDOWN FROM THE HVAC UNIT
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.7	N/A	8.7	pH	0	2 / 31	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	8 MINIMUM	*****	9 MAXIMUM	pH		Once Per Month	GRAB
Copper, total (as Cu)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.0251	0.0401	mg/L	0	2 / 31	GRAB
01042 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	GRAB
Zinc, total (as Zn)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.1	<0.1	mg/L	0	2 / 31	GRAB
01092 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	1.5 MO AVG	1.5 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 31	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Once Per Month	ESTIMA
Solids, total dissolved	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	572	580	mg/L	0	2 / 31	GRAB
70295 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS				12/ 19/ 2013
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		
		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 11

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

013A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
OUTFALL 013
External Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.4	N/A	8.0	N/A	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Cyanide, total (as CN)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.01	<0.01	N/A	0	2 / 31	24 HR COMP
00720 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Twice Per Month	COMP24
Copper, total (as Cu)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.01	<0.01	N/A	0	2 / 31	24 HR COMP
01042 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Twice Per Month	COMP24
Chlorobenzene	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.005	<0.005	N/A	0	2 / 31	24 HR COMP
34301 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	2 / 31	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724 682-7773		12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

Sample for 11-18-13 was analyzed outside 40CFR Part136 hold times for Chlorobenzene.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 12

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

101A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
101 CHEMICAL WASTE TREATMENT
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO-AVG	100 DAILY-MX	mg/L		Weekly	COMP-2
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO-AVG	20 DAILY-MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT										
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon MO-AVG	Req. Mon DAILY-MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO-AVG	Req. Mon DAILY-MX	Mgal/d	*****	*****	*****			DAILY	CONTIN
Hydrazine	SAMPLE MEASUREMENT										
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon MO-AVG	Req. Mon DAILY-MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. SAMPLES SHALL BE TAKEN AT THE DISCHARGE FROM THE CHEMICAL WASTE SUMP PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 13

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

102A
DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
102 INTAKE SCREEN HOUSE
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.8	N/A	8.0	pH	0	2 / 31	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	7	9	mg/L	0	2 / 31	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	2 / 31	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	2 / 31	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS			724 682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF COLLECTED PUMP BEARING LEAKAGE PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 14

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

103A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR (SUBR05)
SLUDGE SETTLING BASIN
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.9	N/A	8.1	pH	0	2 / 31	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	21	22	mg/L	0	2 / 31	24 HR COMP
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.022	0.034	MGD	N/A	N/A	N/A	N/A	-	2 / 31	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE BASIN PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 15

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

111A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
111 DIESEL GENERATOR BLDG
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.3	N/A	8.6	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	8 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req: Mon MO AVG	Req: Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 16

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

113A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 SEWAGE TMT PLANT
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO.AVG	60 DAILY.MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	.043 MO.AVG	Req. Mon DAILY.MX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	1.4 MO.AVG	3.3 INST.MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general	SAMPLE MEASUREMENT										
74055 1 1 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	200 MO.GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C	SAMPLE MEASUREMENT										
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	25 MO.AVG	50 DAILY.MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724 682-7773		12/ 19/ 2013	
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 17

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

203A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
MAIN SEWAGE TMT PLANT
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	60 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	023 MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	1.4 MO AVG	3.3 INST MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general	SAMPLE MEASUREMENT										
74055 1 1 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	200 MO GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C	SAMPLE MEASUREMENT										
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 18

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

211A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
211 TURBINE BLDG
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.4	N/A	8.4	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	15	18	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A		-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 19

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

213A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 COOL TOWER PUMPHOUSE
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST. MAX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM THE PUMP HOUSE PRIOR TO MIXING WITH ANY OTHER WATER. NOTE: THE MONITORING OF THIS DISCHARGE IS NOT REQUIRED WHEN EFFLUENT FROM UNIT NO. 2 COOLING TOWER PUMP HOUSE FLOOR & EQUIPMENT DRAINS IS BEING RECYCLED TO THE UNIT NO. 2 WATER RECIRCULATION SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 20

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

301A
DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 AUX BOILER BLOWDOWN
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM 11/ 01/ 2013		TO 11/ 30/ 2013	

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	2 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO.AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	2 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO.AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon MO.AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS				12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF BOILER BLOWN DOWN PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 21

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

303A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 1 OIL WATER SEPARATOR
Internal Outfall


ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS			724	682-7773	12/ 19/ 2013
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE OIL WATER SEPARATOR PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 22

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

313A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
313 TURBINE BLDG DRAIN
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.4	N/A	8.0	pH	1	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	8	8	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req: Mon MO AVG	Req: Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

See non-compliance form attached to the cover letter. WMC 11-12-13

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #21 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 23

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

401A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
CHEM.FEED AREA OF AUX BOILERS
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	9.5	N/A	9.6	pH	0	2 / 31	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	Req. Mon. MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	2 / 31	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO. AVG	100 DAILY MX.	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	2 / 31	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO. AVG	20 DAILY MX.	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO. AVG	Req. Mon. DAILY MX.	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT CHEMICAL FEED AREA DRAINS PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 24

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

403A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004

MAJOR
(SUBR05)

CONDENSATE BLOWDOWN & RIVR WAT
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT										
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT										
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	0 MO AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

Computer Generated Version of EPA Form 3320-1 (Rev. 01/06)

Page 1

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 25

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

403A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
CONDENSATE BLOWDOWN & RIVR WAT
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
FROM **MM/DD/YYYY** 11/ 01/ 2013 TO **MM/DD/YYYY** 11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Hydrazine	SAMPLE MEASUREMENT										
81313 10 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	0 MO AVG	0 DAILY-MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS			724 682-7773	12/ 19/ 2013
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 26

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

413A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
BULK FUEL STORAGE DRAIN
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD
MM/DD/YYYY MM/DD/YYYY
FROM 11/ 01/ 2013 TO 11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A		N/A		pH			
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A				mg/L			
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A			mg/L			
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT			MGD				N/A			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR
AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #24 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 27

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

501A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 1 GENRTR BLWDWN FILT BW
Internal Outfall

ATTN: RICHARD D BOLOGNA/DIR SITE OPER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2013	TO	11/ 30/ 2013

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	30 MO:AVG	100 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Richard D. Bologna, DIRECTOR OF SITE OPERATIONS		724	682-7773	12/ 19/ 2013
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY
		AREA Code	NUMBER	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT INTERNAL MP 501 PRIOR TO MIXING WITH ANY OTHER WATER.