

NRR-PMDAPEm Resource

From: Wang, Alan
Sent: Tuesday, January 07, 2014 2:39 PM
To: SEITER, JEFFERY ALAN
Cc: Burkhardt, Janet
Subject: Acceptance Review of Grand Gulf Nuclear Station License Amendment Request Regarding Technical Task Force (TSTF) -535 Revised Shut Down Margin (TAC No. MF3175)

Jeff,

The U.S. Nuclear Regulatory Commission (NRC) staff has completed the acceptance review for the amendment request dated November 8, 2013 (Agencywide Documents Access and Management System Accession No. ML13337A592) from Entergy Operations, Inc. (Entergy, the licensee), for the Grand Gulf Nuclear Station, Unit 1 (GGNS). The license amendment request (LAR) proposes to adopt Technical Specification Changes Task Force (TSTF) -535, Revision 0, "Revise Shutdown Margin Definition To Address Advanced Fuel Designs." Specifically, the proposed amendment would modify the Technical Specifications (TSs) definition of "Shutdown Margin " (SDM) to allow for shutdown moderator temperatures at or above the current 68°F. This change is needed to accommodate new Boiling Water Reactor (BWR) fuel designs which may be more reactive at shutdown temperatures above 68°F. This TS improvement is part of the Consolidated Line Item Improvement Process (CLIIP) and no modifications are proposed.

Consistent with Section 50.90 of Title 10 of the Code of Federal Regulations (10 CFR), an amendment to the license (including the technical specifications) must fully describe the changes requested and follow as far as applicable, the form prescribed for original applications. Section 10 CFR 50.34 addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

The NRC staff has reviewed your application and concludes that sufficient technical information is available to complete a detailed review. The NRC staff will make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence.

If you have any questions, please contact Alan Wang at (301) 415-1445.

Alan Wang
Project Manager
NRR/DORL/PD IV-2
(301) 415-1445

Hearing Identifier: NRR_PMDA
Email Number: 993

Mail Envelope Properties (Alan.Wang@nrc.gov20140107143800)

Subject: Acceptance Review of Grand Gulf Nuclear Station License Amendment Request
Regarding Technical Task Force (TSTF) -535 Revised Shut Down Margin (TAC No. MF3175)
Sent Date: 1/7/2014 2:38:35 PM
Received Date: 1/7/2014 2:38:00 PM
From: Wang, Alan

Created By: Alan.Wang@nrc.gov

Recipients:
"Burkhardt, Janet" <Janet.Burkhardt@nrc.gov>
Tracking Status: None
"SEITER, JEFFERY ALAN" <jseiter@entergy.com>
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	2583	1/7/2014 2:38:00 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: ZZZ