

**From:** [aceactivists@comcast.net](mailto:aceactivists@comcast.net) [mailto:[aceactivists@comcast.net](mailto:aceactivists@comcast.net)]  
**Sent:** Tuesday, January 07, 2014 5:55 PM  
**To:** DiPaolo, Eugene  
**Subject:** Re: URGENT - LIMERICK ALARM QUESTION

Gene,

**Thank you for the response. Please inform us of the determination when the investigation is completed.**

**Donna Cuthbert**

---

**From:** "Eugene DiPaolo" <[Eugene.DiPaolo@nrc.gov](mailto:Eugene.DiPaolo@nrc.gov)>  
**To:** [aceactivists@comcast.net](mailto:aceactivists@comcast.net)  
**Cc:** "Fred Bower" <[Fred.Bower@nrc.gov](mailto:Fred.Bower@nrc.gov)>

**Sent:** Monday, January 6, 2014 4:58:06 PM  
**Subject:** RE: URGENT - LIMERICK ALARM QUESTION

Mrs. Cuthbert,

Thank you for your questions concerning a Limerick emergency preparedness siren that was alarming on Friday, January 3, at approximately 11:00 p.m. During my review of the issue, I discovered that operators were aware that a siren in South Coventry had sounded and that no actual emergency existed at the time. The Exelon personnel who investigated the siren determined that the siren was malfunctioning because no signal had been sent to actuate the siren. Limerick personnel contacted appropriate state and local authorities due to the spurious actuation of the siren. As a result of the condition and offsite notifications, Exelon made a Title 10, Code of Federal Regulations (CFR) 50.72 report. As a part of the notification process, I was contacted about the incident that evening. A copy of the 10CFR 50.72 (Event Number 49691) report can be viewed through the following link: <http://www.nrc.gov/reading-rm/doc-collections/event-status/event/en.html>

The vendor who maintains the siren system is currently in the process of troubleshooting and repairing the siren. At this point in the investigation, the problem was caused by an equipment failure within the siren. The other 164 Limerick emergency preparedness sirens remain functional. Additional investigation to determine the exact cause of the failure will be performed.

Gene DiPaolo  
USNRC Senior Resident Inspector  
Limerick Generating Station  
Office: 610-327-1345  
-----

---

**From:** [aceactivists@comcast.net](mailto:aceactivists@comcast.net) [mailto:[aceactivists@comcast.net](mailto:aceactivists@comcast.net)]

**Sent:** Friday, January 03, 2014 11:38 PM

**To:** DiPaolo, Eugene

**Subject:** URGENT - LIMERICK ALARM QUESTION

Gene,

We were just contacted by North Coventry residents who are very worried.

The Limerick alarm went off just a short time ago, a little after 11:00 P.M.

It was ringing for a long period of time, in fact until a few minutes ago.

Can you PLEASE look into it and let us know why that alarm went off?

Thank you,

Donna Cuthbert