

ESBWR DCD Chapter 8

26A6642AX Revision 9 to Revision 10 Change List

| Item | Location | Description of Change |
|------|--|--|
| 1. | Cover Page | Added GE Hitachi Logo per GEH branding requirements. |
| 2. | Entire Chapter | Header changed from Rev 9 to Rev 10. |
| 3. | Figure 8.1-6 | Figure deleted in a previous revision of the DCD. A placeholder had been provided noting this deletion. Since placeholder was not needed for numbering consistency, it has also been deleted for this revision of the DCD. |
| 4. | New Subsection 8.2.1.2.2 | In response to RAI 8.1-22, added new Subsection 8.2.1.2.2 which addresses NRC Bulletin 2012-01. |
| 5. | Subsection 8.2.2.2, "Applicable Criteria," Bullet for GDC 17 | In response to RAI 8.1-22, added new last sentence: "See Subsection 8.2.1.2.2 for discussion on GDC 17 as related to Reference 8.2-3." |
| 6. | Subsection 8.2.5, New Reference 8.2-3 | In response to RAI 8.1-22, added new Reference 8.2-3: "NRC Bulletin 2012-01, 'Design Vulnerability in Electric Power System,' July 27, 2012." |