



Entergy Nuclear South  
Entergy Operations, Inc.  
17265 River Road  
Kilbuck, LA 70057-3093  
Tel: 504-739-6715  
Fax: 504-739-6698  
rmurillo@entergy.com

Robert J. Murillo  
Licensing Manager Acting  
Waterford 3

W3F1-2006-0031

June 8, 2006

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

**SUBJECT:** Deletion of Regulatory Commitment  
Waterford Steam Electric Station, Unit 3  
Docket No. 50-382  
License No. NPF-38

**REFERENCES:** 1. Entergy letter dated October 29, 2004, "Supplement to  
Amendment Request NPF-38-249, Extended Power Uprate"  
2. NRC letter dated April 15, 2005, "Waterford Steam Electric  
Station, Unit 3 – Issuance of Amendment RE: Extended Power  
Uprate (TAC NO. MC1355)

Dear Sir or Madam:

By letter dated October 29, 2004 (Reference 1) and reflected in the associated NRC safety evaluation (Reference 2) Waterford Steam Electric Station, Unit 3 (Waterford 3) made the following commitment:

"To improve the fuel oil storage capability and provide a larger operational band, Waterford 3 commits to a design change to the onsite fuel oil storage system that will accommodate fuel oil storage volume equivalent to the fuel oil needed to run each DG [diesel generator] for seven days based on calculational methods described in American National Standards Institute (ANSI) Standard N195-1976, "Fuel Oil Systems for Standby Diesel Generators." The modification will be completed by December 31, 2006. Supporting TS changes will be submitted as needed to support changes."

Based on further evaluation and discussions with the NRC staff, Waterford 3 has chosen to withdraw the above stated commitment. The current fuel oil storage system meets ANSI Standard N195-1976 with NRC approved exceptions. The commitment was made to provide Waterford 3 with operational flexibility. The deletion of the commitment does not impact the DGs ability to perform their intended safety function.

Designate as Original

Alan Wang  
3/14/2014


A001  
MLK

W3F1-2006-0031  
Page 2 of 3

This letter provides a courtesy notification of Waterford 3's withdrawal of the commitment. The deletion of the commitment was evaluated in accordance with Entergy's Commitment Management Program (EN-LI-110) which implements Nuclear Energy Institute (NEI), Guidelines for Managing Commitments, NEI 99-04 Revision 0, July 1999.

If you have any questions or require additional information, please contact Dana Millar at 601-368-5445.

Sincerely,

A handwritten signature in black ink, appearing to read "Dana J. Millar". The signature is written in a cursive style with a large initial "D".

RJM/DM/cbh

cc: Dr. Bruce S. Mallett  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011

NRC Senior Resident Inspector  
Waterford 3  
P.O. Box 822  
Killona, LA 70066-0751

U.S. Nuclear Regulatory Commission  
Attn: Mr. Mel B. Fields  
MS O-7E1  
Washington, DC 20555-0001

Wise, Carter, Child & Caraway  
Attn: J. Smith  
P.O. Box 651  
Jackson, MS 39205

Winston & Strawn  
Attn: N.S. Reynolds  
1700 K Street, NW  
Washington, DC 20006-3817

Morgan, Lewis & Bockius LLP  
ATTN: T.C. Poindexter  
1111 Pennsylvania Avenue, NW  
Washington, DC 20004

Louisiana Department of Environmental Quality  
Office of Environmental Compliance  
Surveillance Division  
P. O. Box 4312  
Baton Rouge, LA 70821-4312

American Nuclear Insurers  
Attn: Library  
95 Glastonbury Blvd.  
Suite 300  
Glastonbury, CT 06033-4443