

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

March 13, 2014

10 CFR 50.90

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Serial No.	13-271B
NL&OS/GDM	R0
Docket Nos.	50-280
	50-281
License Nos.	DPR-32
	DPR-37

**VIRGINIA ELECTRIC AND POWER COMPANY**  
**SURRY POWER STATION UNITS 1 AND 2**  
**PROPOSED LICENSE AMENDMENT REQUEST REGARDING**  
**RELOCATION OF SNUBBER SURVEILLANCE REQUIREMENTS FROM**  
**TECHNICAL SPECIFICATION 4.17 TO SNUBBER PROGRAM - CORRECTION**

By letter dated May 13, 2013 (Serial No. 13-271), Virginia Electric and Power Company (Dominion) requested license amendments, in the form of changes to the Technical Specifications (TS) to Facility Operating License Numbers DPR-32 and DPR-37, for Surry Power Station Units 1 and 2, respectively. The proposed amendments request revision of TS 4.17, "Shock Suppressors (Snubbers)," and the TS 4.17 Bases, as well as addition of TS 6.4.T, "Inservice Examination, Testing, and Service Life Monitoring Program for Snubbers." The proposed changes will revise the TS surveillance requirements for snubbers to be in accordance with ASME OM Code, Subsection ISTD, and will relocate the surveillance requirements to the Surry Units 1 and 2 Inservice Examination, Testing, and Service Life Monitoring Program Plans for Snubbers. By letter dated September 9, 2013 (Serial No. 13-271A), a subsequent revision to the license amendment request (LAR) was provided, at the request of the NRC review staff, to specifically note in TS 4.17 that the Inservice Examination, Testing, and Service Life Monitoring Program for Snubbers is defined in TS 6.4.T.

The need for an editorial correction has since been identified in the description of the Inservice Examination, Testing, and Service Life Monitoring Program for Snubbers described in proposed TS 6.4.T. The correction regards a reference to Chapter 10 Code of Federal Regulations (10 CFR). While the 10 CFR reference is correctly stated in the LAR discussion of change, it was incorrectly stated in the proposed TS insert included in Attachment 2 and the proposed typed TS page included in Attachment 3 of the LAR. Specifically, the 10 CFR reference should have been stated as "10 CFR 50.55a(b)(3)(v)", with a lower case "v", rather than "10 CFR 50.55a(b)(3)(V)", with an uppercase "V", as stated in LAR Attachments 2 and 3. The 10 CFR reference has been corrected in the attached pages, which include the revised proposed TS insert and the proposed typed TS page. One additional administrative change is also being incorporated to change the proposed typed TS page number from "TS 6.4-15a" to

A047  
NRC



cc: Region II Administrator  
U.S. Nuclear Regulatory Commission  
Marquis One Tower  
245 Peachtree Center Avenue, NE  
Suite 1200  
Atlanta, GA 30303-1257

State Health Commissioner  
Virginia Department of Health  
James Madison Building - 7th floor  
109 Governor Street, Suite 730  
Richmond, Virginia 23219

Ms. Martha C. Barillas  
NRC Project Manager - Surry  
U.S. Nuclear Regulatory Commission  
One White Flint North  
Mail Stop 08 G-9A  
11555 Rockville Pike  
Rockville, MD 20852-2738

Dr. V. Sreenivas  
NRC Project Manager - North Anna  
U.S. Nuclear Regulatory Commission  
One White Flint North  
Mail Stop 08 G-9A  
11555 Rockville Pike  
Rockville, MD 20852-2738

NRC Senior Resident Inspector  
Surry Power Station

**Attachment**

**REVISED TS 6.4.T INSERT AND PROPOSED TYPED PAGE TS 6.4-16**

**VIRGINIA ELECTRIC AND POWER COMPANY  
(DOMINION)  
SURRY POWER STATION UNITS 1 AND 2**

TS 6.4.T INSERT:

T. Inservice Examination, Testing, and Service Life Monitoring Program for Snubbers

This program conforms to the examination, testing, and service life monitoring for dynamic restraints (snubbers) in accordance with 10 CFR 50.55a inservice inspection (ISI) requirements for supports. The program shall be in accordance with the following:

- a. This program shall meet 10 CFR 50.55a(g) requirements for supports.
- b. The program shall meet the requirements of ISI of supports set forth in subsequent editions of the Code of Record and addenda of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel (BPV) Code and the ASME Code for Operation and Maintenance of Nuclear Power Plants (OM Code) that are incorporated by reference in 10 CFR 50.55a(b), subject to its limitations and modifications, and subject to Commission approval.
- c. The program shall, as allowed by 10 CFR 50.55a(b)(3)(v), meet Subsection ISTA, "General Requirements," and Subsection ISTD, "Preservice and Inservice Examination and Testing of Dynamic Restraints (Snubbers) in Light-Water Reactor Nuclear Power Plants," in lieu of Section XI of the ASME BPV Code ISI requirements for snubbers, or meet authorized alternatives pursuant to 10 CFR 50.55a(a)(3).
- d. The 120-month program updates shall be made in accordance with 10 CFR 50.55a (including 10 CFR 50.55a(b)(3)(v)) subject to the limitations and modifications listed therein.

- a. This program shall meet 10 CFR 50.55a(g) requirements for supports.
- b. The program shall meet the requirements of ISI of supports set forth in subsequent editions of the Code of Record and addenda of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel (BPV) Code and the ASME Code for Operation and Maintenance of Nuclear Power Plants (OM Code) that are incorporated by reference in 10 CFR 50.55a(b), subject to its limitations and modifications, and subject to Commission approval.
- c. The program shall, as allowed by 10 CFR 50.55a(b)(3)(v), meet Subsection ISTA, "General Requirements," and Subsection ISTD, "Preservice and Inservice Examination and Testing of Dynamic Restraints (Snubbers) in Light-Water Reactor Nuclear Power Plants," in lieu of Section XI of the ASME BPV Code ISI requirements for snubbers, or meet authorized alternatives pursuant to 10 CFR 50.55a(a)(3).
- d. The 120-month program updates shall be made in accordance with 10 CFR 50.55a (including 10 CFR 50.55a(b)(3)(v)) subject to the limitations and modifications listed therein.