

ArevaEPRDCPEm Resource

From: Hearn, Peter
Sent: Wednesday, April 02, 2014 8:18 AM
To: ArevaEPRDCPEm Resource
Subject: FW: US EPR DC DRAFT RAI LETTER 628 RAI 3773
Attachments: Draft RAI 628 RAI_7337.docx

Importance: High

AREVA determined that they did not require a clarification phone call; therefore the draft RAI 628 is final.

From: KOWALSKI David (AREVA) [<mailto:David.Kowalski@areva.com>]
Sent: Wednesday, March 12, 2014 8:36 AM
To: Hearn, Peter
Cc: 'George.Wunder@nrc.gov'; HOTTLE Nathan (AREVA); GUCWA Len (EXTERNAL AREVA); RANSOM Jim (AREVA)
Subject: FW: US EPR DC DRAFT RAI LETTER 628 RAI 3773
Importance: High

Hello Peter.

We would like to have a clarification call to discuss Draft RAI 628. We can support the following days and times during next week:

- Monday, 3/17, 1:30PM - 5:00PM.
- Tuesday, 3/18, 10:00AM - Noon.
- Thursday, 3/20, 11:00AM - Noon and 1:00PM - 3:00PM.

I anticipate the meeting will not require more than 30 minutes. Please let me know if any of these times work for you.

Thanks.

David J. Kowalski, P.E.

Senior Licensing Engineer

Regulatory Affairs

AREVA Inc.

7207 IBM Drive, Charlotte, NC 28262

Phone: 704-805-2590

Mobile: 704-293-3346

Email: David.Kowalski@areva.com

From: Wunder, George [<mailto:George.Wunder@nrc.gov>]
Sent: Thursday, February 06, 2014 1:39 PM
To: ZZ-DL-A-USEPR-DL
Cc: ArevaEPRDCPEm Resource; Bergman, Thomas; Hearn, Peter
Subject: US EPR DC DRAFT RAI LETTER 628 RAI 3773

Attached please find Draft RAI Letter No. 628 regarding your application for standard design certification of the U.S. EPR. If you have any questions or need clarification regarding this Draft RAI, please let us know as soon as possible; I will have our technical Staff available to discuss them with you.

Please also review the Draft RAI to ensure that we have not inadvertently included proprietary information. If there is any proprietary information, please let us know within the next ten days. If I do not hear from you within the next ten days, I will make the Draft RAI publicly available.

Sincerely,

George Wunder, Senior Project Manager
Office of New Reactors

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 4851

Mail Envelope Properties (E3D0DF334F617344BE38EB00C881B1B30142CFE455C5)

Subject: FW: US EPR DC DRAFT RAI LETTER 628 RAI 3773
Sent Date: 4/2/2014 8:18:11 AM
Received Date: 4/2/2014 8:18:12 AM
From: Hearn, Peter

Created By: Peter.Hearn@nrc.gov

Recipients:
"ArevaEPRDCPEm Resource" <ArevaEPRDCPEm.Resource@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	2102	4/2/2014 8:18:12 AM
Draft RAI 628 RAI_7337.docx	24797	

Options
Priority: High
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Draft Request for Additional Information 628

Issue Date: 02/06/2014

Application Title: U. S. EPR Standard Design Certification - Docket Number 52-020

Operating Company: AREVA NP Inc.

Docket No. 52-020

Review Section: 09.01.04 - Light Load Handling System (Related to Refueling)

Application Section: 9.1.4

QUESTIONS

09.01.04-44

The staff has reviewed technical report (TR) ANP-10317, "Design Requirements for the U.S. EPR Aircraft Hazard Protection Structures", Revision 3, and the associated US EPR Tier 2 FSAR Interim Revision 6 markup pages, regarding the Spent Fuel Cask Transfer Facility (SFCTF) transmitted by AREVA Letter No. NRC:13:068 dated August 1, 2013 (ADAMS Accession Nos. ML13218A006, ML13218A007, and ML13218A008 all non-public). Section 2.2, Item 16 of the technical report and associated proposed changes to Tier 2 FSAR (Interim Revision 6) Section 9.1.4 incorporated additional aircraft impact shock criteria into the design basis of the safety-related SFCTF components.

Currently, US EPR Tier 2, FSAR, Revision 5, Section 9.1.4 states, in part in Subsection 9.1.4.1 "Design Bases," that the safety-related components of the SFCTF are designed to maintain the fluid boundary to preclude the loss of significant inventory in the SFP during cask loading operations, including SSE, and the postulated drop of a fuel assembly from the maximum handling height in the cask loading pit onto a connected cask. Further, the SFCTM is designed to prevent tipping or dropping of the fuel cask during cask handling operations, including a SSE.

However, in TR ANP-10317, Revision 3, and the associated Interim Revision 6 Tier 2 FSAR markup pages for Section 9.1.4, AREVA credits, as part of its design basis, that the SFCTF design can additionally withstand the shock and vibration effects and remain capable of performing its safety functions during and following the beyond design basis large commercial aircraft impact event

The SFCTF contains safety related procured components and ITAAC are included to verify the seismic category I components can withstand design basis loads. Therefore, pursuant to 10 CFR 52.47(a)(26) and (b)(1), in addition to the proposed FSAR Tier 2, Section 9.1.4 changes, the applicant is requested to revise Tier 1 FSAR, Section 2.2.8 and ITAAC, Table 2.2.8-2, Item 3.2 to include conforming additional aircraft impact shock design criteria credited for the SFCTF design. The applicant is also requested to verify that the additional aircraft impact shock criteria for the SFCTF is consistently incorporated into all applicable subsections in the proposed markup of Tier 2 FSAR Section 9.1.4.