



Scott L. Batson
Vice President
Oconee Nuclear Station

Duke Energy
ON01VP | 7800 Rochester Hwy
Seneca, SC 29672

o: 864.873.3274
f: 864.873.4208
Scott.Batson@duke-energy.com

ONS-2014-040

March 31, 2014


Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Subject: Duke Energy LLC
Oconee Nuclear Station
Docket Nos. 50-269, 50-270 and 50-287
2013 Annual Commitment Change Report

Attached is a summary report of commitment changes for Oconee Nuclear Station completed during the 2013 calendar year. These changes were made per the guidance defined in NEI 99-04, "Guidelines for Managing NRC Commitments," and have no adverse effect on compliance with NRC rules or regulations.

Should there be any questions concerning this report please contact Judy E. Smith, Oconee Regulatory Affairs, at 864-873-4309.

Sincerely,


Scott L. Batson
Vice President
Oconee Nuclear Station

Attachment

A001
NRK

xc:

Mr. Victor McCree, Regional Administrator
U.S. Nuclear Regulatory Commission, Region II
Marquis One Tower
245 Peachtree Center Ave., NE, Suite 1200
Atlanta, GA 30303-1257

Mr. Eddy Crowe
NRC Senior Resident Inspector
Oconee Nuclear Station

Mr. Richard Guzman
Senior Project Manager
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Mail Stop O-8C2
Rockville, MD 20852

Attachment
Oconee Nuclear Station
Commitment Change Summary
Docket Nos. 50-269, 50-270 and 50-287

NUMBER	SOURCE DOCUMENT	ORIGINAL COMMITMENT	MODIFIED COMMITMENT
2013-O-002	Selected License Commitment (SLC) 16.5.6	Reactor Coolant System (RCS) unidentified leakage shall be limited to: a. < 0.1 gpm above previous daily reading b. < 0.25 gpm above baseline value APPLICABILITY: Applicable on Units 2 and 3 only until mitigation of the Pressurizer Nozzle butt welds is complete. MODES 1, 2, 3, and 4.	Delete Oconee Selected License Commitment (SLC) 16.5.6 because the mitigation of the Pressurizer Nozzle butt welds is complete.