



Steven D. Capps
Vice President
McGuire Nuclear Station

Duke Energy
MG01VP | 12700 Hagers Ferry Road
Huntersville, NC 28078

o: 980.875.4805
f: 980.875.4809
Steven.Capps@duke-energy.com

March 19, 2014
Serial Number: MNS-14-030

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555-0001

Subject: Duke Energy Carolinas, LLC
McGuire Nuclear Station, Units 1 and 2
Docket Nos. 50-369, 50-370
Annual Commitment Change Report

Attached is the summary of a commitment change completed at McGuire Nuclear Station during the 2013 calendar year. This change was made per the guidance defined in NEI 99-04, "Guidelines for Managing NRC Commitments" and has no adverse effect on compliance with NRC rules or regulations.

Questions regarding this submittal should be directed to Kay Crane, McGuire Regulatory Affairs at (980) 875-4306.



Steven D. Capps

Attachment

ADD
HRR

U. S. Nuclear Regulatory Commission
March 19, 2014
Page 2

xc:

Mr. Victor McCree
U. S. Nuclear Regulatory Commission, Region II
Marquis One Tower
245 Peachtree Center Ave., NE, Suite 1200
Atlanta, GA 30303

Mr. Ed Miller
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, DC 20555-0001

Mr. John Zieler
NRC Senior Resident Inspector
McGuire Nuclear Station

McGuire Nuclear Station
Commitment Change Summary Report
Docket Nos. 369 and 370

| NUMBER | SOURCE DOCUMENT | ORIGINAL COMMITMENT | MODIFIED COMMITMENT |
|------------|--|--|---|
| 2013-M-001 | Response to Notice of Violation by letter dated November 6, 1997 | Monitor the ice condenser floor cooling parameters on a weekly basis to establish baseline performance criteria. | Ice condenser floor cooling parameter surveillances are performed at monthly intervals. |