



MAR 26 2014

L-2014-069  
10 CFR 50.36

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555-0001

Re: Turkey Point Unit 3  
Docket No. 50-250  
Core Operating Limits Report

In accordance with Technical Specification 6.9.1.7, the attached Core Operating Limits Report (COLR) is provided for Turkey Point Unit 3. The COLR is applicable for Unit 3 Cycle 27.

Should there be any questions, please contact Robert Tomonto, Licensing Manager, at 305-246-7327.

Very truly yours,

Michael Kiley  
Site Vice President  
Turkey Point Nuclear Plant

Attachment

cc: Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

A001  
LIRR

**TURKEY POINT UNIT 3 CYCLE 27 COLR**

**Turkey Point Unit 3 Cycle 27  
Core Operating Limits Report (COLR)**

## TURKEY POINT UNIT 3 CYCLE 27 COLR

### 1.0 INTRODUCTION

This Core Operating Limits Report for Turkey Point Unit 3 Cycle 27 has been prepared in accordance with the requirements of Technical Specification 6.9.1.7.

The Technical Specifications (TS) affected by this report are listed below with the section and page for each one of the TS addressed in this COLR document.

<u>Section Technical Specification</u>			<u>Page</u>
2.1	2.1.1	Reactor Core Safety Limits	14A-A3
2.2	2.2.1	Reactor Trip System Instrumentation Setpoints, Table 2.2-1, Notes 1 & 3	14A-A3-14A-A4
2.3	3.1.1.1	Shutdown Margin Limit for MODES 1, 2, 3, 4	14A-A4
2.4	3.1.1.2	Shutdown Margin Limit for MODE 5	14A-A4
2.5	3.1.1.3	Moderator Temperature Coefficient	14A-A5
2.6	4.1.1.3	MTC Surveillance at 300 ppm	14A-A5
2.7	3.1.3.2	Analog Rod Position Indication System	14A-A5
2.8	3.1.3.6	Control Rod Insertion Limits	14A-A5
2.9	3.2.1	Axial Flux Difference	14A-A5
2.10	3.2.2	Heat Flux Hot Channel Factor $F_Q(Z)$	14A-A5
2.11	3.2.3	Nuclear Enthalpy Rise Hot Channel Factor	14A-A6
2.12	3.2.5	DNB Parameters	14A-A6
<u>Figure</u>	<u>Description</u>		
A1	Reactor Core Safety Limit – Three Loops in Operation		14A-A7
A2	Required Shutdown Margin vs Reactor Coolant Boron Concentration		14A-A8
A3	Turkey Point Unit 3 Cycle 27 Rod Insertion Limits vs Thermal Power		14A-A9
A4	Axial Flux Difference as a Function of Rated Thermal Power		14A-A10

## TURKEY POINT UNIT 3 CYCLE 27 COLR

### 2.0 OPERATING LIMITS

The cycle-specific parameter limits for the specifications listed in the Introduction are presented below and listed sequentially by Technical Specification (TS). These limits have been developed using the NRC-approved methodologies specified in TS 6.9.1.7.

#### 2.1 Reactor Core Safety Limits – Three Loops in Operation (TS 2.1.1)

- Figure A1(page 14A-A7) In Modes 1 and 2, the combination of Thermal Power, reactor coolant system highest loop average temperature and pressurizer pressure shall not exceed the limits in Figure A1.

#### 2.2 Reactor Trip System Instrumentation Setpoints (TS 2.2.1)

NOTE 1 on TS Table 2.2-1 Overtemperature  $\Delta T$

- $\tau_1 = 0s, \tau_2 = 0s$  Lead/Lag compensator on measured  $\Delta T$
- $\tau_3 = 2s$  Lag compensator on measured  $\Delta T$
- $K_1 = 1.31$
- $K_2 = 0.023/^\circ F$
- $\tau_4 = 25s, \tau_5 = 3s$  Time constants utilized in the lead-lag compensator for  $T_{avg}$
- $\tau_6 = 2s$  Lag compensator on measured  $T_{avg}$
- $T' \leq 583.0^\circ F$  Indicated Loop  $T_{avg}$  at RATED THERMAL POWER
- $K_3 = 0.00116/psi$
- $P' \geq 2235 \text{ psig}$  Nominal RCS operating pressure
- $f_1(\Delta I) = 0$  for  $q_t - q_b$  between  $-18\%$  and  $+7\%$ .

For each percent that the magnitude of  $q_t - q_b$  exceeds  $-18\%$ , the  $\Delta T$  Trip Setpoint shall be automatically reduced by 3.51% of its value at RATED THERMAL POWER; and

For each percent that the magnitude of  $q_t - q_b$  exceeds  $+7\%$ , the  $\Delta T$  Trip Setpoint shall be automatically reduced by 2.37% of its value at RATED THERMAL POWER.

Where  $q_t$  and  $q_b$  are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and  $q_t + q_b$  is total THERMAL POWER in percent of RATED THERMAL POWER.

## TURKEY POINT UNIT 3 CYCLE 27 COLR

### NOTE 2 on TS Table 2.2-1 Overtemperature $\Delta T$ (Not affected by COLR, included for completeness)

The Overtemperature  $\Delta T$  function Allowable Value shall not exceed the nominal trip setpoint by more than 0.5%  $\Delta T$  span for the  $\Delta T$  channel, 0.2%  $\Delta T$  span for the Pressurizer Pressure channel, and 0.4%  $\Delta T$  span for the  $f(\Delta I)$  channel. No separate Allowable Value is provided for  $T_{avg}$  because this function is part of the  $\Delta T$  value.

### NOTE 3 on TS Table 2.2-1 Overpower $\Delta T$

- $K_4 = 1.10$
- $K_5 \geq 0.0/^\circ\text{F}$  For increasing average temperature
- $K_5 = 0.0$  For decreasing average temperature
- $\tau_7 \geq 0 \text{ s}$  Time constants utilized in the lead-lag compensator for  $T_{avg}$
- $K_6 = 0.0016/^\circ\text{F}$  For  $T > T''$
- $K_6 = 0.0$  For  $T \leq T''$
- $T'' \leq 583.0^\circ\text{F}$  Indicated Loop  $T_{avg}$  at RATED THERMAL POWER
- $f_2(\Delta I) = 0$  For all  $\Delta I$

### NOTE 4 on TS Table 2.2-1 Overpower $\Delta T$ (Not affected by COLR, included for completeness)

The Overpower  $\Delta T$  function Allowable Value shall not exceed the nominal trip setpoint by more than 0.5%  $\Delta T$  span for the  $\Delta T$  channel. No separate Allowable Value is provided for  $T_{avg}$  because this function is part of the  $\Delta T$  value.

## 2.3 Shutdown Margin Limit for MODES 1, 2, 3 and 4 (TS 3.1.1.1)

- Figure A2 (page 14A-A8)

## 2.4 Shutdown Margin Limit for MODE 5 (TS 3.1.1.2)

- $\geq 1.77\% \Delta k/k$

## TURKEY POINT UNIT 3 CYCLE 27 COLR

### 2.5 Moderator Temperature Coefficient (MTC) (TS 3.1.1.3)

- $\leq + 5.0 \times 10^{-5} \Delta k/k/^{\circ}F$  BOL, HZP, ARO and from HZP to 70% Rated Thermal Power (RTP)
- From 70% RTP to 100% RTP the MTC decreasing linearly from  $\leq + 5.0 \times 10^{-5} \Delta k/k/^{\circ}F$  to  $\leq 0.0 \times 10^{-5} \Delta k/k/^{\circ}F$
- Less negative than  $- 41.0 \times 10^{-5} \Delta k/k/^{\circ}F$  EOL, RTP, ARO

### 2.6 MTC Surveillance at 300 ppm (TS 4.1.1.3)

- Less negative than  $- 35.0 \times 10^{-5} \Delta k/k/^{\circ}F$  Within 7 EFPD of reaching equilibrium boron concentration of 300 ppm.

### 2.7 Analog Rod Position Indication System (TS 3.1.3.2)

- Figure A3 (page 14A-A9) The All Rods Out (ARO) position for all shutdown Banks and Control Banks is defined to be 230 steps withdrawn.

### 2.8 Control Rod Insertion Limits (TS 3.1.3.6)

- Figure A3 (page 14A-A9) The control rod banks shall be limited in physical insertion as specified in Figure A3 for ARO = 230 steps withdrawn.

### 2.9 Axial Flux Difference (TS 3.2.1)

- Figure A4 (page 14A-A10)

### 2.10 Heat Flux Hot Channel Factor $F_Q(Z)$ (TS 3.2.2)

- $[F_Q]^L = 2.30$
- $K(z) = 1.0$  For  $0' \leq z \leq 12'$  where  $z$  is core height in ft

## **TURKEY POINT UNIT 3 CYCLE 27 COLR**


### **2.11 Nuclear Enthalpy Rise Hot Channel Factor (TS 3.2.3)**

- $F_{\Delta H}^{RTP} = 1.600$      $PF_{\Delta H} = 0.3$

### **2.12 DNB Parameters (TS 3.2.5)**

- $RCS\ T_{avg} \leq 585.0\ ^\circ F$
- Pressurizer Pressure  $\geq 2204$  psig

### TURKEY POINT UNIT 3 CYCLE 27 COLR




**FIGURE A1 Reactor Core Safety Limit – Three Loops in Operation**



TURKEY POINT UNIT 3 CYCLE 27 COLR

FIGURE A2


Required Shutdown Margin vs Reactor Coolant  
Boron Concentration



# TURKEY POINT UNIT 3 CYCLE 27 COLR

FIGURE A3

**Turkey Point Unit 3 Cycle 27 Rod Insertion Limits vs Thermal Power**  
**ARO = 230 Steps Withdrawn, Overlap = 102 Steps**



**TURKEY POINT UNIT 3 CYCLE 27 COLR**

**FIGURE A4**

**Axial Flux Difference as a Function of Rated Thermal Power  
Turkey Point Unit 3 Cycle 27**

