

Kahler, Carolyn

From: Kahler, Carolyn
Sent: Wednesday, April 23, 2014 9:37 AM
To: Johnson, Don
Cc: Anderson, Joseph
Subject: RE: Response from "Submit a Question about Emergency Preparedness"

Don:

Thank you for your recent submission of EPFAQ No. 2014-003 regarding EALs PD-AU1 and PD-AA1.

At this time, your comment has been accepted for review by appropriate NRC staff. You will be notified when EPFAQ No. 2014-003 has been added to www.regulations.gov for a 30-day public comment period. At that time, the ADAMS accession number and Federal Register Notice docket number will be provided for your reference.

To track the status of your submitted question, please visit the website <http://www.nrc.gov/about-nrc/emerg-preparedness/faq/faq-contactus.html#status>. If you have any questions regarding submitting an EP FAQ, please feel free to contact me at carolyn.kahler@nrc.gov or 301-287-3722.

Sincerely,

Carolyn J. Kahler

EP Specialist
NSIR/DPR/ORLOB
U.S. Nuclear Regulatory Commission
Location: 3WFN- 9A31
Phone: 301-287-3722
Email: Carolyn.Kahler@nrc.gov

-----Original Message-----

From: don.johnson@nrc.gov [<mailto:don.johnson@nrc.gov>]
Sent: Tuesday, April 22, 2014 1:18 PM
To: EPFAQ Resource
Subject: Response from "Submit a Question about Emergency Preparedness"

Below is the result of your feedback form. It was submitted by

(don.johnson@nrc.gov) on Tuesday, April 22, 2014 at 13:17:30

through the IP 209.170.118.134

using the form at <http://www.nrc.gov/about-nrc/emerg-preparedness/faq/faq-contactus.html>

and resulted in this email to epfaq.resource@nrc.gov

relevant-guidance: NEI 99-01

revision-number: Revision 6

applicable-sections: Permanently Defueled (PD) EALs

comments: Is it appropriate to change EALs PD-AU1 and PD-AA1 as follows?

PD-AU1: Revise the Initiating Condition (IC) to "An uncontrolled release of gaseous or liquid radioactivity for 60-minutes or longer." Also, revise EAL #1 to "Reading on any effluent radiation monitor that is greater than the reading shown for 60-minutes or longer."

PD-AA1: Revise the IC to "An uncontrolled release of gaseous or liquid radioactivity resulting in detectable levels at the site boundary." Also, remove EALs #2 and #4, and revise EAL #3 to allow for licensees to consider alternatives to the guidance provided in NEI 99-01, Revision 6.

proposed-solution:

originator: Don Johnson

organization: USNRC

phone: 301.287.9230
