

David H. Jones  
Technical Compliance VP  
Vogtle 3&4

Southern Nuclear  
Operating Company, Inc.  
7825 River Road  
Waynesboro, GA 30830

Tel 706.826.4336  
Fax 205.980.5443  
dahjones@southernco.com



April 23, 2014

Docket No.: 52-026

ND-14-0459  
10 CFR 52.99(c)(1)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555-0001

Southern Nuclear Operating Company  
Vogtle Electric Generating Plant Unit 4  
Completion of ITAAC 2.4.02.03.i [Index Number 500]

Ladies and Gentlemen:

In accordance with 10 CFR 52.99(c)(1), this letter is to notify the Nuclear Regulatory Commission (NRC) of the completion of Vogtle Electric Generating Plant (VEGP) Unit 4 Inspection, Test, Analysis and Acceptance Criteria (ITAAC) Item 2.4.02.03.i [Index Number 500], Independence and Isolation of the Turbine Overspeed Protection Systems. The closure process for this ITAAC is based on the guidance described in NEI 08-01, Industry Guideline for the ITAAC Closure Process Under 10 CFR Part 52, which was endorsed by the NRC in Regulatory Guide 1.215.

This letter contains no new NRC regulatory commitments. Southern Nuclear Operating Company (SNC) requests NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99.

If there are any questions, please contact Paulo Albuquerque at 706-826-5531.

Respectfully submitted,

A handwritten signature in black ink, appearing to read "D.H. Jones", written over a horizontal line.

David H. Jones

Technical Compliance Vice President

Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 4  
Completion of ITAAC 2.4.02.03.i [Index Number 500]

cc:

Southern Nuclear Operating Company/ Georgia Power Company

Mr. J. A. Miller

Mr. B. L. Ivey

Mr. M. D. Rauckhorst

Mr. D. H. Jones

Mr. B. H. Whitley

Mr. M. J. Yox

Mr. P. C. Albuquerque

Mr. S. Thomason

Mr. B. W. Waites

Document Services RTYPE: VND.LI.L00

File AR.01.02.06

Nuclear Regulatory Commission

Mr. V. M. McCree

Mr. M. Delligatti

Mr. L. Burkhardt

Mr. D. H. Jaffe

Mr. R. G. Joshi

Mr. B. C. Anderson

Ms. D. L. McGovern

Mr. M. E. Ernestes

Mr. G. Khouri

Mr. J. D. Fuller

Mr. C. B. Abbott

Mr. C. Huffman

Georgia Power Company

Mr. D. J. Clem

Ms. J. L. Hall

State of Georgia

Mr. J. H. Turner

Oglethorpe Power Corporation

Mr. M. W. Price

Mr. K. T. Haynes

Municipal Electric Authority of Georgia

Mr. J. E. Fuller

Mr. S. M. Jackson

Dalton Utilities

Mr. D. Cope

CB&I

Mr. J. Simmons  
Ms. K. Stoner  
Mr. C. A. Castell

Westinghouse Electric Company, LLC

Ms. J. Falascino  
Mr. S. W. Gray  
Mr. F. G. Gill  
Mr. P. A. Russ  
Mr. L. E. Erin  
Mr. G. F. Couture

Other

Mr. S. Blanton, Balch Bingham

**Southern Nuclear Operating Company**

**ND-14-0459**

**Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 4**

**Completion of ITAAC 2.4.02.03.i [Index Number 500]**

## **ITAAC Statement**

### **Design Commitment**

The trip signals from the two turbine electrical overspeed protection trip systems are isolated from, and independent of, each other.

### **Inspection/Test/Analysis**

The system design will be reviewed.

### **Acceptance Criteria**

The system design review shows that the trip signals of the two electrical overspeed protection trip systems are isolated from, and independent of, each other.

## **ITAAC Determination Basis**

Multiple ITAAC are performed to demonstrate that the trip signals from the two turbine electrical overspeed protection trip systems are isolated from, and independent of, each other. The subject ITAAC requires a system design review be performed to show that the trip signals from the two turbine electrical overspeed protection trip systems are isolated from, and independent of, each other.

The system design for the Turbine Control and Protection System (TCPS) was reviewed in accordance with the site procedure for formal design reviews. The AP1000 Plant Control System/Data Display & Processing System Final Design Review Report (Reference 1) shows that each trip is initiated and maintained electrically in separate systems, is located physically in separate cabinets, and is in use of different hardware and software/firmware. These system design attributes eliminate common cause failures (CCFs) from rendering the trip functions inoperable. The system design review shows that the trip signals of the two electrical overspeed protection trip systems are isolated from, and independent of, each other.

## **ITAAC Finding Review**

In accordance with plant procedures for ITAAC completion, SNC performed a review of all ITAAC findings pertaining to the subject ITAAC and associated corrective actions. This review found that there are no relevant ITAAC findings associated with this ITAAC. The ITAAC finding review is documented in the ITAAC Completion Package for ITAAC 2.4.02.03.i (Reference 2) and is available for NRC inspection.

## **ITAAC Completion Statement**

Based on the above information, SNC hereby notifies the NRC that ITAAC 2.4.02.03.i [Index Number 500] was performed for VEGP Unit 4, and that the prescribed acceptance criteria are met.

Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

**References (available for NRC inspection)**

1. APP-PLS-GGR-007, Revision 2, AP1000 Plant Control System/Data Display & Processing System (FDR-09-29) Final Design Review Report
2. SVP\_SV0\_002425, Attachment 2, ITAAC 2.4.02.03.i Unit 4 Completion Package