

Record of Review
Dispositions to Nine Mile Point Internal Events PRA Facts and Observations (F&Os)

FINDING/SUGGESTION (F&O) ID OR SUPPORTING REQUIREMENT (SR)	ACCEPTABLE TO STAFF VIA		
	Review of Plant Disposition (A/B/C)	RAI Response	
		Not Discussed in SE	Discussed in SE
DA-E1-01			See PRA RAI 14.
SY-A11-01	C		
SY-B10-01	A		
IE-D3-01	C		
SY-B13-01	A		
IF-D5a-01	C		
DA-C8-01	B		
MU-C1-01	C		
DA-D4-01	B		
SY-B11-01	A		
IF-C8-01	A		
IF-C3-01	A		
IF-E5a-01	A		
HR-E3-01	B		
LE-F1a-01	C		
QU-C1-01	B		
QU-D1a-01			See PRA RAI 16.
DA-C14-01		See PRA RAI 15. Acceptable to the NRC staff because the licensee stated that non-recoverable failures of an EDG are built into the non-recovery failure probability provided in Section 4.2 of Revision 1 of the Initiating Event Notebook. The fire PRA does not credit this non-recovery probability utilized in the internal events PRA. The licensee performed a Bayesian analysis to develop a plant-specific LOSP EDG failure rate based on industry and plant-specific information.	
AS-A8-02	C		
MU-B4-01	C		
QU-D5b-01			See PRA RAI 16.

Record of Review
Dispositions to Nine Mile Point Internal Events PRA Facts and Observations (F&Os)

FINDING/SUGGESTION (F&O) ID OR SUPPORTING REQUIREMENT (SR)	ACCEPTABLE TO STAFF VIA		
	Review of Plant Disposition (A/B/C)	RAI Response	
		Not Discussed in SE	Discussed in SE
HR-G6-01	B		
HR-G7-01	B		
QU-D4-01	A		
QU-E4-01			See PRA RAI 16.
QU-F6-01	B		

- A: The NRC staff finds that the disposition of the F&O as described by the licensee in the LAR provides confidence that the issues raised by the F&O have been addressed and, if needed, the PRA has been modified, and therefore the resolution of the F&O is acceptable for this application.
- B: The NRC staff finds that the disposition of the F&O as described by the licensee in the LAR and further clarified during the audit provides confidence that the issues raised by the F&O have been addressed and, if needed, the PRA has been modified, and therefore the resolution of the F&O is acceptable for this application.
- C: The NRC staff finds that the resolution of the F&O, as described by the licensee in the LAR, would have a negligible effect on the evaluations relied upon to support fire risk evaluations and has no impact on the conclusions of the risk assessment and therefore the resolution of the F&O is acceptable for this application. Examples of such F&Os may be suggestions, as well as those F&Os that don't affect the fire PRA. Documentation issues may fall into this category as well.