

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7911070451 DOC. DATE: 79/10/15 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light 05000261
 AUTH. NAME AUTHOR AFFILIATION
 STARKEY, R.B. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Notifies that support within safety injection sys does not meet seismic requirements of IE Bulletin 79-14. Test showed support would marginally withstand design basis earthquake.

DISTRIBUTION CODE: M007S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: LER (Backfit)

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTR ENCL |
|-----------|---------------------------|--------------------|---------------------------|--------------------|
| INTERNAL: | 01 <u>REG FILE</u> | 1 | 02 NRC PDR | 1 |
| | 04 I&E | 2 | MPA | 1 |
| | NSIC | 1 | S HANAUER | 1 |
| EXTERNAL: | 03 LPDR | 1 | | |

TOTAL NUMBER OF COPIES REQUIRED: LTR 8 ENCL

Ad/I
 2 CCP

USNRC REGION II
ATLANTA, GEORGIA

CPRI

19 OCT 15 P3:14

Carolina Power & Light Company

H. B. ROBINSON STEAM ELECTRIC PLANT
Post Office Box 790
Hartsville, South Carolina 29550

October 15, 1979

L. P. O'REILLY
C. M. UPRIGHT
P. D. CHENDEMI
W. B. KENNA
J. LONG
E. MURPHY
T. SUTHERLAND
E. M. CLARK
*Copy to
Robinson
Killey*

Robinson File No: 2-0-4-a-5

SERIAL: RSEP/79-1130

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

As required by Technical Specification 6.9.2.a.2, the following event is reported:

On October 10, 1979 while performing seismic support inspections required by IE Bulletin 79-14, a support within the Safety Injection (SI) System was identified as a "deviation" as defined in the response to the Bulletin dated September 5, 1979. The initial engineering evaluation indicated that the support would marginally withstand a Design Basis Earthquake (DBE). At that time, the restraint was modified to ensure that a computer analysis (already in progress) would verify no loss of operability.

On October 15, 1979, review of the results of the reanalysis and the function of operability of the containment spray system was completed. The results of the reanalysis, as a consequence of the modification, are satisfactory. The results of the reanalysis, as a consequence of the modification, are satisfactory. The results of the reanalysis, as a consequence of the modification, are satisfactory. T. J. McHenry of the NRC, Atlanta Office, on October 15, 1979.

Very truly yours,

R. B. Starkey, Jr.
R. B. Starkey, Jr., Manager
H. B. Robinson SEG Plant

M007
S/10

7911070451