

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8707170165 DOC. DATE: 87/06/17 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH. NAME AUTHOR AFFILIATION
 ROBERTS, E. W. EG&G Idaho, Inc. (subs. of EG&G, Inc.)
 ROBERTS, E. W. Idaho National Engineering Laboratory
 RECIP. NAME RECIPIENT AFFILIATION
 CARRINGTON, M. Office of Nuclear Reactor Regulation, Director (Post 870411)

SUBJECT: Forwards final EGG-NTA-7647, "Conformance to Generic Ltr
 83-28, Item 2.2.2-Vendor Interface Programs for All Other
 Safety-Related Components, Robinson-2," informal rept. Plant
 conforms to generic ltr on item.

DISTRIBUTION CODE: H001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+16
 TITLE: File Location Distribution: NRR Docket 50

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| INTERNAL: | REG FILE 01 | 1 1 | | |
| EXTERNAL: | LPDR | 1 1 | NRC PDR | 1 1 |

Add: K. Eccheston Ltrs 1 Encl 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 4 ENCL 4



Idaho National Engineering Laboratory

June 17, 1987

50-261

Mr. M. Carrington, Project Manager
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

TRANSMITTAL OF FINAL REPORT, "CONFORMANCE TO GENERIC LETTER 83-28,
ITEM 2.2.2--VENDOR INTERFACE PROGRAMS FOR ALL OTHER SAFETY-RELATED
COMPONENTS: ROBINSON-2," EGG-NTA-7647, JUNE 1987 (FIN D6001) - EWR-151-87

Ref: NRC Form 189, "Evaluation of Conformance to Generic Letter 83-28 For
ORs (Project 2)" (D6001)

Dear Mr. Carrington:

Transmitted herewith is the above subject report.

The report documents INEL's evaluation of the licensee actions in response to NRC Generic Letter 83-28, Item 2.2.2--Vendor Interface Programs for All Other Safety-Related Components. Based on the licensee submittals, we conclude that the plant does not conform to the generic letter on this item. The licensee should initiate formal vendor interface programs with the vendors of major safety-related equipment.

Very truly yours,

E. W. Roberts, Manager
NRC Headquarters Support

ACU:gp

Enclosure:
As Stated

cc: G. L. Jones, DOE-ID
D. Lasher, SICB (2)
J. O. Zane, EG&G Idaho, Inc. (w/o Encl.)

8707170165 870617
PDR ADOCK 05000261
P PDR

Mr Encl
Hool Add: K. Eccleston