

Letter to N. C. Moseley from Carolina Power and Light Company dated December 16, 1974.

DISTRIBUTION:

H. D. Thornburg, RO

RO:HQS (5)

Regulatory Standards

→ DR Central Files

Directorate of Licensing (13)

J. Rizzo, OOE, RO

PDR

Local PDR

NSIC

TIC

Chief, Regulatory News Branch, OIS, HQs

50-261

Reply to ROB - 74-13

As H.

Carolina Power & Light Company

December 16, 1974

File: NG-3513 (R)

Serial: NG-74-1489

Mr. Norman C. Moseley, Director
Directorate of Regulatory Operations
U. S. Atomic Energy Commission
Region II, Suite 818
230 Peachtree Street, N.W.
Atlanta, Georgia 30303

Dear Mr. Moseley:


H. B. ROBINSON UNIT NO. 2
LICENSE NO. DPR-23
RO BULLETIN NO. 74-13

IMPROPER FACTORY WIRING ON GENERAL ELECTRIC MOTOR CONTROL CENTERS AT FORT CALHOUN

In response to RO Bulletin No. 74-13, an investigation was undertaken at the H. B. Robinson Unit No. 2 Plant to determine if any motor control centers at this facility had been improperly wired with G.E. "Vulkene" wire.

All plant motor control centers were manufactured by Westinghouse, which implies that the use of competitive G.E. cable is improbable. Also, a check of accessible cables in these motor control units indicated that no General Electric 2 AWG or 4 AWG, "Vulkene" cable is used in the factory wiring of the units. Additionally, no failures due to incomplete removal of cable insulation have been reported during the operating life of the plant. Therefore, we have concluded that the problem experienced by the Omaha Public Power District does not apply to this facility and our motor control centers meet the original design requirements.

Yours very truly,


E. E. Utley
Vice-President
Bulk Power Supply

KPY:DBW:mvp

cc: Messrs. N. B. Bessac
T. E. Bowman
W. B. Howell
J. B. McGirt
D. V. Menscer
D. B. Waters

RECEIVED
DEC 17 1974
FACILITY
FACILITY
FACILITY