

Letter to N. C. Moseley from Carolina Power and Light Company dated March 17, 1975.

DISTRIBUTION:

50-261

H. D. Thornburg, IE

IE:HQS (5)

Office of Standards Development

Central Files

Division of Reactor Licensing (13)

PDR

Local PDR

NSIC

TIC

STATE

A.O.
4

u



Carolina Power & Light Company

H. B. ROBINSON STEAM ELECTRIC PLANT
Post Office Box 790
Hartsville, South Carolina

March 17, 1975

Robinson File No. 2-0-4-a-1

Mr. Norman C. Moseley, Director
Directorate of Regulatory Operations
U. S. Nuclear Regulatory Commission
Region II, Suite 818
230 Peachtree Street, N.W.
Atlanta, Georgia 30303

Mr. Donald Knuth, Director
Directorate of Regulatory Operations
U. S. Nuclear Regulatory Commission
Washington, D. C. 20545

Dear Sirs:

This is to inform you of an Abnormal Occurrence as required by H. B. Robinson Unit No. 2 Technical Specifications, paragraph 6.6.2.a.


On March 14, 1975, at 1130, a contractor Health Physics Technician received 639 mrem, whole body radiation during transfer of spent resin... to a truck cask.

Exposure results became available at 1157, March 17, 1975.

This is in violation as described in Section 1.8.g of the Plant Technical Specification.

This was reported to Mr. Neal Bender of NRC DRO on March 17, 1975.

Yours very truly,


Jack R. McGirt, Manager
H. B. Robinson SEG Plant

JEM:ala